




SITE PLAN




SITE PROFILE




PERC TEST HOLE 1



PERC TEST HOLE 2



PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 3 min 22 sec
 Hole 2 - Time to fall 1 inch (T value) = 3 min 51 sec
 Hole 3 - Time to fall 1 inch (T value) = 4 min 39 sec
 Average T Value of all three = 3 min 57 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 1

SITE PLAN




SITE PROFILE




⊙ - Perc Test Hole

⊙ - Perc Test Hole


PERC TEST HOLE 1



PERC TEST HOLE 2



PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 6 min 23 sec
 Hole 2 - Time to fall 1 inch (T value) = 5 min 51 sec
 Hole 3 - Time to fall 1 inch (T value) = 5 min 38 sec
 Average T Value of all three = 5 min 57 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 2


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 8 min 26 sec
 Hole 2 - Time to fall 1 inch (T value) = 7 min 23 sec
 Hole 3 - Time to fall 1 inch (T value) = 9 min 47 sec
 Average T Value of all three = 8 min 34 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 3


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




rock at 0.35 metres
no water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = >50 minutes
 Hole 2 - Time to fall 1 inch (T value) = >50 minutes
 Hole 3 - Time to fall 1 inch (T value) = >50 minutes

Imported Fill Recommended

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 4


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




water at 0.4 metres
No Bedrock

PERC TEST HOLE 2



water at 0.4 metres
No Bedrock

PERC TEST HOLE 3



water at 0.4 metres
No Bedrock

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = >50 minutes
 Hole 2 - Time to fall 1 inch (T value) = >50 minutes
 Hole 3 - Time to fall 1 inch (T value) = >50 minutes

Imported Fill Recommended

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 5


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 22 min 06 sec
 Hole 2 - Time to fall 1 inch (T value) = 44 min 22 sec
 Hole 3 - Time to fall 1 inch (T value) = 21 min 30 sec
 Average T Value of all three = 29 min 30 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 6


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 33 min 37 sec
 Hole 2 - Time to fall 1 inch (T value) = 45 min 48 sec
 Hole 3 - Time to fall 1 inch (T value) = 32 min 30 sec
 Average T Value of all three = 37 min 19 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 7


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water


PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 7 min 17 sec
 Hole 2 - Time to fall 1 inch (T value) = 8 min 24 sec
 Hole 3 - Time to fall 1 inch (T value) = 9 min 21 sec
 Average T Value of all three = 8 min 21 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 6 min 59 sec
 Hole 2 - Time to fall 1 inch (T value) = 6 min 37 sec
 Hole 3 - Time to fall 1 inch (T value) = 8 min 29 sec
 Average T Value of all three = 7 min 22 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 9

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 9 min 11 sec
 Hole 2 - Time to fall 1 inch (T value) = 11 min 56 sec
 Hole 3 - Time to fall 1 inch (T value) = >50 minutes
 Average T Value of all three = 10 min 33 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 10


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = >50 minutes
 Hole 2 - Time to fall 1 inch (T value) = >50 minutes
 Hole 3 - Time to fall 1 inch (T value) = >50 minutes

Imported Fill Recommended

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 11

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 6 min 10 sec
 Hole 2 - Time to fall 1 inch (T value) = 6 min 23 sec
 Hole 3 - Time to fall 1 inch (T value) = 5 min 37 sec
 Average T Value of all three = 6 min 03 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 12

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



Rock at 0.30m/ No water

PERC TEST HOLE 3



Rock at 0.30m / No water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = >50 minutes
 Hole 2 - Time to fall 1 inch (T value) = >50 minutes
 Hole 3 - Time to fall 1 inch (T value) = >50 minutes

Imported Fill Recommended

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


**STEPHEN BURT SURVEYS LTD.
 KING'S POINT, NL
 TEL. 709-268-3525**

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C


DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 13


SITE PLAN



SITE PROFILE




PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 5 min 04 sec
 Hole 2 - Time to fall 1 inch (T value) = 5 min 19 sec
 Hole 3 - Time to fall 1 inch (T value) = 5 min 33 sec
 Average T value of all three = 5 min 18 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 14

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 4 min 08 sec
 Hole 2 - Time to fall 1 inch (T value) = 6 min 55 sec
 Hole 3 - Time to fall 1 inch (T value) = 7 min 59 sec
 Average T value of all three = 6 min 21 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 15

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 4 min 42 sec
 Hole 2 - Time to fall 1 inch (T value) = >50 minutes
 Hole 3 - Time to fall 1 inch (T value) = 18 min 58 sec
 Average T value of all three = 11 min 50 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 16

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 5 min 16 sec
 Hole 2 - Time to fall 1 inch (T value) = 4 min 28 sec
 Hole 3 - Time to fall 1 inch (T value) = 6 min 07 sec
 Average T value of all three = 5 min 17 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 17

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 7 min 37 sec
 Hole 2 - Time to fall 1 inch (T value) = 6 min 44 sec
 Hole 3 - Time to fall 1 inch (T value) = 8 min 39 sec
 Average T value of all three = 7 min 40 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
 KING'S POINT, NL
 TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 18

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




Rock at 0.30m/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = NA (rock at 0.30m)
 Hole 2 - Time to fall 1 inch (T value) = 6 min 11 sec
 Hole 3 - Time to fall 1 inch (T value) = 18 min 41 sec
 Average T value of all three = 12 min 26 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 19

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/ Water at 0.30m

PERC TEST HOLE 2



No Bedrock/Water at 0.45m

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

- Hole 1 - Time to fall 1 inch (T value) = >50 minutes
- Hole 2 - Time to fall 1 inch (T value) = >50 minutes
- Hole 3 - Time to fall 1 inch (T value) = >50 minutes

Imported Fill Recommended

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 20

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/ No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 25 min 53 sec
 Hole 2 - Time to fall 1 inch (T value) = 35 min 39 sec
 Hole 3 - Time to fall 1 inch (T value) = 44 min 17 sec
 Average T value of all three = 35 min 15 sec.

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 21

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/ No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 7 min 14 sec
 Hole 2 - Time to fall 1 inch (T value) = 6 min 42 sec
 Hole 3 - Time to fall 1 inch (T value) = 18 min 47 sec
 Average T value of all three = 10 min 54 sec.

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 22

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/ No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 24 min 22 sec
 Hole 2 - Time to fall 1 inch (T value) = 40 min 27 sec
 Hole 3 - Time to fall 1 inch (T value) = 43 min 51 sec
 Average T value of all three = 36 min 24 sec.

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 23

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 6 min 16 sec
 Hole 2 - Time to fall 1 inch (T value) = 5 min 52 sec
 Hole 3 - Time to fall 1 inch (T value) = 5 min 56 sec
 Average T value of all three = 5 min 54 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 26

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 12 min 26 sec
 Hole 2 - Time to fall 1 inch (T value) = 13 min 31 sec
 Hole 3 - Time to fall 1 inch (T value) = 14 min 11 sec
 Average T value of all three = 13 min 22 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
 KING'S POINT, NL
 TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 27

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/ Water at 0.45m

PERC TEST HOLE 2



No Bedrock/Water at 0.45m

PERC TEST HOLE 3



No Bedrock/Water at 0.55m

PERC TEST RESULTS:

- Hole 1 - Time to fall 1 inch (T value) = >50 minutes
- Hole 2 - Time to fall 1 inch (T value) = >50 minutes
- Hole 3 - Time to fall 1 inch (T value) = >50 minutes

Imported Fill Recommended

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


**STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525**

SEPTIC SYSTEM SITE EVALUATION
NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
DATE: DECEMBER 5, 2019
SCALE: NTS


LOT 28

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/ Water at 0.50m

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

- Hole 1 - Time to fall 1 inch (T value) = >50 minutes
- Hole 2 - Time to fall 1 inch (T value) = >50 minutes
- Hole 3 - Time to fall 1 inch (T value) = >50 minutes

Imported Fill Recommended

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.


STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS


LOT 29

SITE PLAN




⊙ - Perc Test Hole

SITE PROFILE




⊙ - Perc Test Hole

PERC TEST HOLE 1




No Bedrock/No Water

PERC TEST HOLE 2



No Bedrock/No Water

PERC TEST HOLE 3



No Bedrock/No Water

PERC TEST RESULTS:

Hole 1 - Time to fall 1 inch (T value) = 5 min 7 sec
 Hole 2 - Time to fall 1 inch (T value) = 4 min 31 sec
 Hole 3 - Time to fall 1 inch (T value) = 5 min 14 sec
 Average T Value of all three = 4 min 57 sec

All Perc Tests and Site walkovers were conducted by Stephen Burt, Ptech, (Registration No. AD-2008 114761 00) during period of November 20 thru December 10, 2019.

STEPHEN BURT SURVEYS LTD.
KING'S POINT, NL
TEL. 709-268-3525

SEPTIC SYSTEM SITE EVALUATION
 NEW BAY POND, PROJECT 004-19-C

DRAWN BY: STEPHEN BURT, PTECH
 DATE: DECEMBER 5, 2019
 SCALE: NTS

LOT 30