



**FOOD PREMISES INSPECTION REPORT
for Non-Compliant
Critical / Non-Critical Items
Date of Report - January 16, 2021**

**Town of Bauline Community Centre
2 Memorial Park Place, Bauline East, NL**

Yearly Operation

For additional information on the Inspection process, please see:

http://www.servicenl.gov.nl.ca/inspections/inspection_information.pdf

Inspection Type and Date	Compliance Item		Observations and Corrective Actions
	Type	Code - Description	
Food - Annual Inspection Feb 11, 2020	Non-Critical Item(s)	606 - Adequate mechanical ventilation	Kitchen range hood needs exterior venting
Food - Routine Inspection Feb 11, 2020	Non-Critical Item(s)	606 - Adequate mechanical ventilation	range hood to be vented out