



FOOD PREMISES INSPECTION REPORT
for Non-Compliant
Critical / Non-Critical Items
Date of Report - Oct 04, 2016

Johnsons Construction Limited
Various locations throughout NL , Corner Brook, NL
Seasonal Operation

For additional information on the inspection process, please see:
http://www.servicenl.gov.nl.ca/inspections/inspection_information.pdf

Inspection Type and Date	Compliance Item Type	Code - Description	Observations and Corrective Actions
Food - Follow-Up Inspection Sep 14, 2016	Non-Critical Item(s)	605 - Adequate lighting; lighting protected	Not all lights are protected. If covers can not be found then replace fixture or use sealed flourscent tubes.
Food - Seasonal Renewal Aug 08, 2016	Critical Item(s)	202 - Adequate Handwashing Facilities Supplied and Accessible	Corrected During Inspection No separate stand alone handwash sink available. Must make third sink as identified during inspection available for hand washing.
	Non-Critical Item(s)	605 - Adequate lighting; lighting protected	Some of the lights are not protected, install missing covers or use sealed flourscent lights.
		606 - Adequate mechanical ventilation	Canopy hood not functioning properly, do investigate.
Food - Compliance Inspection Jun 23, 2015		Compliant at the time of this inspection	