

May 15, 2012

Electrical Bulletin

Information for Electrical Contractors

Information contained in this bulletin does not negate the responsibility of Electrical Contractors, and others, to comply with the requirements of the Canadian Electrical Code, the *Public Safety Act*, the *Electrical Regulations* and the supply authority.

RE: Applying a Permanent Label to the Electrical Panel.

As per Part III, Section 8 (7) Of the *Electrical Regulations* under the *Public Safety Act*:
“Where a registered contractor does work under an installation and repair permit, the contractor shall ensure a permanent label in a pre-printed format acceptable to the chief inspector and bearing the registered contractor's registration number and the year the installation was completed is affixed to the front of the service panel upon completion of an installation or repair”

The Chief Electrical Inspector with Service NL directs that all electrical work performed under an installation and repair permit must have a permanent label affixed to the electrical panel cover identifying the contractor's registration number and ten digit electrical permit number (ie, 2012 123456) at the time of completion. These labels will be provided to the electrical contractor with each electrical permit issued. It is the responsibility of the electrical contractor to ensure the label contains the proper information, is legible, and is affixed to the front cover of the electrical panel.

Mike Mosher
Manager of Electrical Safety Services
Chief Electrical Inspector
Program and Support Services
Confederation Building
P.O.Box 8700
St.John's, NL,Canada A1B 4J6
Telephone (709).729.3517
Facsimile (709).729.5710
E-mail mmosher@gov.nl.ca