
AMENDMENT TO PERMIT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 49

Date: **MAY 18, 2023**

File No: **536-04**

Permit No: **ALT11740-2021**

Amendment No: **1**

Permit Holder: **Nalcor Energy, Churchill Falls
P.O. Box 310
Churchill Falls NLA0R 1A0**

Attention: **Mr. Scottie Blake**

Re: **Menihek Generating Station - Riprap Refurbishment - North Dam, South Dam and Margaret Hamilton Dam**


The original Permit dated MAY 20, 2021 is amended as follows:

The expiry date is extended to May 20, 2025.

Term 9 of the original permit is to be replaced with:

The reservoir side of the North Dam structure must be constructed with rip-rap of D50 = 850 mm to a depth of 1.8 m to provide adequate protection from wave or ice induced erosion.

All other terms and conditions of the original Permit will apply and failure to comply with the terms and conditions of this amendment and the original Permit will render this Permit null and void, place the Permit Holder and their agent(s) in violation of the *Water Resources Act* and make the Permit Holder responsible for taking any remedial measures as may be prescribed by this Department.



(for) MINISTER

File No: **536-04**
Permit No: **ALT11740-2021**
Amendment No: **1**

cc: Fisheries Protection Division
Ecosystem Management Branch
Fisheries and Oceans Canada
P.O. Box 5667
St. John's, NL A1C 5X1
FPP-NL@dfo-mpo.gc.ca

cc: Ms. Deneen Spracklin, P.Eng.
Manager, Drinking Water and Wastewater Section
Water Resources Management Division
Department of Environment and Climate Change
P.O. Box 8700
4th Floor, West Block, Confederation Building
St. John's, NL A1B 4J6
dspracklin@gov.nl.ca

cc: Ms. Paula Dawe, P.Eng.
Manager, Water Rights, Investigations and Modelling Section
Water Resources Management Division
Department of Environment and Climate Change
P.O. Box 8700
4th Floor, West Block, Confederation Building
St. John's, NL A1B 4J6
pauladawe@gov.nl.ca