

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Anchor Point	Anchor Point	Well Cove Brook	Nov 02, 2022	0.02	0.08	LTD	7.10
Appleton	Appleton (+Glenwood)	Gander Lake (The Outflow)	Nov 09, 2022	0.01	0.10	LTD	6.30
Aquaforte	Aquaforte	Davies Pond	Dec 01, 2022	0.01	LTD	0.01	11.00
Arnold's Cove	Arnold's Cove	Steve's Pond (2 Intakes)	Nov 28, 2022	0.01	LTD	LTD	6.80
Avondale	Avondale	Lees Pond	Dec 08, 2022	0.01	0.08	LTD	5.50
Baie Verte	Baie Verte	Southern Arm Pond	Nov 23, 2022	0.01	0.06	LTD	6.90
Baine Harbour	Baine Harbour	Baine Harbour Pond	Nov 09, 2022	0.01	LTD	LTD	13.00
Bartletts Harbour	Bartletts Harbour	Long Pond (same as Castors River North)	Nov 03, 2022	0.02	LTD	LTD	6.80
Bay L'Argent	Bay L'Argent	Sugarloaf Hill Pond	Nov 07, 2022	0.01	LTD	LTD	12.00
Bay Roberts	Bay Roberts	Rocky Pond	Nov 01, 2022	0.01	LTD	LTD	2.30
Bay de Verde	Bay de Verde	Island Pond	Nov 03, 2022	0.01	LTD	0.03	2.90
Beaches	Beaches	Grassey Pond Brook	Nov 01, 2022	0.02	LTD	LTD	6.60
Beachside	Beachside	Long Pond	Nov 16, 2022	0.01	0.07	LTD	5.70
Bellburns	Bellburns	Bound Brook Tributary	Nov 28, 2022	0.05	0.06	LTD	5.80
Belleoram	Belleoram	Rabbits Pond	Nov 23, 2022	0.01	0.09	LTD	16.00
Bellevue	Bellevue	Big Pond	Nov 07, 2022	0.02	LTD	0.01	5.10
Bellevue Beach	Bellevue Beach	Unnamed Brook	Nov 07, 2022	0.01	LTD	0.01	14.00
Benton	Benton	Little Pond	Nov 08, 2022	0.01	LTD	LTD	5.50
Birchy Bay	Birchy Bay	Jumper's Pond	Dec 13, 2022	0.03	0.26	LTD	8.30
Bird Cove	Bird Cove (+Brig Bay)	Inner Gilmour Pond	Nov 03, 2022	0.03	0.06	LTD	9.00
Biscay Bay	Biscay Bay	Unnamed Pond	Nov 03, 2022	0.00	0.05	LTD	7.60
Bishop's Falls	Bishop's Falls	Northern Arm Lake	Nov 08, 2022	0.01	LTD	LTD	3.00
Black Tickle-Domino	Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	Nov 03, 2022	0.01	0.12	0.01	8.60
Black Tickle-Domino	Black Tickle-Domino - PWDU	Martin's Pond - Tap at Pumphouse	Nov 03, 2022	LTD	LTD	0.01	LTD
Bonavista	Bonavista	Long Pond	Nov 29, 2022	0.01	LTD	LTD	6.40
Botwood	Botwood	Northern Arm Lake	Nov 08, 2022	0.01	LTD	LTD	2.90
Branch	Branch	Valley Pond	Nov 01, 2022	0.01	LTD	LTD	9.30
Brent's Cove	Brent's Cove	Paddy's Pond	Nov 22, 2022	0.01	LTD	LTD	13.00
Brig Bay	Brig Bay	Inner Gilmour Pond	Nov 03, 2022	0.03	LTD	0.02	8.40
Brighton	Brighton	Hynes Cove Pond	Nov 22, 2022	0.02	0.05	LTD	8.90
Brigus	Brigus (+Cupids, +South River)	Brigus Long Pond (to Brigus)	Nov 01, 2022	0.01	LTD	LTD	7.00
Buchans	Buchans	Buchans Lake aka Sandy Lake	Nov 16, 2022	0.01	LTD	LTD	8.30

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Buchans Junction	Buchans Junction	Lapland Pond	Nov 16, 2022	0.01	LTD	LTD	7.40
Burgeo	Burgeo	Long Pond	Nov 07, 2022	0.01	0.08	LTD	13.00
Burgoyne's Cove	Burgoyne's Cove	Lower Rocky Pond	Nov 30, 2022	0.01	LTD	LTD	2.70
Burin	Burin (+Lewin's Cove)	Big Pond	Nov 09, 2022	0.01	LTD	0.01	5.30
Burin	Port au Bras	Gripe Cove Pond	Nov 09, 2022	0.02	LTD	LTD	4.70
Burin	Burin	Long Pond	Nov 09, 2022	0.01	0.07	LTD	4.20
Burlington	Burlington	Eastern Island Pond	Nov 23, 2022	0.01	LTD	0.01	8.20
Burnt Islands	Burnt Islands	Long Lake	Nov 30, 2022	0.01	0.06	LTD	7.60
Burnt Islands	Burnt Islands - PWDU	Long Lake	Nov 30, 2022	LTD	LTD	LTD	LTD
Campbellton	Campbellton	Indian Arm Brook	Nov 15, 2022	0.01	LTD	LTD	4.90
Cape Freels North	Cape Freels North	Long Pond	Nov 08, 2022	0.01	0.07	LTD	8.60
Cape St. George	Cape St. George, Red Brook, De-Grau, Marches Point	Rouzes Brook	Nov 24, 2022	0.05	0.25	LTD	1.50
Caplin Cove-Southport	Southport	Button's Pond	Nov 25, 2022	0.01	LTD	LTD	5.90
Carbonear	Carbonear	Island Pond / Flings Long Pond	Nov 28, 2022	0.01	LTD	LTD	3.70
Carmanville	Carmanville	Grandfathers Pond	Nov 09, 2022	0.01	LTD	0.01	3.80
Cartwright	Cartwright	Burdett's Pond	Oct 03, 2022	0.01	LTD	LTD	12.00
Cartwright	Cartwright - PWDU	Burdett's Pond	Oct 03, 2022	LTD	LTD	LTD	LTD
Castor River North	Castor River North	Long Pond (same as Bartletts Harbour)	Nov 03, 2022	0.02	LTD	LTD	6.50
Castor River South	Castor River South	Unnamed	Nov 03, 2022	0.05	0.12	LTD	2.70
Cavendish	Cavendish	Long Pond	Nov 14, 2022	0.01	LTD	LTD	3.60
Centreville-Wareham-Trinity	Centreville-Wareham	Northwest Pond	Nov 08, 2022	0.01	0.08	LTD	5.20
Centreville-Wareham-Trinity	Trinity	Southwest Feeder Pond	Nov 08, 2022	0.01	LTD	0.01	5.30
Chanceport	Chanceport	Bridger's Cove Pond	Dec 09, 2022	0.02	0.18	LTD	16.00
Channel-Port aux Basques	Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Nov 30, 2022	0.01	0.06	LTD	2.10
Charlottetown (Labrador)	Charlottetown (Labrador) - PWDU	Middle Pond	Oct 05, 2022	LTD	LTD	0.01	LTD
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Oct 05, 2022	0.01	LTD	LTD	11.00
Churchill Falls	Churchill Falls	Smallwood Reservoir	Oct 20, 2022	0.01	LTD	LTD	29.00
Clarenville	Clarenville, Shoal Harbour	Shoal Harbour River	Nov 29, 2022	0.01	0.07	LTD	3.00
Clarke's Beach	Clarke's Beach	Clarke's Pond	Nov 01, 2022	0.01	LTD	LTD	3.10
Colliers	Colliers	Bedlam Pond	Dec 08, 2022	0.00	LTD	LTD	5.80
Come By Chance	Come By Chance	Butchers Brook	Nov 25, 2022	0.01	LTD	LTD	0.60
Comfort Cove-Newstead	Comfort Cove-Newstead	Steady Cove Pond	Dec 09, 2022	0.03	0.07	LTD	1.90

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	Nov 01, 2022	0.01	0.08	LTD	2.10
Conche	Conche	Martin's Brook	Nov 01, 2022	0.02	LTD	LTD	18.00
Conne River	Conne River	Southwest Brook	Nov 09, 2022	0.00	LTD	LTD	LTD
Cook's Harbour	Cook's Harbour	Unnamed Pond	Nov 02, 2022	0.07	LTD	LTD	5.40
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Nov 07, 2022	0.01	0.08	LTD	1.50
Cottlesville	Cottlesville	Rushy Cove Pond	Dec 09, 2022	0.04	LTD	0.07	LTD
Cottrell's Cove	Cottrell's Cove	Cottrell's Pond	Nov 29, 2022	0.03	LTD	LTD	6.50
Cow Head	Cow Head - PWDU	Short Cat Path Pond	Nov 28, 2022	LTD	LTD	LTD	0.55
Cow Head	Cow Head	Short Cat Path Pond	Nov 28, 2022	0.02	LTD	LTD	7.90
Cox's Cove	Cox's Cove	Cox's Brook	Nov 10, 2022	0.02	0.06	0.01	4.60
Crow Head	Crow Head	Oars Pond	Dec 14, 2022	0.02	0.09	LTD	7.70
Cupids	Cupids	Brigus Long Pond (to Brigus)	Nov 01, 2022	0.01	LTD	LTD	7.00
Daniel's Harbour	Daniel's Harbour	Unnamed Spring & Brook	Nov 28, 2022	0.06	0.35	LTD	3.30
Deadman's Bay	Deadman's Bay	Deadman's Pond	Nov 08, 2022	0.00	LTD	0.01	4.40
Deep Bight	Deep Bight	Deep Bight River	Dec 08, 2022	0.02	LTD	LTD	8.40
Deer Lake	Deer Lake (+Reidville)	Humber Canal, Grand Lake	Nov 16, 2022	0.01	0.11	0.01	4.00
Dildo	Dildo, Broad Cove (+South Dildo)	Broad Cove Pond	Nov 14, 2022	0.01	LTD	LTD	6.00
Eddies Cove West	Eddies Cove West	Unnamed	Nov 03, 2022	0.03	LTD	LTD	10.00
Elliston	Elliston	Big Pond	Nov 29, 2022	0.01	0.12	LTD	2.70
Embree	Embree (+Little Burnt Bay)	Troke's Cove Pond	Nov 15, 2022	0.02	LTD	LTD	5.70
Englee	Englee	Island Cove Pond	Nov 01, 2022	0.01	LTD	LTD	10.00
Fairbanks-Hillgrade	Fairbanks-Hillgrade	Saltine's Pond	Dec 14, 2022	0.02	LTD	LTD	7.00
Fermeuse	Fermeuse, Kingman's	Merrymeeting Pond, Bear Cove Pond (2 intakes)	Dec 01, 2022	0.01	LTD	LTD	17.00
Ferryland	Ferryland	Deep Cove Pond	Dec 01, 2022	0.01	LTD	0.02	6.40
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Nov 22, 2022	0.01	LTD	LTD	11.00
Flower's Cove	Flower's Cove (+Nameless Cove)	French Island Pond	Nov 02, 2022	0.02	0.06	LTD	5.50
Fogo Island	Seldom-Little Seldom	Bullock Cove Pond	Nov 30, 2022	0.01	LTD	LTD	9.80
Fogo Island	Seldom-Little Seldom - PWDU	Bullock Cove Pond	Nov 30, 2022	LTD	LTD	0.06	LTD
Fogo Island	Fogo - PWDU	Freeman's Pond	Nov 30, 2022	LTD	LTD	LTD	LTD
Fogo Island	Fogo	Freeman's Pond	Nov 30, 2022	0.02	0.06	LTD	13.00
Fogo Island	Joe Batt's Arm-Barr'd Islands-Shoal Bay	Long Pond	Nov 30, 2022	0.01	0.07	LTD	8.40
Fogo Island	Tilting	Sandy Cove Pond	Nov 30, 2022	0.01	0.08	LTD	9.90

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Forresters Point	Forresters Point	Rudges Pond	Nov 02, 2022	0.03	LTD	0.03	7.30
Forteau	Forteau	Trout Brook	Oct 04, 2022	0.03	LTD	0.01	4.00
Fortune	Fortune (+Grand Bank)	Horsebrook	Nov 08, 2022	0.01	0.10	LTD	5.30
Fox Cove-Mortier	Fox Cove-Mortier	Rock Pond	Nov 09, 2022	0.01	0.06	0.01	7.80
Francois	Francois	Our Pond	Nov 15, 2022	0.00	0.08	LTD	5.60
Frenchman's Cove	Frenchman's Cove	Dug Well	Nov 08, 2022	0.02	0.12	LTD	3.50
Freshwater	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	Nov 28, 2022	0.21	2.00	LTD	0.69
Gallants	Gallants	Gallant's Brook	Dec 13, 2022	0.05	0.11	0.03	0.67
Gambo	Gambo	Dark Cove Pond	Nov 08, 2022	0.01	LTD	LTD	5.30
Gander	Gander	Gander Lake	Nov 09, 2022	0.01	0.14	0.01	4.80
Gander Bay South	George's Point, Harris Point	Barry's Brook	Nov 09, 2022	0.01	0.08	0.01	5.20
Gander Bay South	Gander Bay South - PWDU	Barry's Brook	Nov 09, 2022	LTD	LTD	LTD	LTD
Garden Cove	Garden Cove	Arch Cove Pond	Nov 30, 2022	0.01	LTD	LTD	8.40
Garnish	Garnish	Witchazel Pond	Nov 08, 2022	0.01	LTD	LTD	7.60
Gaskiers	Gaskiers-Point La Haye	Big Hare Hill Pond	Nov 03, 2022	0.01	LTD	LTD	10.00
Gaultois	Gaultois - PWDU	Piccaire Pond	Nov 28, 2022	0.01	1.60	0.01	0.56
Gaultois	Gaultois	Piccaire Pond	Nov 28, 2022	0.01	LTD	LTD	29.00
George's Brook-Milton	George's Brook-Milton	George's Brook	Nov 28, 2022	0.02	0.13	0.01	13.00
Georgetown	Georgetown	Third Pond	Dec 08, 2022	0.01	0.09	LTD	4.30
Gillams	Gillams	Meaters Pond	Dec 08, 2022	0.02	LTD	LTD	4.30
Glenburnie-Birchy Head-Shoal Brook	Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Nov 02, 2022	0.04	0.15	LTD	3.50
Glenwood	Glenwood	Gander Lake (The Outflow)	Nov 09, 2022	0.01	0.08	0.01	6.30
Glovertown	Glovertown	Northwest Pond	Nov 28, 2022	0.01	0.06	LTD	7.00
Goobies	Goobies	Water Pond	Nov 30, 2022	0.00	LTD	LTD	9.70
Goose Cove East	Goose Cove East	Jack's Pond	Nov 01, 2022	0.02	LTD	LTD	12.00
Grand Bank	Grand Bank	Horsebrook	Nov 08, 2022	0.01	0.09	LTD	5.20
Grand Falls-Windsor	Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Nov 08, 2022	0.01	LTD	LTD	3.30
Grand Le Pierre	Grand Le Pierre	Nip Nose Pond	Nov 07, 2022	0.00	0.05	0.01	8.20
Great Brehat	Great Brehat	Little Steady Pond	Nov 02, 2022	0.03	LTD	LTD	14.00
Green Island Brook	Green Island Brook	Green Island Brook	Nov 02, 2022	0.03	LTD	0.01	6.30
Greenspond	Greenspond	Shambler's Cove Pond	Nov 08, 2022	0.01	0.10	LTD	7.00
Grey River	Grey River	Big Charlie's Pond	Dec 16, 2022	0.01	LTD	LTD	11.00

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Hampden	Hampden	Elliot Brook	Nov 01, 2022	0.06	LTD	0.03	4.30
Hant's Harbour	Hant's Harbour	Eastern Pond (Halfway Brook)	Nov 03, 2022	0.01	LTD	LTD	3.90
Happy Adventure	Happy Adventure	Goose Neck Pond	Nov 28, 2022	0.01	LTD	LTD	7.90
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	Oct 21, 2022	0.02	LTD	LTD	1.20
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	Oct 21, 2022	0.04	LTD	LTD	1.20
Harbour Breton	Harbour Breton	Connaigra Pond, Hutchings Pond	Nov 23, 2022	0.02	0.09	LTD	6.60
Harbour Grace	Harbour Grace, Harbour Grace South (+Riverhead)	Bannerman Lake	Nov 01, 2022	0.01	LTD	LTD	2.70
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Nov 08, 2022	0.01	LTD	LTD	7.50
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Dec 07, 2022	0.01	LTD	LTD	9.30
Hawke's Bay	Hawke's Bay	Torrent River	Nov 08, 2022	0.02	0.05	LTD	5.50
Heart's Content	Heart's Content	Southern Cove Pond	Nov 08, 2022	0.00	LTD	LTD	2.90
Heart's Delight-Islington	Heart's Delight-Islington	Long Pond	Nov 14, 2022	0.01	LTD	LTD	2.60
Heart's Desire	Heart's Desire	Terrence Pond	Nov 14, 2022	0.01	LTD	0.01	2.90
Hermitage	Hermitage-Sandyville	Granfer's Pond	Nov 23, 2022	0.01	LTD	0.01	14.00
Hermitage	Hermitage-Sandyville - PWDU	Granfer's Pond	Nov 23, 2022	LTD	LTD	LTD	LTD
Herring Neck	Herring Neck, Hatchet Harbour, Salt Harbour, Shoal Cove, Sunnyside	Gut Pond	Dec 14, 2022	0.03	0.07	LTD	5.80
Hickman's Harbour-Robinson Bight	Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Dec 08, 2022	0.01	LTD	LTD	4.00
Hopedale	Hopedale	American Pond	Nov 01, 2022	0.01	LTD	LTD	4.60
Howley	Howley	Sandy Lake	Nov 16, 2022	0.01	0.07	LTD	7.30
Howley	Howley - PWDU	Sandy Lake	Nov 16, 2022	LTD	LTD	LTD	0.54
Hughes Brook	Hughes Brook	Reservoir	Dec 01, 2022	0.03	0.23	LTD	1.90
Humber Arm South	Halfway Point, Benoit's Cove, John's Beach	Dormody's Brook	Nov 07, 2022	0.02	0.17	0.01	1.90
Humber Arm South	Frenchman's Cove Area	Gurges Pond	Nov 07, 2022	0.05	LTD	LTD	3.80
Indian Bay	Indian Bay	Indian Bay Brook	Nov 08, 2022	0.01	0.07	LTD	4.80
Irishtown-Summerside	Irishtown	Irishtown Brook	Nov 10, 2022	0.03	0.21	LTD	5.80
Irishtown-Summerside	Summerside	Pynn's Pond	Nov 10, 2022	0.02	0.05	0.01	7.10
Isle aux Morts	Isle aux Morts	Burnt Ground Pond	Nov 30, 2022	0.01	LTD	LTD	6.30
Isle aux Morts	Isle aux Morts - PWDU	Burnt Ground Pond	Nov 30, 2022	LTD	LTD	LTD	LTD
Jackson's Arm	Jackson's Arm	Unnamed Brook	Nov 01, 2022	0.03	LTD	LTD	7.60
Jackson's Arm	Jackson's Arm - PWDU	Unnamed Brook	Nov 01, 2022	LTD	LTD	LTD	LTD
Jackson's Cove-Langdon's Cove-Silverdale	Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Nov 16, 2022	0.01	0.08	LTD	3.70

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Keels	Keels	Boland's Pond	Nov 29, 2022	0.02	LTD	0.02	25.00
Keels	Keels	Boland's Pond	Dec 20, 2022	0.01	LTD	LTD	19.00
King's Point	King's Point	Bulley's Pond	Nov 16, 2022	0.01	LTD	LTD	6.10
King's Point	King's Point	Bulley's Pond	Dec 12, 2022	0.01	0.08	LTD	7.50
L'Anse au Clair	L'Anse au Clair	Park Pond	Oct 04, 2022	0.03	LTD	LTD	3.00
L'Anse au Loup	L'Anse au Loup	L'anse Au Loup River	Oct 04, 2022	0.01	LTD	LTD	3.10
La Poile	La Poile	Black Duck Pond	Dec 20, 2022	0.01	LTD	LTD	11.00
LaScie	La Scie	Stakes Pond	Nov 22, 2022	0.01	LTD	LTD	5.90
Labrador City	Labrador City	Beverly Lake	Oct 20, 2022	0.01	LTD	LTD	2.50
Lamaline	Lamaline	Upper Hodges Pond	Nov 08, 2022	0.01	LTD	0.02	10.00
Lamaline	Lamaline - PWDU	Upper Hodges Pond	Nov 08, 2022	LTD	0.05	LTD	LTD
Lark Harbour	Lark Harbour	Fairfax Brook	Nov 07, 2022	0.02	0.31	LTD	4.40
Lawn	Lawn - PWDU	Brazil Pond	Nov 08, 2022	LTD	LTD	0.01	0.56
Lawn	Lawn	Brazil Pond	Nov 08, 2022	0.01	0.07	LTD	9.30
Leading Ticks	Leading Ticks	Cook's Pond	Nov 29, 2022	0.02	LTD	0.01	10.00
Leading Ticks	Leading Ticks - PWDU	Cook's Pond	Nov 29, 2022	LTD	LTD	0.02	1.30
Lewin's Cove	Lewin's Cove	Big Pond	Nov 08, 2022	0.01	LTD	0.01	5.80
Lewisporte	Lewisporte	Stanhope Pond	Nov 15, 2022	0.02	LTD	LTD	6.50
Little Bay	Little Bay	First Pond	Nov 16, 2022	0.01	0.18	LTD	2.10
Little Bay	Little Bay	Mine Pond	Nov 16, 2022	0.02	LTD	LTD	4.50
Little Burnt Bay	Little Burnt Bay	Troke's Cove Pond	Nov 15, 2022	0.02	LTD	LTD	5.70
Little Harbour East	Little Harbour East (Placentia Bay)	Unnamed Pond	Nov 07, 2022	0.01	0.06	LTD	8.80
Long Harbour-Mount Arlington Heights	Long Harbour-Mount Arlington Heights	Shingle Pond and/or Trout Pond (2 Intakes)	Nov 18, 2022	0.02	LTD	0.01	2.90
Loon Bay	Loon Bay	Southeast Pond	Dec 09, 2022	0.02	0.10	LTD	6.00
Lourdes	Lourdes (+West Bay)	Victor's Brook	Nov 23, 2022	0.09	0.21	LTD	7.60
Lower Lance Cove	Lower Lance Cove	Big Long Pond	Dec 08, 2022	0.01	LTD	LTD	5.40
Lumsden	Lumsden	Gull Pond	Nov 08, 2022	0.00	LTD	0.01	3.70
Main Brook	Main Brook	Joe Burt's Pond	Nov 01, 2022	0.02	LTD	LTD	5.70
Mainland	Mainland	Caribou Brook	Nov 24, 2022	0.07	0.28	LTD	2.90
Makkovik	Makkovik	Ranger Bight Pond	Nov 01, 2022	0.02	LTD	0.01	5.50
Makkovik	Makkovik - PWDU	Ranger Bight Pond	Nov 01, 2022	0.01	0.06	LTD	LTD
Mary's Harbour	Mary's Harbour - PWDU	St. Mary's River	Oct 04, 2022	LTD	LTD	LTD	0.59
Mary's Harbour	Mary's Harbour	St. Mary's River	Oct 04, 2022	0.00	LTD	LTD	7.70

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Marystown	Marystown	Fox Hill Reservoir / Clam Pond	Nov 08, 2022	0.02	LTD	0.01	2.20
Massey Drive	Massey Drive	Trout Pond, Third Pond (2 intakes)	Nov 07, 2022	0.01	0.08	LTD	1.70
Mclvers	Mclvers	Mclvers Brook	Nov 09, 2022	0.06	0.10	0.01	3.20
Meadows	Meadows, Summerside West	Meaters Pond	Dec 08, 2022	0.02	LTD	LTD	4.50
Merritt's Harbour	Merritt's Harbour	Jimmy's Pond	Dec 14, 2022	0.02	LTD	LTD	7.10
Middle Arm	Middle Arm	Dam Pond Brook	Nov 23, 2022	0.01	0.09	LTD	6.10
Miles Cove	Miles Cove	Paddock's Pond	Nov 22, 2022	0.01	0.07	LTD	5.30
Millertown	Millertown	Water Pond	Nov 16, 2022	0.01	0.05	LTD	6.90
Milltown-Head of Bay D'Espoir	Milltown, Head of Bay D'Espoir	Jersey Pond	Nov 09, 2022	0.03	LTD	0.01	8.40
Ming's Bight	Ming's Bight	Middle Brook Pond	Nov 22, 2022	0.01	0.06	LTD	5.80
Morrisville	Morrisville	Morrisville Pond	Nov 09, 2022	0.03	0.06	LTD	5.30
Mount Moriah	Mount Moriah	Trout Pond, Third Pond (2 intakes)	Nov 07, 2022	0.01	0.08	LTD	1.50
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	Nov 01, 2022	0.01	0.08	LTD	2.10
Musgrave Harbour	Musgrave Harbour	Rocky Pond	Nov 08, 2022	0.01	LTD	0.01	3.10
Nain	Nain	Trouser Lake	Nov 01, 2022	0.01	0.06	0.01	2.00
Nameless Cove	Nameless Cove / Flower Cove	French Island Pond	Nov 02, 2022	0.02	0.07	LTD	5.40
Natuashish	Natuashish (Sango Bay)	Sango Brook and Wellfield	Nov 01, 2022	0.11	LTD	0.04	1.60
New Chelsea-New Melbourne-Brownsdale-Sibley's Cove-Lead Cove	Sibley's Cove, Lead Cove	Sibley's Cove Pond	Nov 03, 2022	0.01	LTD	LTD	2.80
New Perlican	New Perlican	New Perlican River	Nov 03, 2022	0.01	LTD	LTD	3.50
New-Wes-Valley	Wesleyville-Badger's Quay-Pool's Island, Brookfield-Poundcove-Newtown-Templeman	Little Northwest Pond	Nov 08, 2022	0.00	0.06	LTD	7.40
Newman's Cove	Newman's Cove	Heale Pond Brook	Nov 29, 2022	0.01	LTD	LTD	20.00
Nippers Harbour	Nippers Harbour	Blackhead Pond Brook	Nov 22, 2022	0.00	LTD	0.01	7.50
Norman's Cove-Long Cove	Norman's Cove-Long Cove	John Newhooks Pond	Nov 22, 2022	0.01	LTD	LTD	4.90
Norris Arm	Norris Arm (south)	Mill Lake	Nov 15, 2022	0.01	LTD	LTD	4.60
Norris Point	Norris Point	Neddy Harbour Pond	Nov 16, 2022	0.02	LTD	LTD	4.30
North Harbour	North Harbour	Grandfather's Pond	Nov 30, 2022	0.01	LTD	LTD	10.00
Northern Arm	Northern Arm	Northern Arm Lake	Nov 08, 2022	0.01	LTD	LTD	2.80
Old Perlican	Old Perlican	Bell Pond	Nov 03, 2022	0.01	LTD	LTD	3.20
Pacquet	Pacquet - PWDU	Big Brook	Nov 22, 2022	LTD	LTD	LTD	LTD
Pacquet	Pacquet	Big Brook	Nov 22, 2022	0.00	LTD	LTD	12.00

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Paradise	Paradise	Bay Bulls Big Pond	Nov 01, 2022	0.01	0.07	LTD	2.10
Parkers Cove	Parkers Cove	Unnamed brook	Nov 07, 2022	0.01	LTD	LTD	14.00
Parson's Pond	Parson's Pond	Cold Brook	Nov 28, 2022	0.16	0.53	0.06	1.90
Pasadena	Pasadena	Blue Gulch Pond	Dec 07, 2022	0.02	LTD	0.01	4.70
Peterview	Peterview	Northern Arm Lake	Nov 08, 2022	0.01	LTD	LTD	3.40
Petit Forte	Petit Forte	Reddy's Pond	Nov 09, 2022	0.01	LTD	0.01	7.60
Petty Harbour-Maddox Cove	Petty Harbour-Maddox Cove	Western Barrens Pond	Dec 01, 2022	0.01	LTD	LTD	4.30
Phillips Head	Phillips Head	Dogberry Brook	Nov 29, 2022	0.02	0.18	LTD	9.70
Piccadilly Head	Piccadilly Head (+West Bay)	Unnamed Brook	Nov 29, 2022	0.13	LTD	LTD	12.00
Pidgeon Cove-St. Barbe	Pigeon Cove - St. Barbe	Long Pond	Nov 02, 2022	0.01	LTD	0.02	8.30
Pilley's Island	Pilley's Island	Loadabats Pond	Nov 22, 2022	0.05	0.09	LTD	4.50
Placentia	Freshwater, Argentia site, Dunville	Clarks Pond	Nov 18, 2022	0.02	LTD	0.01	9.30
Placentia	Placentia, Jersey side, SE Placentia	Larkins Pond	Nov 18, 2022	0.02	LTD	LTD	6.50
Placentia	Dunville	Wyses Pond (Backup Supply)	Nov 18, 2022	0.02	0.05	LTD	9.30
Pleasantview	Pleasantview	Little Arm Pond	Nov 29, 2022	0.02	0.06	LTD	11.00
Plum Point	Plum Point	Grand Pond	Nov 03, 2022	0.02	LTD	LTD	6.30
Point Lance	Point Lance	Unnamed Pond	Nov 01, 2022	0.01	0.08	LTD	17.00
Point Leamington	Point Leamington	Little Pond	Nov 29, 2022	0.02	LTD	LTD	7.20
Point May	Point May	Short's Pond	Nov 08, 2022	0.01	LTD	LTD	13.00
Point May	Point May - PWDU	Short's Pond	Nov 08, 2022	0.00	LTD	0.01	0.71
Point of Bay	Point of Bay	Indian Cove Pond	Nov 29, 2022	0.01	LTD	LTD	5.80
Pollards Point	Pollards Point, Country Cove	Country Cove Pond	Nov 01, 2022	0.03	LTD	LTD	5.30
Pollards Point	Pollards Point East	George Ricks Pond	Dec 12, 2022	0.01	LTD	0.02	7.50
Pool's Cove	Pool's Cove	Widgeon Pond	Nov 23, 2022	0.01	0.13	LTD	8.20
Pool's Cove	Pool's Cove	Widgeon Pond	Dec 15, 2022	0.01	0.15	LTD	7.10
Pool's Cove	Pool's Cove	Widgeon Pond	Dec 15, 2022	0.01	0.15	LTD	7.10
Port Albert	Port Albert	Beaverton Pond	Dec 13, 2022	0.03	0.40	LTD	11.00
Port Anson	Port Anson	Anchor Pond	Nov 22, 2022	0.01	LTD	LTD	8.30
Port Blandford	Port Blandford	Noseworthy's Pond	Nov 30, 2022	0.02	0.05	LTD	5.10
Port Hope Simpson	Port Hope Simpson	Arnold's Brook and Pond	Oct 04, 2022	0.00	LTD	LTD	10.00
Port Saunders	Port Saunders - PWDU	Tom Taylor's Pond	Nov 08, 2022	0.01	LTD	LTD	0.70
Port Saunders	Port Saunders	Tom Taylor's Pond	Nov 08, 2022	0.02	LTD	LTD	6.70



## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Port au Choix	Port au Choix	Winterhouse Pond	Nov 08, 2022	0.07	0.23	LTD	8.90
Port au Choix	Port au Choix - PWDU	Winterhouse Pond	Nov 08, 2022	0.00	0.16	LTD	LTD
Portland Creek	Portland Creek	Unnamed Streams	Nov 28, 2022	0.09	0.14	LTD	2.30
Portugal Cove South	Portugal Cove South	Wrights Brook	Nov 03, 2022	0.01	LTD	LTD	7.00
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	Nov 01, 2022	0.01	0.08	LTD	2.10
Postville	Postville	Big Pond	Nov 01, 2022	0.01	LTD	LTD	6.60
Postville	Postville - PWDU	Big Pond	Nov 01, 2022	LTD	LTD	0.01	0.51
Pouch Cove	Pouch Cove	North Three Island Pond	Nov 02, 2022	0.00	LTD	LTD	0.66
Purcell's Harbour	Purcell's Harbour	Purcell's Harbour Pond	Dec 14, 2022	0.02	0.05	LTD	21.00
Pynn's Brook	Pynn's Brook	Pynn's Brook	Dec 07, 2022	0.05	0.09	LTD	7.70
Ramea	Ramea	Northwest Pond	Nov 27, 2022	0.09	0.08	LTD	3.00
Ramea	Ramea - PWDU	Northwest Pond	Nov 27, 2022	0.01	0.06	LTD	LTD
Random Sound West	Queen's Cove	Reservoir	Dec 05, 2022	0.01	LTD	LTD	8.00
Rattling Brook	Rattling Brook	Mark's Pond Brook	Nov 16, 2022	0.00	LTD	LTD	6.40
Red Bay	Red Bay	Northern Brook	Oct 04, 2022	0.01	LTD	LTD	6.20
Reidville	Reidville	Humber Canal, Grand Lake	Nov 16, 2022	0.01	0.12	LTD	3.90
Rigolet	Rigolet - PWDU	Rigolet Pond	Nov 01, 2022	LTD	LTD	LTD	0.57
Rigolet	Rigolet	Rigolet Pond	Nov 01, 2022	0.02	LTD	LTD	14.00
River of Ponds	River of Ponds	Burnt Head Ponds	Nov 08, 2022	0.02	LTD	LTD	5.60
Robert's Arm	Robert's Arm	Young's Pond / Dam Pond	Nov 22, 2022	0.03	0.06	LTD	4.60
Rocky Harbour	Rocky Harbour	Gull Pond	Nov 16, 2022	0.03	LTD	LTD	21.00
Roddickton-Bide Arm	Roddickton	East Brook Pond	Nov 01, 2022	0.03	0.08	0.01	3.60
Roddickton-Bide Arm	Bide Arm	First Clay Cove Pond	Nov 01, 2022	0.03	LTD	LTD	4.90
Rose Blanche-Harbour Le Cou	Rose Blanche-Harbour Le Cou	Rose Blanche Brook	Nov 30, 2022	0.01	LTD	LTD	5.50
Rushoon	Rushoon	Big Pond Brook	Nov 09, 2022	0.01	0.08	LTD	9.80
Salmon Cove	Salmon Cove	Rocky Pond	Nov 28, 2022	0.01	LTD	LTD	3.60
Salvage	Salvage	Wild Cove Pond	Nov 28, 2022	0.02	LTD	LTD	14.00
Seal Cove (FB)	Seal Cove, F.B.	Big Black Duck Pond	Nov 23, 2022	0.01	LTD	LTD	17.00
Seal Cove (FB)	Seal Cove, F.B. - PWDU	Big Black Duck Pond	Nov 23, 2022	LTD	LTD	LTD	LTD
Seal Cove (WB)	Seal Cove, W.B.	Seal Cove Brook & Long Pond	Nov 22, 2022	0.02	LTD	LTD	9.50
Sheaves Cove	Sheaves Cove	Unnamed Brook	Nov 24, 2022	0.07	0.30	LTD	4.00
Shoe Cove	Shoe Cove	Second Pond	Nov 22, 2022	0.01	LTD	LTD	12.00
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#10 Well - Cantwood Hill Well	Nov 28, 2022	1.10	0.08	LTD	0.70

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Smith's Harbour	Smith's Harbour	Fleshetts Brook	Nov 23, 2022	0.01	0.07	LTD	8.30
Sop's Arm	Sop's Arm	Little Tickle Pond	Nov 01, 2022	0.03	LTD	LTD	10.00
Sop's Arm	Sop's Arm	Little Tickle Pond	Dec 12, 2022	0.03	0.09	LTD	9.80
Sop's Arm	Sop's Arm	Little Tickle Pond	Dec 12, 2022	0.03	0.08	LTD	9.90
South Brook	South Brook	Next to Brook	Nov 16, 2022	0.04	0.32	LTD	LTD
South Dildo	South Dildo	Broad Cove Pond	Nov 22, 2022	0.01	LTD	LTD	6.30
South Dildo	South Dildo	Broad Cove Pond	Dec 05, 2022	0.01	LTD	LTD	7.10
South Dildo	South Dildo	Broad Cove Pond	Dec 05, 2022	0.01	LTD	LTD	7.00
South Dildo	South Dildo	Broad Cove Pond	Dec 05, 2022	0.10	LTD	0.01	LTD
South River	South River	Brigus Long Pond (to Brigus)	Nov 01, 2022	0.01	LTD	LTD	7.00
Southern Harbour	Southern Harbour	Brigades Pond	Nov 07, 2022	0.02	0.05	0.01	6.10
Spaniard's Bay	Spaniard's Bay (+Upper Island Cove, + Bryant's Cove)	Kelly's Pond (Spider's Pond)	Nov 01, 2022	0.00	LTD	LTD	3.40
Springdale	Springdale	Sullivan's Pond (2 Intakes)	Nov 16, 2022	0.01	0.05	LTD	4.00
St. Alban's	St. Alban's	Well Field	Nov 09, 2022	0.02	0.27	LTD	LTD
St. Anthony	St. Anthony	St. Anthony Pond	Nov 01, 2022	0.01	0.07	LTD	6.20
St. Bernard's-Jacques Fontaine	St. Bernard's-Jacques Fontaine	Rattle Brook	Nov 07, 2022	0.01	LTD	0.01	7.10
St. Bride's	St. Bride's	North Side Brook	Nov 01, 2022	0.03	LTD	LTD	5.60
St. Bride's	St. Bride's	South Side Brook	Nov 01, 2022	0.02	LTD	LTD	18.00
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Nov 01, 2022	0.01	0.08	LTD	2.30
St. John's	St. John's	Petty Harbour Long Pond	Nov 01, 2022	0.01	LTD	LTD	1.90
St. John's	St. John's	Windsor Lake	Nov 01, 2022	0.01	LTD	LTD	2.40
St. Joseph's	St. Joseph's S.M.B.	Drilled	Nov 03, 2022	0.13	LTD	LTD	1.30
St. Judes	St. Judes	Chute Brook	Dec 07, 2022	0.07	LTD	LTD	5.70
St. Judes	St. Judes	Uncle Arthur Brook	Dec 07, 2022	0.05	0.09	LTD	13.00
St. Lawrence	St. Lawrence	St. Lawrence River	Nov 08, 2022	0.01	0.06	LTD	8.30
St. Lewis	St. Lewis	Tub Harbour Pond	Oct 04, 2022	0.01	LTD	LTD	13.00
St. Lunaire-Griquet	St. Lunaire-Griquet	Joe's Pond	Nov 02, 2022	0.03	0.05	LTD	13.00
St. Lunaire-Griquet	Gunners Cove	Lookout Brook	Nov 02, 2022	0.07	0.07	LTD	11.00
St. Pauls	St. Pauls	Two Mile Pond	Nov 28, 2022	0.04	0.10	LTD	7.10
St. Shott's	St. Shott's	Unnamed Pond	Nov 03, 2022	0.01	LTD	0.02	4.30
Steady Brook	Steady Brook	Wellfield + Steady Brook	Dec 07, 2022	0.03	LTD	LTD	8.50
Stephenville	Stephenville	Well Field	Nov 29, 2022	0.14	0.13	LTD	LTD

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Stoneville	Stoneville	Dog Bay Pond Brook	Dec 13, 2022	0.02	0.10	LTD	5.80
Straitsview	Straitsview	Saddle Hill Pond	Nov 02, 2022	0.04	LTD	LTD	17.00
Summerford	Summerford (+Cottlesville)	Rushy Cove Pond	Dec 09, 2022	0.04	LTD	LTD	8.60
Sunnyside (T.B.)	Sunnyside	Center Cove River	Nov 25, 2022	0.01	LTD	LTD	10.00
Terrenceville	Terrenceville	Big Brook	Nov 07, 2022	0.00	LTD	0.01	6.60
Thornlea	Thornlea	Big Bakeapple Pond	Nov 07, 2022	0.03	LTD	LTD	7.30
Tilt Cove	Tilt Cove	Castle Rock Pond	Nov 22, 2022	0.02	LTD	LTD	3.40
Tizzard's Harbour	Tizzard's Harbour	Rocky Pond	Dec 09, 2022	0.01	LTD	LTD	13.00
Torbay	Torbay	North Pond	Nov 02, 2022	0.01	LTD	LTD	3.10
Trepassey	Trepassey	Miller's Pond	Nov 03, 2022	0.01	LTD	LTD	13.00
Trinity	Trinity, T.B.	Indian Pond	Nov 29, 2022	0.00	LTD	LTD	6.60
Trinity Bay North	Little Catalina	Whirl Pond	Nov 29, 2022	0.01	LTD	LTD	11.00
Trinity Bay North	Port Union, Catalina (+Little Catalina)	Whirl Pond	Nov 29, 2022	0.01	LTD	0.01	8.60
Trinity Bay North	Melrose	Whirl Pond	Nov 29, 2022	0.01	LTD	LTD	10.00
Triton	Triton, Jim's Cove, Card's Harbour	Triton Pond	Nov 22, 2022	0.03	0.08	LTD	11.00
Trout River	Trout River	Feeder Brook	Nov 02, 2022	0.01	0.24	LTD	1.10
Twillingate	Twillingate	Wild Cove Pond	Dec 14, 2022	0.01	0.08	LTD	7.20
Upper Island Cove	Upper Island Cove	Kelly's Pond (Spider's Pond)	Nov 01, 2022	0.00	LTD	LTD	3.40
Victoria	Victoria (+Salmon Cove)	Rocky Pond	Nov 28, 2022	0.01	LTD	LTD	2.80
Wabush	Wabush	Wahnahnish Lake	Oct 20, 2022	0.02	LTD	LTD	5.00
West Bay	West Bay	Unnamed Brook	Nov 23, 2022	0.15	0.10	LTD	9.30
West Bay	West Bay	Victor's Brook	Nov 29, 2022	0.09	0.11	LTD	8.60
Westport	Westport	Western Brook Pond	Nov 23, 2022	0.01	LTD	LTD	15.00
Whitbourne	Whitbourne	Hodges River	Nov 18, 2022	0.01	LTD	0.01	7.10
Whiteway	Whiteway (+Cavendish)	Long Pond	Nov 14, 2022	0.01	LTD	0.01	3.70
Whiteway	Whiteway - PWDU	Long Pond	Nov 14, 2022	LTD	0.06	LTD	LTD
Wild Cove	Wild Cove	Hedderson's Pond Brook	Nov 22, 2022	0.03	0.07	LTD	9.60
Winterton	Winterton	Western Pond	Nov 08, 2022	0.01	LTD	LTD	4.10
Wooddale	Wooddale	Northern Arm Lake	Nov 08, 2022	0.01	LTD	LTD	2.80
Woodstock	Woodstock	Mill Pond	Nov 22, 2022	0.00	LTD	LTD	12.00
Woody Point	Woody Point	Winterhouse Brook	Nov 02, 2022	0.02	0.12	0.03	0.93

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC	
			Units	mg/L	mg/L	mg/L	mg/L	
			Guidelines for Canadian Drinking Water Quality				7	10
				1				

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

This report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ. Guidelines have not been developed for all the parameters listed in this report.

Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

### Contaminant Exceedances

**Strontium:** The maximum acceptable concentration for strontium is 7.0 mg/L. Strontium may enter drinking water from naturally occurring deposits or as a result of human activity, such as mining or other industries. High levels of this contaminant can cause adverse health effects for some people.

**Nitrate:** The maximum acceptable concentration for nitrate is 10 mg/L as nitrate-nitrogen. Nitrate is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

**Nitrite:** The maximum acceptable concentration for nitrite is 1 mg/L as nitrite-nitrogen. Nitrite is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

mg/L = milligrams per litre or parts per million      TOC = total organic carbon