

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Admirals Beach	Admiral's Beach	2 Well Fields	Sep 01, 2023	0.21	LTD	LTD	4.00
Appleton	Appleton (+Glenwood)	Gander Lake (The Outflow)	Aug 30, 2023	0.01	0.09	LTD	6.90
Aquaforte	Aquaforte	Davies Pond	Aug 31, 2023	0.00	LTD	LTD	6.50
Badger	Badger	Well Field, 2 wells on standby	Aug 16, 2023	0.20	0.06	LTD	LTD
Baine Harbour	Baine Harbour	Dug	Aug 28, 2023	0.04	0.58	LTD	0.58
Barachois Brook	Barachois Brook	Drilled	Sep 26, 2023	0.13	LTD	LTD	LTD
Bauline	Bauline	#1 Brook Path Well	Aug 30, 2023	0.06	LTD	LTD	6.10
Bay Roberts	Bay Roberts	Rocky Pond	Aug 09, 2023	0.01	0.06	LTD	1.90
Bay St. George South	Heatherton	#1 Well Heatherton (Home Hardware)	Sep 20, 2023	2.10	LTD	LTD	1.20
Bay St. George South	Jeffrey's	#1 Well Jeffery's (Joe Curnew)	Sep 20, 2023	0.92	LTD	LTD	LTD
Bay St. George South	Robinson's	#1 Well Robinson's (Louie MacDonald)	Sep 20, 2023	0.22	2.70	LTD	LTD
Bay St. George South	St. Fintan's, St. David's	#1 Well St. Fintan's (The Y)	Sep 20, 2023	0.37	LTD	LTD	LTD
Bay St. George South	Jeffrey's	#2 Well Jeffery's (Calvin Madore)	Sep 20, 2023	1.30	LTD	LTD	0.52
Bay St. George South	St. Fintan's	#2 Well St. Fintan's (Louis King)	Sep 20, 2023	0.27	1.30	LTD	LTD
Bay St. George South	McKay's	#2B Lions Club Well	Sep 20, 2023	0.91	LTD	LTD	LTD
Bay St. George South	Highlands	#3 Brian Pumphrey Well Highlands	Sep 20, 2023	0.37	LTD	LTD	LTD
Bay St. George South	Jeffrey's	#3 Well Jeffery's (Sid Shears)	Sep 20, 2023	3.00	LTD	LTD	1.30
Bay St. George South	Robinson's	#3 Well Robinson's (Gales)	Sep 20, 2023	0.41	LTD	LTD	LTD
Bay St. George South	McKay's	#3 Woodworth Well McKay's	Sep 20, 2023	0.23	0.08	LTD	0.90
Bay St. George South	Lock Leven	#6 Well Loch Leven (Jerry Quilty)	Sep 20, 2023	0.16	0.27	LTD	LTD
Bay St. George South	McKay's	#7 Well McKay's (Gordon Hulan)	Sep 20, 2023	0.48	LTD	LTD	1.90
Benoit's Siding	Doyles	# 2 Well Doyles	Sep 22, 2023	2.00	0.10	LTD	LTD
Benoit's Siding	Benoit's Siding (aka Bennett's Siding)	Drilled	Sep 26, 2023	0.81	0.63	LTD	0.54
Birchy Bay	Birchy Bay	Jumper's Pond	Aug 14, 2023	0.03	LTD	LTD	9.90
Bishop's Falls	Bishop's Falls	Northern Arm Lake	Aug 09, 2023	0.01	0.13	LTD	1.90
Black Duck	Black Duck (Siding)	#1 Well	Sep 14, 2023	0.11	0.23	LTD	LTD
Black Duck	Black Duck (Siding)	#2 Well	Sep 14, 2023	0.10	0.16	LTD	LTD
Black Tickle-Domino	Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	Sep 01, 2023	0.01	0.09	LTD	7.10
Black Tickle-Domino	Black Tickle-Domino - PWDU	Martin's Pond - Tap at Pumphouse	Sep 01, 2023	LTD	0.10	LTD	LTD
Blaketown	Blaketown South	#1 Selby Mercer Well	Sep 06, 2023	0.04	0.78	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Blaketown	Blaketown	#2 Daphne Pincent Well	Sep 06, 2023	0.09	0.24	LTD	0.55
Blaketown	Blaketown Centre	#3 Fred Osborne Well	Sep 06, 2023	0.06	0.19	LTD	2.00
Blaketown	Blaketown North	#4 Hilda Barrett Well	Sep 06, 2023	0.12	LTD	LTD	LTD
Brent's Cove	Brent's Cove	Paddy's Pond	Aug 14, 2023	0.01	LTD	LTD	18.00
Brigus South	Forge Hill area	#1 Well Forge Hill	Aug 30, 2023	0.40	LTD	LTD	2.80
Brigus South	Dunphey's Hill area	#2 Well Dunphey's Hill	Aug 30, 2023	0.40	LTD	LTD	0.70
Brigus South	Near highway	#3 Well Main Road	Aug 30, 2023	0.03	0.10	LTD	0.63
Bryant's Cove	Bryant's Cove South Side	#1 Well - Bert James Well #2 Well - Baxter Bowering Well	Aug 09, 2023	0.07	0.15	LTD	LTD
Bunyan's Cove	Bunyan's Cove	#1 Wellfield	Aug 23, 2023	0.06	0.21	LTD	3.10
Canning's Cove	Lower Canning's Cove	#1 Well - Pleman Pitts	Aug 23, 2023	0.26	0.10	LTD	LTD
Canning's Cove	Upper Canning's Cove	#2 Well - Eugene Ellis	Aug 23, 2023	0.15	0.14	LTD	0.95
Canning's Cove	Centre Canning's Cove	#3 Well - Glenda Penney	Aug 23, 2023	0.05	0.08	LTD	LTD
Cartwright	Cartwright	Burdett's Pond	Aug 14, 2023	0.00	LTD	LTD	8.70
Cartwright	Cartwright - PWDU	Burdett's Pond	Aug 14, 2023	LTD	0.07	LTD	LTD
Cavendish	North Side Cavendish	#1 Well - Max Bishop	Aug 23, 2023	0.23	2.60	LTD	LTD
Cavendish	North Side Cavendish	#2 Well - Tom Critch	Aug 23, 2023	0.20	LTD	LTD	3.00
Centreville-Wareham-Trinity	Trinity	Southwest Feeder Pond	Aug 22, 2023	0.01	LTD	LTD	6.10
Chance Cove	Lower Cove	#5B Albert Rowe Well	Aug 15, 2023	0.43	LTD	LTD	1.60
Chance Cove	Upper Cove	Hollett's Well	Aug 15, 2023	0.02	0.12	LTD	0.90
Chance Cove	New Housing Area	New Housing Area Well	Aug 15, 2023	0.31	LTD	LTD	LTD
Chance Cove	Back Cove Area	Olive Smith Well	Aug 15, 2023	0.01	0.08	LTD	1.10
Channel-Port aux Basques	Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Aug 08, 2023	0.00	LTD	LTD	2.60
Charlottetown (Labrador)	Charlottetown (Labrador) - PWDU	Middle Pond	Aug 16, 2023	LTD	0.07	LTD	LTD
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Aug 16, 2023	0.01	LTD	LTD	9.80
Churchill Falls	Churchill Falls	Smallwood Reservoir	Jul 14, 2023	0.01	0.06	LTD	2.90
Clareville	Clareville, Shoal Harbour	Shoal Harbour River	Sep 28, 2023	0.01	0.19	LTD	2.50
Clarke's Beach	Otterbury	#1 Well - Quinlon Well	Aug 24, 2023	0.15	LTD	LTD	LTD
Clarke's Beach	Otterbury	#2 Well - Delaney Well	Aug 24, 2023	0.10	0.07	LTD	LTD
Colliers	Merrigan's Lane + Main Rd	#2 Well - Merrigan's Well	Sep 12, 2023	0.22	0.12	LTD	LTD
Colliers	Harbour Drive & Main Road	#3 Well - Griffin's Well	Sep 12, 2023	0.17	0.25	LTD	0.96
Colliers	Harbour Drive	#4 Well - Flynn's Well	Sep 07, 2023	0.10	0.22	0.01	LTD
Colliers	Harbour Drive	#5 Well - Whalen's Well	Sep 13, 2023	0.10	1.10	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	Sep 13, 2023	0.01	0.06	LTD	1.50
Conception Harbour	Cemetery Road & Main Road	Cemetery Road Well	Sep 12, 2023	0.09	0.40	LTD	LTD
Conception Harbour	Healey's Pond Rd, Old Rd & Main Rd	Healey's Pond Road Well	Sep 12, 2023	0.08	0.22	LTD	LTD
Conception Harbour	Lower Bacon Cove	Lower Bacon Cove Well	Sep 13, 2023	0.72	0.24	LTD	0.62
Conception Harbour	Old Road and Coles Crescent	Old Road Well	Sep 12, 2023	0.23	0.18	LTD	LTD
Conception Harbour	Upper Bacon Cove, Kitchuses	Upper Bacon Cove Well	Sep 12, 2023	0.33	0.11	LTD	0.53
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Aug 30, 2023	0.01	0.25	LTD	1.30
Cox's Cove	Upper Area	Upper Area Wellfield	Sep 11, 2023	0.41	0.07	0.01	0.72
Dildo	Dildo, Broad Cove (+South Dildo)	Broad Cove Pond	Jul 18, 2023	0.01	0.06	LTD	4.60
Eastport	Eastport (+Sandy Cove)	Dug	Sep 27, 2023	0.03	0.34	LTD	LTD
Fermeuse	Fermeuse, Kingman's	Merrymeeting Pond, Bear Cove Pond (2 intakes)	Aug 31, 2023	0.01	LTD	LTD	3.80
Fermeuse	Fermeuse	Port Kirwan Road Well	Sep 05, 2023	0.15	0.74	LTD	1.00
Ferryland	Ferryland	Deep Cove Pond	Aug 30, 2023	0.01	LTD	LTD	3.30
Flat Bay	Flat Bay (East)	#1 Well	Sep 26, 2023	0.11	LTD	LTD	LTD
Flat Bay	Flat Bay (East)	#3 Well	Sep 26, 2023	0.31	1.00	LTD	1.60
Flat Bay West	Flat Bay West	#3 Well	Sep 26, 2023	0.07	0.84	LTD	0.58
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Aug 01, 2023	0.01	LTD	LTD	12.00
Forteau	Forteau	Trout Brook	Aug 15, 2023	0.03	LTD	LTD	2.20
Fox Roost-Margaree	Fox Roost-Margaree	Drilled Well and Margaree Pond	Aug 08, 2023	0.01	0.06	LTD	21.00
Fox Roost-Margaree	Fox Roost-Margaree - PWDU	Drilled Well and Margaree Pond	Aug 08, 2023	LTD	LTD	LTD	LTD
Frenchman's Cove	Frenchman's Cove	Dug Well	Aug 29, 2023	0.02	0.71	LTD	2.80
Freshwater	Freshwater (Carbonear)	#2 Well - Covage's Lane Well	Aug 09, 2023	0.06	0.10	LTD	LTD
Freshwater	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	Aug 09, 2023	0.60	0.80	LTD	LTD
Gander	Gander	Gander Lake	Aug 30, 2023	0.01	0.18	0.01	4.60
Gander Bay South	Gander Bay South - PWDU	Barry's Brook	Aug 28, 2023	LTD	LTD	LTD	LTD
Gander Bay South	George's Point, Harris Point	Barry's Brook	Aug 28, 2023	0.01	0.11	LTD	5.20
Georgetown	Georgetown	Drilled	Sep 07, 2023	0.09	0.27	LTD	LTD
Grates Cove	Grates Cove Centre	#1C Well	Aug 17, 2023	0.09	0.06	LTD	0.61
Grates Cove	Grates Cove North End	#3 Frank Janes Well	Aug 17, 2023	0.06	0.10	LTD	1.90
Grates Cove	Grates Cove South End	#4 Stoyles Hill Well	Aug 17, 2023	0.06	0.15	LTD	0.88
Great Codroy	Great Codroy East	#1 Well	Sep 26, 2023	3.20	0.08	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Great Codroy	Great Codroy West	#2 Well	Sep 22, 2023	0.42	0.16	LTD	LTD
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	Aug 17, 2023	0.02	0.08	LTD	0.78
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	Aug 17, 2023	0.04	LTD	LTD	0.60
Harbour Grace	Thickett	#1 Thickett Susie Galway Well	Aug 17, 2023	0.04	0.72	LTD	LTD
Harbour Grace	Riverhead	Mercer's Rd. Well	Aug 17, 2023	0.03	0.29	LTD	LTD
Harbour Grace	Harbour Grace South Lower	New Southside Well (Well#3)	Aug 17, 2023	0.11	LTD	LTD	0.61
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Aug 17, 2023	0.08	0.05	LTD	LTD
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Aug 17, 2023	0.08	0.10	LTD	LTD
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Flynn's Hill Well	Sep 13, 2023	0.19	0.77	LTD	1.60
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Holden's Road Well	Sep 13, 2023	0.10	0.95	LTD	LTD
Harry's Harbour	Harry's Harbour	#1C Well - Northeast Well	Aug 22, 2023	0.10	LTD	LTD	0.71
Harry's Harbour	Harry's Harbour	#2 Well - Northwest Hill / Country Road	Aug 22, 2023	0.16	0.07	LTD	0.90
Harry's Harbour	Harry's Harbour	#3 Well - South Well	Aug 22, 2023	0.38	0.11	LTD	0.78
Heart's Content	Heart's Content	Southern Cove Pond	Aug 23, 2023	0.00	LTD	LTD	3.40
Hodge's Cove	Hodge's Cove	Drilled	Aug 04, 2023	0.06	0.19	LTD	LTD
Holyrood	Holyrood	Main Line	Aug 24, 2023	0.12	0.08	LTD	LTD
Holyrood	Holyrood	O'Connell's Well	Sep 07, 2023	0.43	LTD	LTD	3.80
Holyrood	Holyrood	Woodford Station - Healey's Well and Quinlan's Well	Aug 24, 2023	0.44	LTD	LTD	3.60
Hopeall	Hopeall	Charles Cumby Well	Aug 23, 2023	0.07	0.18	LTD	0.54
Hopeall	Gilberts Hill	Gilberts Hill Well	Aug 23, 2023	0.08	0.57	LTD	0.51
Hopedale	Hopedale	American Pond	Aug 29, 2023	0.01	LTD	LTD	4.40
Humber Arm South	Frenchman's Cove Area	Gurges Pond	Aug 30, 2023	0.05	LTD	LTD	3.80
Jackson's Cove-Langdon's Cove-Silverdale	Langdon's Cove	#3 Well Langdon's Cove Well	Aug 22, 2023	0.11	LTD	LTD	1.20
Jean de Baie	Jean de Baie	#1 Well	Aug 30, 2023	0.08	0.25	LTD	0.58
Kippens	Kippens	Well Field	Aug 30, 2023	0.12	0.12	LTD	LTD
L'Anse au Clair	L'Anse au Clair	Park Pond	Aug 15, 2023	0.03	LTD	0.01	2.80
L'Anse au Loup	L'Anse au Loup	L'anse Au Loup River	Aug 15, 2023	0.01	LTD	LTD	3.90
Labrador City	Labrador City	Beverly Lake	Jul 14, 2023	0.01	LTD	LTD	1.80
Lance Cove	Lance Cove	Local Service District Well	Sep 26, 2023	1.30	0.28	LTD	0.52
Lewisporte	Lewisporte	Stanhope Pond	Aug 07, 2023	0.02	0.07	LTD	8.10
Mainland	Mainland	Caribou Brook	Sep 25, 2023	0.07	0.19	LTD	3.70

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Makinsons	Turkswater & Hodgewater Line West	Country Path Wells	Sep 20, 2023	0.02	0.05	LTD	LTD
Makkovik	Makkovik - PWDU	Ranger Bight Pond	Aug 29, 2023	0.01	0.05	LTD	LTD
Makkovik	Makkovik	Ranger Bight Pond	Aug 29, 2023	0.02	0.06	LTD	3.80
Mary's Harbour	Mary's Harbour - PWDU	St. Mary's River	Aug 15, 2023	LTD	LTD	LTD	0.56
Mary's Harbour	Mary's Harbour	St. Mary's River	Aug 15, 2023	0.01	LTD	LTD	7.20
Marystown	Marystown	Fox Hill Reservoir / Clam Pond	Aug 29, 2023	0.01	LTD	LTD	6.00
Marysvale	Marysvale, Long Pond	Drilled	Sep 07, 2023	0.02	LTD	LTD	LTD
Mattis Point	Mattis Point	Drilled	Sep 26, 2023	0.12	0.13	LTD	LTD
McCallum	McCallum	Drilled	Sep 14, 2023	0.04	LTD	LTD	37.00
Ming's Bight	Ming's Bight	Middle Brook Pond	Aug 14, 2023	0.01	LTD	LTD	6.40
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	Sep 13, 2023	0.01	0.09	LTD	1.40
Nain	Nain	Trouser Lake	Aug 30, 2023	0.01	0.06	LTD	1.70
Natuashish	Natuashish (Sango Bay)	Sango Brook and Wellfield	Aug 30, 2023	0.09	0.07	LTD	0.94
New Harbour	New Harbour	Williams Hill Well	Sep 08, 2023	0.13	0.10	LTD	0.63
Norris Arm	Norris Arm (south)	Mill Lake	Aug 07, 2023	0.01	0.08	LTD	4.30
North West River	North West River	Wellfield (Well # 1 & Well # 2)	Aug 17, 2023	0.18	LTD	LTD	LTD
O'Donnells	O'Donnell's	Well Field	Sep 01, 2023	0.07	LTD	LTD	LTD
O'Regans East	O'Regan's East	Drilled	Sep 22, 2023	0.30	0.65	LTD	0.57
Paradise	Paradise	Bay Bulls Big Pond	Sep 13, 2023	0.01	LTD	LTD	1.50
Petley	Petley	Drilled + Dug Reservoir	Sep 11, 2023	0.04	LTD	LTD	1.60
Piccadilly Slant-Abraham's Cove	Piccadilly Slant	#1 Well - Piccadilly Slant	Sep 11, 2023	0.25	0.30	LTD	1.50
Piccadilly Slant-Abraham's Cove	Abraham's Cove	#2 Well - Abraham's Cove	Sep 26, 2023	0.10	0.88	LTD	3.80
Point Lance	Point Lance (5 houses)	Well	Aug 21, 2023	0.05	LTD	LTD	LTD
Point Lance	Point Lance (5 houses)	Well	Aug 21, 2023	0.05	LTD	LTD	LTD
Point of Bay	Point of Bay	Indian Cove Pond	Aug 03, 2023	0.01	LTD	LTD	7.30
Port Blandford	Port Blandford	Noseworthy's Pond	Sep 19, 2023	0.02	0.06	LTD	6.20
Port Hope Simpson	Port Hope Simpson	Arnold's Brook and Pond	Aug 16, 2023	0.01	LTD	LTD	12.00
Port Kirwan	Port Kirwan	Developed Spring	Aug 30, 2023	0.03	0.09	LTD	0.50
Port Kirwan	North Side	Dug Well / Drilled Well	Aug 31, 2023	0.12	LTD	LTD	LTD
Port Rexton	Port Rexton	#1 Well - Lois Long Well	Sep 25, 2023	0.09	0.60	LTD	LTD
Port Rexton	Champneys Arm	Champney's Arm Well	Sep 25, 2023	0.19	0.09	LTD	1.80
Port au Port East	Port au Port East	Drilled Well - 75-80% Berry Head Watershed - 20-25%	Aug 30, 2023	0.06	0.20	LTD	6.70

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Port au Port West-Aguathuna-Felix Cove	Port au Port West, Aguathuna	#1 & #3 & #6 FatherJoy's Well	Sep 11, 2023	0.38	0.07	LTD	1.80
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#4-Goose Pond Road Well	Sep 26, 2023	0.18	0.18	LTD	0.81
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	Sep 12, 2023	0.01	LTD	LTD	1.50
Postville	Postville - PWDU	Big Pond	Aug 29, 2023	LTD	LTD	LTD	LTD
Postville	Postville	Big Pond	Aug 29, 2023	0.01	0.09	LTD	6.20
Pouch Cove	Pouch Cove	North Three Island Pond	Aug 30, 2023	0.01	LTD	LTD	1.70
Raleigh	Raleigh	#4 Well	Sep 13, 2023	0.20	LTD	LTD	1.70
Ramea	Ramea	Northwest Pond	Sep 24, 2023	0.05	0.15	LTD	2.60
Ramea	Ramea - PWDU	Northwest Pond	Sep 24, 2023	0.03	0.14	LTD	1.30
Random Sound West	North West Brook, Ivany Cove	#1 Well - Cabot Road South Well	Aug 03, 2023	0.79	LTD	0.01	1.50
Random Sound West	North West Brook, Ivany Cove	#2 Well	Aug 03, 2023	0.08	0.58	LTD	0.58
Random Sound West	North West Brook, Ivany Cove	#3 Well - Harbour Well	Aug 03, 2023	0.12	0.40	0.01	3.10
Red Bay	Red Bay	Northern Brook	Aug 15, 2023	0.01	LTD	LTD	5.20
Red Harbour	Red Harbour	1A Well Drilled + 1C Dug Well (back-up)	Aug 28, 2023	0.39	0.10	LTD	1.70
Reidville	Reidville	Humber Canal, Grand Lake	Sep 08, 2023	0.01	0.13	LTD	3.80
Renews-Cappahayden	Cappahayden	#1 Dinn's Well	Sep 05, 2023	0.27	LTD	LTD	0.50
Rigolet	Rigolet - PWDU	Rigolet Pond	Aug 29, 2023	LTD	0.08	LTD	LTD
Rigolet	Rigolet	Rigolet Pond	Aug 29, 2023	0.02	LTD	LTD	8.40
Riverhead	Riverhead (St. Mary's Bay)	Well Field	Sep 01, 2023	0.02	0.32	LTD	0.82
Sandy Cove	Sandy Cove	Dug	Sep 27, 2023	0.03	0.33	LTD	LTD
Sheaves Cove	Sheaves Cove	Drilled	Sep 26, 2023	0.28	0.28	LTD	1.20
Sheppardville	Sheppardville	Drilled	Aug 01, 2023	0.06	LTD	LTD	LTD
Sheshatshiu	Sheshatshiu - Indian Band Council	Wells 1, 2 & 3	Aug 17, 2023	0.17	0.26	LTD	1.10
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#1 Well - PJ's Variety Well	Sep 14, 2023	0.43	LTD	LTD	1.30
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#2 Well - Howard & Rodney Jesso Well	Sep 12, 2023	0.27	0.08	LTD	1.40
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove East	#3 Well - Bernard Brake Well	Sep 12, 2023	0.27	0.32	LTD	1.80
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#4B Well - Nancy Rowe Well	Sep 12, 2023	1.20	0.07	LTD	1.80
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#5 Well - Murdock Wheeler Well	Sep 12, 2023	0.05	0.23	LTD	LTD
Ship Cove-Lower Cove-Jerry's Nose	Lower Cove	#6 Well - Lower Cove Well	Sep 14, 2023	0.19	0.37	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Adam's Cove	#1 Well - Reg Burse Well	Aug 08, 2023	0.32	0.27	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Blackhead + Adam's Cove	#4 Well - Leonard King Well	Aug 08, 2023	0.13	0.12	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#6 Well - Herb Trickett Well	Aug 08, 2023	0.13	0.13	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#8 Well - Effie Flight Wells	Aug 08, 2023	0.24	1.40	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#9 Well - Walter Reynolds Well	Aug 08, 2023	0.03	1.60	LTD	LTD
Smith's Sound	Harcourt-Monroe-Waterville	Developed Spring	Sep 19, 2023	0.07	0.64	LTD	LTD
South Dildo	South Dildo	#5 Well - Calvin Reid Well	Sep 08, 2023	0.09	LTD	LTD	0.80
South Dildo	South Dildo	Broad Cove Pond	Jul 18, 2023	0.01	0.08	LTD	4.60
South Dildo	South Dildo	Broad Cove Pond	Jul 18, 2023	0.01	LTD	LTD	4.60
South Dildo	South Dildo	Broad Cove Pond	Jul 18, 2023	0.01	LTD	0.04	4.70
Springdale	Springdale Industrial Park	Well	Aug 23, 2023	0.13	0.31	LTD	LTD
St. Alban's	St. Alban's	Well Field	Aug 08, 2023	0.02	0.27	LTD	LTD
St. Andrews	St. Andrew's	#1 Well	Sep 22, 2023	0.88	0.37	LTD	1.30
St. Andrews	St. Andrew's	#2 Well	Sep 22, 2023	0.38	0.09	LTD	0.76
St. Andrews	St. Andrew's East	#3 Well	Sep 22, 2023	0.17	0.22	LTD	3.20
St. Andrews	Air Strip Road	#4 Well Strip Road Well	Sep 22, 2023	0.72	LTD	0.05	0.66
St. Anthony	St. Anthony	St. Anthony Pond	Sep 13, 2023	0.01	LTD	LTD	6.50
St. George's	St. George's	Wellfield	Sep 26, 2023	0.12	0.12	LTD	2.20
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Sep 14, 2023	0.01	0.12	LTD	1.50
St. John's	St. John's	Petty Harbour Long Pond	Sep 18, 2023	0.01	LTD	LTD	1.40
St. John's	St. John's	Windsor Lake	Sep 18, 2023	0.01	LTD	LTD	1.80
St. Joseph's	St. Joseph's S.M.B.	Drilled	Sep 01, 2023	0.12	LTD	LTD	1.50
St. Lewis	St. Lewis	Tub Harbour Pond	Aug 15, 2023	0.01	LTD	LTD	9.50
St. Lunaire-Griquet	St. Lunaire-Griquet	Drilled	Sep 13, 2023	0.12	LTD	LTD	2.00
St. Lunaire-Griquet	St. Lunaire-Griquet	Joe's Pond	Sep 13, 2023	LTD	LTD	LTD	LTD
St. Mary's	St. Mary's	Wellfield	Sep 01, 2023	0.11	0.16	0.02	0.54
St. Pauls	St. Pauls	Two Mile Pond	Aug 29, 2023	0.06	0.05	LTD	7.50
Steady Brook	Steady Brook	Wellfield + Steady Brook	Aug 09, 2023	0.04	LTD	LTD	8.70
Stephenville	Stephenville	Well Field	Aug 30, 2023	0.14	0.18	LTD	LTD
Stephenville Crossing	Stephenville Crossing	Well Fields 1 & 2	Aug 30, 2023	0.11	0.36	LTD	LTD
Sunnyside (T.B.)	Sunnyside	Center Cove River	Aug 10, 2023	0.01	LTD	LTD	7.00
Swift Current	Swift Current (Hollett's Point)	Drilled	Aug 10, 2023	0.05	LTD	LTD	6.40
Terrenceville	Terrenceville	Big Brook	Aug 28, 2023	0.00	LTD	LTD	6.40
Tompkins	Tompkins	Greg Wall Well	Sep 22, 2023	0.23	0.35	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				7	10	1	
Upper Amherst Cove	Upper Amherst Cove	Drilled	Sep 28, 2023	0.12	0.08	0.01	2.10
Upper Ferry	Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	Sep 22, 2023	0.08	1.90	LTD	LTD
Upper Ferry	Upper Ferry - Middle	#2 Well - Hughie MacIassac Well	Sep 22, 2023	0.19	0.22	0.02	LTD
Upper Ferry	Upper Ferry - Upper	#3 Well - Marshall Devoe Well	Sep 22, 2023	0.30	LTD	LTD	LTD
Upper Ferry	Upper Ferry	#4 Well - Angus MacNeil Well	Sep 26, 2023	0.42	LTD	LTD	LTD
Wabana	Wabana - PWDU	#3 Yard West Mines Road	Sep 26, 2023	LTD	LTD	LTD	LTD
Wabana	Wabana	#3 Yard West Mines Road	Sep 26, 2023	0.50	LTD	LTD	3.40
Wabana	Wabana	#4-West Mines Road	Sep 26, 2023	0.51	LTD	LTD	3.40
Wabana	Wabana	Middleton Ave	Sep 26, 2023	0.37	0.32	LTD	3.30
Wabana	Wabana	Mixed Supplies	Sep 26, 2023	0.40	LTD	LTD	1.90
Wabana	Wabana	Mixed Supplies	Sep 26, 2023	0.45	0.06	LTD	1.60
Wabana	Wabana	Mixed Supplies	Sep 26, 2023	0.42	LTD	LTD	1.90
Wabana	Wabana	Normore Crescent East #1	Sep 26, 2023	0.72	LTD	0.05	3.40
Wabana	Wabana	Quigley's Line	Sep 26, 2023	0.74	0.10	LTD	3.40
Wabana	Wabana	Scotia #1	Sep 26, 2023	0.37	LTD	LTD	4.20
Wabana	Wabana	St. Edward's Memorial St.	Sep 26, 2023	0.07	0.06	0.02	LTD
Wabush	Wabush	Wahnahnish Lake	Jul 14, 2023	0.02	LTD	0.02	3.10
West St. Modeste	West St. Modeste	Well Field	Aug 15, 2023	0.00	LTD	LTD	4.60
Winterland	Winterland	Well Field	Aug 30, 2023	0.14	0.81	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC	
			Units	mg/L	mg/L	mg/L	mg/L	
			Guidelines for Canadian Drinking Water Quality				7	10
				1				

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

This report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ. Guidelines have not been developed for all the parameters listed in this report.

Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant Exceedances

Strontium: The maximum acceptable concentration for strontium is 7.0 mg/L. Strontium may enter drinking water from naturally occurring deposits or as a result of human activity, such as mining or other industries. High levels of this contaminant can cause adverse health effects for some people.

Nitrate: The maximum acceptable concentration for nitrate is 10 mg/L as nitrate-nitrogen. Nitrate is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

Nitrite: The maximum acceptable concentration for nitrite is 1 mg/L as nitrite-nitrogen. Nitrite is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

mg/L = milligrams per litre or parts per million TOC = total organic carbon