



GOVERNMENT OF  
NEWFOUNDLAND AND LABRADOR  
Department of Environment and Climate Change

## CERTIFICATE OF APPROVAL

Pursuant to the Environmental Protection Act, SNL 2002 c E-14.2 Section 83

Issue Date: *June 30, 2022*

Approval No. AA22-065672

Expiration: *June 30, 2027*

File No. 716.006.1

Proponent:

Newfoundland and Labrador Hydro  
Hydro Place, 500 Columbus Drive  
P.O. Box 12400, St. John's, NL  
A1B 4K7

Attention:

Rod Healey, Manager Environment Operations

Re:

Black Tickle Diesel Generating Station

Approval is hereby given for the operation of three (3) prime power diesel generating units, including the storage of used oil and used glycol in containers, located at Black Tickle, NL.

This Certificate of Approval does not release the proponent from the obligation to obtain appropriate Approvals from other concerned provincial, federal and municipal agencies. Nothing in this certificate of Approval negates any regulatory requirement placed on the proponent. Where there is a conflict between conditions in this Certificate of Approval and a regulation, the condition in the regulation shall take precedence. Approval from the Department of Environment and Climate Change shall be obtained prior to any significant change in the design, construction, installation, or operation of the diesel generating units at the Black Tickle diesel generating station, including any future expansion of the diesel generating units. This Certificate of Approval shall not be sold, assigned, transferred, leased, mortgaged, sublet or otherwise alienated by the proponent without obtaining prior Approval from the Minister.

This Certificate of Approval is subject to the terms and conditions as contained therein, as may be revised from time to time by the Department. Failure to comply with any of the terms and conditions may render this Certificate of Approval null and void, may require the proponent to cease all activities associated with this Certificate of Approval, may place the proponent and its agent(s) in violation of the *Environmental Protection Act*, and will make the proponent responsible for taking such remedial measures as may be prescribed by the Department. The Department reserves the right to add, delete or modify conditions to correct errors in the Certificate of Approval or to address significant environmental or health concerns.

Fel MINISTER

June 30, 2022

**General**

1. This Certificate of Approval is for the operation of three (3) prime power diesel generating units, as outlined in Table 1, including the storage of used oil and used glycol in containers, located at Black Tickle, NL. Extensive future expansion or change of activities will require a separate Certificate of Approval.

**Table 1: Black Tickle Diesel Generating Units**

Number of Units	Unit No.	Date of Manufacture	Power Rating (kW)	Manufacturer	Model
1	582	2010	300	Detroit Diesel	DET6063HK35
1	2066	2003	455	Caterpillar	CAT3456
1	579	2007	250	Detroit Diesel	DETS60

2. Any inquiries concerning this Approval shall be directed to the St. John's office of the Pollution Prevention Division (telephone: (709) 729-2556; or facsimile: (709) 729-6969).

3. In this Certificate of Approval:

- **associated product** means petroleum or a derivative of it, except gasoline, which is in a liquid state at ambient temperature and pressure;
- **Department** means the Department of Environment and Climate Change and its successors;
- **DGSNL** means Digital Government and Service NL and its successors;
- **HYDRO** means Newfoundland & Labrador Hydro;
- **leak or leakage** means any discharge of gasoline, associated product or used glycol from a storage tank system, pipeline, tank vessel, tank car or tank vehicle, other than through the usual function for which the storage tank system, pipeline, tank vessel, tank car or tank vehicle was designed;
- **licensed** means has a Certificate of Approval issued by the Minister to conduct an activity;
- **Minister** means the Minister of the Department;
- **register(ed)**, in the context of storage tanks, means that information regarding the storage tank system has been submitted to a DGSNL office and a registration number has been assigned to the storage tank system. In the context of dispersion modelling, register(ed) means submitted to and approved by the Department in accordance with departmental policy and guidelines. In the context of environmental site assessment and impacted site management work, register(ed) means approved by the Department in accordance with

7. HYDRO shall keep all records or other documents required by this Approval at the diesel generating site for a period of not less than three (3) years, beginning the day

6. HYDRO shall provide to the Department, within a reasonable time, any information, records, reports or access to data requested or specified by the Department.

- minimizing the area disturbed by the operation,
- minimizing air, water or soil pollution,
- finding alternative uses, acceptable to the Department, for waste or rejected materials,
- removing equipment or structures when they no longer have further use, and
- considering the requirement for the eventual rehabilitation of disturbed areas when planning the development of any area on the facility property.

5. All reasonable efforts shall be taken to minimize the impact of the operation on the environment. Such efforts include:

This Approval provides terms and conditions to satisfy various requirements of the above listed acts, regulations, policies, guidance documents and guidelines. If it appears that all of the pertinent requirements of these acts, regulations, policies and guidelines are not being met, then a further review of the works shall be conducted, and suitable pollution control measures may be required by the Minister.

- Environmental Protection Act;
- Water Resources Act;
- Air Pollution Control Regulations, 2022;
- Environmental Control Water and Sewage Regulations, 2003;
- Halocarbon Regulations;
- Storage and Handling of Gasoline and Associated Products Regulations, 2003; and
- Used Oil and Used Glycol Control Regulations.

4. All necessary measures shall be taken to ensure compliance with all applicable acts, regulations, policies, guidance documents and guidelines, including the following, or their successors:

- regulated substance means a substance subject to discharge limit(s) under the *Environmental Control Water and Sewage Regulations, 2003*;
- spill or spillage means a loss of gasoline, associated product or used glycol in excess of 70 litres from a storage tank system, pipeline, tank vessel or vehicle, or an uncontrolled release of any volume of a regulated substance onto or into soil or a body of water;
- storage tank system means a tank and all vent, fill and withdrawal piping associated with it installed in a fixed location and includes a temporary arrangement;
- used glycol means glycol that, through use, storage or handling, can no longer be used for its original purpose; and
- used oil means oil that, through use, storage or handling, can no longer be used for its original purpose.

they were made. These records shall be made available for review by officials of the Department or DGSNL when requested.

8. Should HYDRO wish to deviate in any way from the terms and conditions of this Certificate of Approval, a written request detailing the proposed deviation shall be made to the Minister. HYDRO shall comply with the most current terms and conditions until the Minister has authorized otherwise. In the case of meeting a deadline requirement, the request shall be made at least 60 days ahead of the applicable date as specified in this Approval or elsewhere by the Department.

### Waste Management

9. The management of waste generated at the site is subject to compliance with the *Environmental Protection Act*. All non-industrial waste shall be stored in a manner acceptable to the Department and, on at least a weekly basis, be disposed of:

- at an authorized waste disposal site, with the permission of the owner/operator of the site; or
  - by some other means acceptable to the Department.
- If required, industrial waste shall be disposed of by a licensed operator.

### Noise

10. Efforts shall be made to minimize and control noise resulting from the operations and maintenance of the three (3) diesel generating units at Black Tickle diesel generating station.

### Spill Prevention and Containment

11. All on site storage of petroleum shall comply with the *Storage and Handling of Gasoline and Associated Products Regulations, 2003*, or its successor. Storage tank systems shall be registered with DGSNL.

12. HYDRO shall submit an inventory of all petroleum and chemical storage tanks located at Black Tickle diesel generating station in Labrador to the Department for review by *August 31, 2023*. This inventory shall include the following information:

- site plan showing tank location,
- storage tank system photos, including manufacturer's labels,
- registration number (where applicable),
- identification number,
- material stored,
- capacity,
- annual throughput,
- tank material,
- tank type,
- tank diameter,
- tank height,
- tank colour,
- roof type,
- year of manufacture,

- the estimated annual emissions of the following flue gas constituents: SO<sub>2</sub>,
19. HYDRO shall submit an annual Air Emission Report to the Department by *June 1* of the subsequent year. This report shall include:

### Annual Air Emission Reporting

18. Pending the results of any ambient air monitoring, stack emission testing, and/or dispersion modeling, the Department may require that HYDRO take measures deemed necessary to ensure the requirements of the *Air Pollution Control Regulations, 2022*, are being met.

### Ambient Air

17. In the event that used oil and/or used glycol generated off-site is stored in the on-site storage tank(s), the information listed above shall also be required for the off-site systems.
- the type(s) of oil and/or glycol used;
  - the approximate total volume of used oil and/or used glycol generated during the previous year; and
  - the method of disposal for the used oil and/or used glycol.

16. Information on used oil that is generated by the diesel generating units shall be submitted to the Department for review by *January 31* each year. This shall include a description of:

15. Used oil and used glycol shall be disposed of by a company licensed for the handling and disposal of such products.
- closed containers;
  - registered tanks; or
  - tanks that have an active approval for DGSNL.

14. Used oil and used glycol shall not be mixed and shall be stored in separate:

### Used Oil and Used Glycol

13. Where applicable, all tanks and fuel delivery systems shall be inspected to appropriate American Petroleum Institute or Underwriters' Laboratories of Canada standards, or any other standards acceptable to this Department. The required frequency of inspections may be changed at the discretion of the Department.
- An update of the complete storage tank inventory including any changes to it shall be submitted to the Department within three (3) months of the change having occurred.

- date of installation,
- date of last inspection,
- failure history,
- maintenance history,
- effective secondary containment capacity, and
- date of next planned inspection.

- 24. Should HYDRO wish to continue to operate the Black Tickle diesel generating station beyond this expiry date, a written request shall be submitted to the Department for the renewal of this Approval. Such request shall be made prior to *January 1, 2027*.
- 23. This Certificate of Approval expires *June 30, 2027*.

### Expiration

- 22. Any spillage or leakage of gasoline, associated product or used glycol shall be reported immediately through the Environmental Emergencies 24-hour report line at 1-800-563-9089.
- 21. All incidents of:
  - Emergency response activities for petroleum or hazardous materials spills associated with the operation of diesel generating units located at Black Tickle; or
  - non-conformance of any condition within this Approval; or
  - verbal/written complaints of an environmental nature from the public received by HYDRO related to the operation of the Black Tickle diesel generating station whether or not they are received anonymously;
 shall be immediately reported, within one (1) working day, to the Department.
 

A written comprehensive incident report, including a detailed description of the incident, a summary of contributing factors, and an Action Plan to prevent future incidents of a similar nature, shall be prepared. The report shall include a description of actions already taken and future actions to be implemented, and shall be submitted to the Department within thirty (30) days of the date of the initial incident.

### Reporting

- 20. Although a monitoring program is not part of this Approval, the Department may require a monitoring program when it is the judgement of the Department that:
  - pollutants might be released to the surrounding environment without being detected, or
  - an adverse environmental effect may occur.

### Monitoring Alteration

- NO<sub>x</sub>, CO<sub>2</sub>, CO, TPM and PM<sub>2.5</sub>; and the actual calculations including factors, formulae and/or assumptions used.

cc:

Mr. Gary Kennell  
Environment and Climate Change Canada  
6 Bruce Street  
Mount Pearl, NL  
A1N 4T3

Mr. Jeff Pickett – Regional Director  
Digital Government and Service NL  
P. O. Box 2006  
Corner Brook, NL  
A2H 6J8

