

PERMIT TO CONSTRUCT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 36

Date: **SEPTEMBER 24, 2021**

File No: **841.014.1**
Permit No: **WS12115-2021**


Permit Holder: **Town of Labrador City
P.O. Box 280, 317 Hudson Drive
Labrador City, NL
A2V 2K5
townengineer@labradorcity.ca**

Attention: **Mr. Tom Mihajlovic, P. Eng.**

Re: **Labrador City - Drake Wastewater Treatment Plant Upgrades**

Permission is hereby given for : **upgrades to the Drake Wastewater Treatment Plant to include a new step screen, manual bar screen, grit chamber auger, conveyors, compactors, coagulation chemical feed equipment, submersible pumps, rotary sludge dewatering equipment, digested sludge pumps, new aeration system in two digesters, two positive displacement blowers, new dissolved oxygen/temperature monitoring equipment, new UV disinfection system and related works and appurtenances as described in a specification (Volume 1 & 2) and revised set of drawings numbered 003-194 (MI. no. 17-SCF-19-00120) as received from Nova Consultants Inc. on September 10, 2021 and additional information submitted on September 23, 2021.**

- This Permit does not release the Permit Holder from the obligation to obtain appropriate approvals from other concerned municipal, provincial and federal agencies.
- The Permit Holder must obtain the approval of the Crown Lands Administration Division if the project is being carried out on Crown Land.
- This Permit is subject to the terms and conditions indicated in Appendices A and B (attached).
- It should be noted that prior to any significant changes in the design or installation of the proposed works, or in event of changes in ownership or management of the project, an amendment to this Permit must be obtained from the Department of Environment and Climate Change under Section 49 of the *Water Resources Act*.



(for) MINISTER

APPENDIX A
Terms and Conditions for Permit

Water & Sewer General

1. Water pumped from excavations or work areas, or any runoff or effluent directed out of work sites, must have silt and turbidity removed by settling ponds, filtration, or other suitable treatment before discharging to a body of water. Effluent discharged into receiving waters must comply with the *Environmental Control Water and Sewage Regulations, 2003*.
2. All operations must be carried out in a manner that prevents damage to land, vegetation, and watercourses, and which prevents pollution of bodies of water.
3. Any areas adversely affected by this project must be restored to a state that resembles local natural conditions. Further remedial measures to mitigate environmental impacts on water resources can and will be specified, if considered necessary in the opinion of this Department.
4. All waste materials resulting from this project must be disposed of at a site approved by the Department of Digital Government and Service NL.
5. The works proposed must satisfy the requirements of the latest applicable codes and standards, and be consistent with or otherwise address the design criteria set out in this Department's publication *Guidelines for the Design, Construction, and Operation of Water and Sewerage Systems, 2005*, and as amended from time to time.
6. The work must be undertaken in strict compliance with the submitted documents and the latest version of the *Municipal Water, Sewer and Roads Master Construction Specifications*. A copy of all documents, including the *Municipal Water, Sewer and Roads Master Construction Specifications* must be available for viewing at the construction site office at all times.
7. Liaison is to be maintained with the Environmental Scientist representing the Drinking Water and Wastewater Section of this Department, during the construction and operation of the project. They shall be notified of the pre-construction and post-construction meetings so that they may attend, if deemed necessary. They can be reached at telephone (709) 637-2034 .
8. Officials of this Department may visit the project from time to time to ensure that work is carried out within the provisions of this Permit, and is not creating any environmental hazard.
9. Any changes in the approved works, or works other than those specified in the application, must be submitted, in writing, to this Department, and approved, in the form of an Amendment to this Permit, prior to any work.
10. Copies of this Permit, as well as any subsequent Amendments, must be provided to the contractor(s) who will be carrying out these works, and to the engineer's site representative.
11. The attached Completion Report (Appendix C) for Permit No. 12115 must be completed and returned to this Department upon completion of the approved works. Pictures must be submitted along with the completion report, showing the project site prior to and after development.
12. This Permit is valid for two years from the date of issue. Work must be completed by that date or the application and approval procedure must be repeated.

13. The drinking water and wastewater system shall be operated and maintained in accordance with the Permit to Operate issued by this Department.
14. The Owner must update any drawings maintained of the drinking water or wastewater system to reflect the modification or replacement of the works, where applicable.

Wastewater Treatment

15. Effluent from the wastewater treatment facility must meet the *Environmental Control Water and Sewage Regulations, 2003* and the federal *Wastewater Systems Effluent Regulations, 2012*.
16. The municipal water system and the potable water piping system within any part of the treatment facility, shall be protected from the potential backflow of sewage due to back-siphonage or backpressure with the use of certified backflow prevention devices. In this case, the minimum device(s) to be used on the all buildings service lines shall be a certified reduced pressure zone backflow preventer, meeting or exceeding CSA 64.4. This device must be tested on an annual basis by a certified tester. This device must be tested on an annual basis by a certified tester. For protection of water users within any of the buildings, appropriate backflow preventers shall be attached to any hose bibb connection or water line where there is the possibility of contaminants entering the potable water system due to back-siphonage or backpressure.
17. Flow measurement facilities shall be provided on all wastewater treatment plants for monitoring of the final discharged effluent.
18. The wastewater treatment plant shall be equipped with adequate gas detectors.
19. Provision should be made for sampling at each supernatant draw-off level. An alternate disposal method for the supernatant liquor or hauling from the plant shall be provided in the case the supernatant is not suitable or other conditions make it advisable not to return it to the plant.
20. An adequate number of sampling pipes shall be provided at proper locations to enable an assessment of the quality of the digester contents and to determine how much sludge is in the digesters.
21. Emergency generators and fuel storage tanks must be approved by the Department of Digital Government and Service NL.
22. The Water Resources Management Division of this Department is to be informed prior to start-up or restart-up of the sewage treatment facility. Specifically, this Division must be given adequate notice of manufacturer's training sessions and demonstrations of all major components as well as full plant initiation so that a representative may be present.
23. Drainage from mechanical sludge dewatering units shall be returned to the wastewater treatment plant.
24. Any wastewater treatment facility that is designed to collect or collects an average daily volume of 100m³ or more of influent must adhere to the requirements of the federal *Wastewater Systems Effluent Regulations, 2012*.

Miscellaneous

25. The Permit Holder must prevent erosion of drainage ditches, streams or other natural bodies of water by installing rip-rap and/or sodding.
26. This project involves the handling and/or dealing with asbestos cement pipe from certain portions of the work area. Any removal, handling or transport and disposal of asbestos must be carried out in accordance with the Asbestos Abatement Regulations 1998 under the Occupational Health and Safety Act. For further information, contact a Hazardous Materials Officer with the Department of Digital Government and Service NL, Occupational Health & Safety Division at (709) 729-5536 or 729-7037.

APPENDIX B

Special Terms and Conditions for Permit

1. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall keep all systems and works in good condition and repair and in accordance with all laws, by-laws, directions, rules and regulations of any governmental authority. The Permit Holder or its agent(s), subcontractor(s), or consultant(s) shall immediately notify the Minister if any problem arises which may threaten the structural stability of the systems and works, endanger public safety and/or the environment or adversely affect others and/or any body of water either in or outside the said Project areas. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall be responsible for all damages suffered by the Minister and Government resulting from any defect in the systems and works, operational deficiencies/inadequacies, or structural failure.
2. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall operate the said Project and its systems and works in a manner which does not cause any water related and/or environmental problems, including but not limited to problems of erosion, deposition, flooding, and deterioration of water quality and groundwater depletion, in or outside the said Project areas. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall be responsible for any and all damages associated with these problems caused as a result of changes, deficiencies, and inadequacies in the operational procedures by the Permit Holder or its agent(s), subcontractor(s), or consultant(s).
3. If the Permit Holder or its agent(s), subcontractor(s), or consultant(s) fails to perform, fulfil, or observe any of the terms and conditions, or provisions of this Permit, as determined by this Department, the Minister may, without notice, amend, modify, suspend or cancel this Permit in accordance with the *Water Resources Act*.
4. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) indemnify and hold the Minister and Government harmless against any and all liabilities, losses, claims, demands, damages or expenses including legal expenses of any nature whatsoever whether arising in tort, contract, statute, trust or otherwise resulting directly or indirectly from granting this Permit, systems and works in or outside the said Project areas, or any act or omission of the Permit Holder or its agent(s), subcontractor(s), or consultant(s) in or outside the said Project areas, or arising out of a breach or non-performance of any of the terms and conditions, or provisions of this Permit by the Permit Holder or its agent(s), subcontractor(s), or consultant(s).
5. This Permit is subject to all provisions of the *Water Resources Act* and any regulations in effect either at the date of this Permit or hereafter made pursuant thereto or any other relevant legislation enacted by the Province of Newfoundland and Labrador in the future.
6. This Permit shall be construed and interpreted in accordance with the laws of the Province of Newfoundland and Labrador.

- cc: Stephen Barbour, P.Eng.
Nova Consultants Inc.
37 Hallett Crescent
St. John's, NL A1B 4C4
sbarbour@ncinl.ca
- cc: Mr. Chris Blanchard, B.Tech.(Env), AScT
Environmental Scientist
Water Resources Management Division
Department of Environment and Climate Change
P.O. Box 2006
Corner Brook, NL A2H 6J8
cblancha@gov.nl.ca
- cc: Ms. Deneen Spracklin, P.Eng.
Environmental Engineer, Drinking Water and Wastewater Section
Water Resources Management Division
Department of Environment, Climate Change and Municipalities
P.O. Box 8700
4th Floor, West Block, Confederation Building
St. John's, NL A1B 4J6
dspracklin@gov.nl.ca
- cc: Mr. Ehsan Khan, P. Eng.
Municipal Affairs & Environment
Goudie Building
PO Box 3104, Stn B
Happy Valley-Goose Bay NL A0P 1C0
ehsankhan@gov.nl.ca
- cc: Mr. Glenn Coates
Occupational Health and Safety Officer
Occupational Health & Safety, Service NL
P.O. Box 8700
St. John's, NL A1B 4J6
GlennCoates@gov.nl.ca
- cc: Ms. Susan Hoddinott (Western/Labrador)
Regional Director
Digital Government and Service Newfoundland and Labrador
PO Box 2006
Corner Brook NL A2H 6J8
SusanHoddinott@gov.nl.ca

Appendix C - Completion Report

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 36

Date: **SEPTEMBER 24, 2021**

File No: **841.014.1**
Permit No: **WS12115-2021**

Permit Holder: **Town of Labrador City**
P.O. Box 280, 317 Hudson Drive
Labrador City, NL
A2V 2K5
townengineer@labradorcity.ca

Attention: **Mr. Tom Mihajlovic, P. Eng.**

Re: **Labrador City - Drake Wastewater Treatment Plant Upgrades**

Permission was given for : **upgrades to the Drake Wastewater Treatment Plant to include a new step screen, manual bar screen, grit chamber auger, conveyors, compactors, coagulation chemical feed equipment, submersible pumps, rotary sludge dewatering equipment, digested sludge pumps, new aeration system in two digesters, two positive displacement blowers, new dissolved oxygen/temperature monitoring equipment, new UV disinfection system and related works and appurtenances as described in a specification (Volume 1 & 2) and revised set of drawings numbered 003-194 (MI. no. 17-SCF-19-00120) as received from Nova Consultants Inc. on September 10, 2021 and additional information submitted on September 23, 2021.**

I (the Permit Holder named above or agent authorized to represent the Permit Holder) do hereby certify that the project described above was completed in accordance with the plans and specifications submitted to the Department of Environment and Climate Change and that the work was carried out in strict compliance with the terms and conditions of the Permit issued for this project.

Date: _____ Signature: _____

This completion report must be completed and forwarded to the following address upon completion of the approved work.

Department of Environment and Climate Change
Water Resources Management Division
PO Box 8700
St. John's NL A1B 4J6