

Government of Newfoundland and Labrador Department of Environment and Climate Change Water Resources Management Division

PERMIT TO CONSTRUCT

Pursuant to the Water Resources Act, SNL 2002 cW-4.01, specifically Section(s) 36

Date: JULY 28, 2022 File No: <u>843.067.5</u>

Permit No: **WS12594-2022**

Permit Holder: Town of Grand Falls - Windsor

5 High Street

Grand Falls - Windsor NL

A2A 2J8

chad.clendennning@townofgfw.com

Attention: Mr. Chad Clendenning

Re: Grand Falls-Windsor-Circular Road - Cured-In-Place Sanitary Sewer System Relining

Permission is hereby given for: rehabilitating sections of sanitary sewer by Cured-In-Place Pipe (CIPP) lining method, the installation of 22 m of 150 mm diameter PVC sanitary sewermain, new manholes, cleanouts and related works as described on a set of revised drawings numbered 1659-22 (17-GI-22-00003), sheets C1.01 to C1.05 inclusive as received from DMG Consulting Limited on July 14, 2022.

- This Permit does not release the Permit Holder from the obligation to obtain appropriate approvals from other concerned municipal, provincial and federal agencies.
- The Permit Holder must obtain the approval of the Crown Lands Administration Division if the project is being carried out on Crown Land.
- This Permit is subject to the terms and conditions indicated in Appendices A and B (attached).
- It should be noted that prior to any significant changes in the design or installation of the proposed works, or in event of changes in ownership or management of the project, an amendment to this Permit must be obtained from the Department of Environment and Climate Change under Section 49 of the *Water Resources Act*.

(for) MINISTER

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR

Department of Environment and Climate Change

File No: <u>843.067.5</u> Permit No: <u>WS12594-2022</u>

APPENDIX A

Terms and Conditions for Permit

Water & Sewer General

- 1. Water pumped from excavations or work areas, or any runoff or effluent directed out of work sites, must have silt and turbidity removed by settling ponds, filtration, or other suitable treatment before discharging to a body of water. Effluent discharged into receiving waters must comply with the *Environmental Control Water and Sewage Regulations*, 2003.
- 2. All operations must be carried out in a manner that prevents damage to land, vegetation, and watercourses, and which prevents pollution of bodies of water.
- 3. Any areas adversely affected by this project must be restored to a state that resembles local natural conditions. Further remedial measures to mitigate environmental impacts on water resources can and will be specified, if considered necessary in the opinion of this Department.
- 4. All waste materials resulting from this project must be disposed of at a site approved by the Department of Digital Government and Service NL.
- 5. The works proposed must satisfy the requirements of the latest applicable codes and standards, and be consistent with or otherwise address the design criteria set out in this Department's publication *Guidelines for the Design*, *Construction, and Operation of Water and Sewerage Systems*, 2005, and as amended from time to time.
- 6. The work must be undertaken in strict compliance with the submitted documents and the latest version of the *Municipal Water, Sewer and Roads Master Construction Specifications*. A copy of all documents, including the *Municipal Water, Sewer and Roads Master Construction Specifications* must be available for viewing at the construction site office at all times.
- 7. Liaison is to be maintained with the Environmental Scientist representing the Drinking Water and Wastewater Section of this Department, during the construction and operation of the project. They shall be notified of the pre-construction and post-construction meetings so that they may attend, if deemed necessary. They can be reached at telephone (709) 637-2034.
- 8. Officials of this Department may visit the project from time to time to ensure that work is carried out within the provisions of this Permit, and is not creating any environmental hazard.
- 9. Any changes in the approved works, or works other than those specified in the application, must be submitted, in writing, to this Department, and approved, in the form of an Amendment to this Permit, prior to any work.
- 10. Copies of this Permit, as well as any subsequent Amendments, must be provided to the contractor(s) who will be carrying out these works, and to the engineer's site representative.
- 11. The attached Completion Report (Appendix C) for Permit No. 12594 must be completed and returned to this Department upon completion of the approved works. Pictures must be submitted along with the completion report, showing the project site prior to and after development.
- 12. This Permit is valid for two years from the date of issue. Work must be completed by that date or the application and approval procedure must be repeated.

- 13. The drinking water and wastewater system shall be operated and maintained in accordance with the Permit to Operate issued by this Department.
- 14. The Owner must update any drawings maintained of the drinking water or wastewater system to reflect the modification or replacement of the works, where applicable.

Sewer Systems

- 15. Safety landings to be installed in all manholes over 5m in depth and in accordance with the Municipal Master Specification.
- 16. In the event that private or existing sewer lines are disturbed during construction, the lines are to be restored to their original *working* condition. Care shall be taken to ensure that soil or other material does not enter the lines to cause blockage.
- 17. Drop manholes must be provided for lateral sanitary sewers entering a manhole at an elevation of 600 mm or more above the manhole invert. Where the difference between the incoming sanitary sewer and the manhole invert is less than 600 mm, the invert should be filleted to prevent deposition of solids.
- 18. The flow channel through manholes should be made to conform in shape and slope to that of the sanitary sewer.
- 19. The direct connection of sanitary sewer service lines to manholes is prohibited unless the service enters at the flow line of the manhole. In this instance, filleting must be provided to prevent solids deposition.
- 20. All sanitary sewers shall be laid or covered with sufficient depth of suitable material to prevent frost penetration and damage from traffic loading.

Miscellaneous

21. The Permit Holder must prevent erosion of drainage ditches, streams or other natural bodies of water by installing rip-rap and/or sodding.

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR Department of Environment and Climate Change

File No: <u>843.067.5</u> Permit No: <u>WS12594-2022</u>

APPENDIX B

Special Terms and Conditions for Permit

- 1. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall keep all systems and works in good condition and repair and in accordance with all laws, by-laws, directions, rules and regulations of any governmental authority. The Permit Holder or its agent(s), subcontractor(s), or consultant(s) shall immediately notify the Minister if any problem arises which may threaten the structural stability of the systems and works, endanger public safety and/or the environment or adversely affect others and/or any body of water either in or outside the said Project areas. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall be responsible for all damages suffered by the Minister and Government resulting from any defect in the systems and works, operational deficiencies/inadequacies, or structural failure.
- 2. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall operate the said Project and its systems and works in a manner which does not cause any water related and/or environmental problems, including but not limited to problems of erosion, deposition, flooding, and deterioration of water quality and groundwater depletion, in or outside the said Project areas. The Permit Holder and its agent(s), subcontractor(s), and consultant (s) shall be responsible for any and all damages associated with these problems caused as a result of changes, deficiencies, and inadequacies in the operational procedures by the Permit Holder or its agent(s), subcontractor(s), or consultant(s).
- 3. If the Permit Holder or its agent(s), subcontractor(s), or consultant(s) fails to perform, fulfil, or observe any of the terms and conditions, or provisions of this Permit, as determined by this Department, the Minister may, without notice, amend, modify, suspend or cancel this Permit in accordance with the *Water Resources Act*.
- 4. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) indemnify and hold the Minister and Government harmless against any and all liabilities, losses, claims, demands, damages or expenses including legal expenses of any nature whatsoever whether arising in tort, contract, statute, trust or otherwise resulting directly or indirectly from granting this Permit, systems and works in or outside the said Project areas, or any act or omission of the Permit Holder or its agent(s), subcontractor(s), or consultant(s) in or outside the said Project areas, or arising out of a breach or non-performance of any of the terms and conditions, or provisions of this Permit by the Permit Holder or its agent(s), subcontractor(s), or consultant(s).
- 5. This Permit is subject to all provisions of the *Water Resources Act* and any regulations in effect either at the date of this Permit or hereafter made pursuant thereto or any other relevant legislation enacted by the Province of Newfoundland and Labrador in the future.
- 6. This Permit shall be construed and interpreted in accordance with the laws of the Province of Newfoundland and Labrador.

File No: <u>843.067.5</u> Permit No: <u>WS12594-2022</u>

cc: Ms. Victoria Pelley, EIT DMG Consulting Ltd. 185 Roe Avenue P.O. Box 194 Gander, NL, A1V 1W6 victoria.pelley@dmg.nf.ca

Ms. Deneen Spracklin, P.Eng.
 Environmental Engineer, Drinking Water and Wastewater Section Water Resources Management Division
 Department of Environment and Climate Change
 P.O. Box 8700
 4th Floor, West Block, Confederation Building
 St. John's, NL A1B 4J6
 dspracklin@gov.nl.ca

cc: Mr. Wilf Maloney, P. Eng.
Regional Engineer, Central Regional Office
Department of Transportation and Infrastructure
PO Box 2222
Gander, NL A1V 2N9
WilfMaloney@gov.nl.ca

cc: Mr. Wayne Lynch (Central)
Regional Director (Central)
Digital Government and Service Newfoundland and Labrador
P.O. Box 2222
Gander, NL A1V 2N9
waynelynch@gov.nl.ca

cc: Mr. Chris Blanchard, B.Tech.(Env), AScT Environmental Scientist Water Resources Management Division Department of Environment and Climate Change P.O. Box 2006 Corner Brook, NL A2H 6J8 cblancha@gov.nl.ca



Date:

Government of Newfoundland and Labrador Department of Environment and Climate Change Water Resources Management Division

Appendix C - Completion Report

Pursuant to the I	Water Resources Act, SNL 2002 cW-4.01,	specifically Section(s) 36
Date:	JULY 28, 2022	File No: <u>843.067.5</u> Permit No: <u>WS12594-2022</u>
Permit Holder:	Town of Grand Falls - Windsor 5 High Street Grand Falls - Windsor NL A2A 2J8 chad.clendennning@townofgfw.com	
Attention:	Mr. Chad Clendenning	
Re:	Grand Falls-Windsor-Circular Road - Cured-In-Place Sanitary Sewer System Relining	
installation of 2 described on a	22 m of 150 mm diameter PVC sanitary s	tary sewer by Cured-In-Place Pipe (CIPP) lining method, the sewermain, new manholes, cleanouts and related works as 22 (17-GI-22-00003), sheets C1.01 to C1.05 inclusive as 22.
that the j	project described above was completed in	rized to represent the Permit Holder) do hereby certify accordance with the plans and specifications submitted hange and that the work was carried out in strict Permit issued for this project.

This completion report must be completed and forwarded to the following address upon completion of the approved work.

Signature:

Department of Environment and Climate Change Water Resources Management Division PO Box 8700 St. John's NL A1B 4J6