

AMENDMENT TO PERMIT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 49

Date: **AUGUST 15, 2016**

File No: **844.004.3**
Permit No: **WS7732-2014**
Amendment No: **1**

Permit Holder: **Town of Whitbourne
P.O. Box 119
Whitbourne NL A0B 3K0**


Attention: **Ms. Crystal Peddle, Town Clerk**

Re: **Whitbourne - Main Street Watermain Replacement-Phase 2**

The original Permit dated SEPTEMBER 19, 2014 is amended as follows:

the installation of 116 m of 100 mm PVC sanitary sewer forcemain and related appurtenances as described in a specification titled, "Town of Whitbourne Station Road-Sanitary Sewer Forcemain" as received from Meridian Engineering Inc. August 12, 2016.

All other terms and conditions of the original Permit will apply and failure to comply with the terms and conditions of this amendment and the original Permit will render this Permit null and void, place the Permit Holder and their agent(s) in violation of the *Water Resources Act* and make the Permit Holder responsible for taking any remedial measures as may be prescribed by this Department.




MINISTER

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR
Department of Environment and Conservation

File No: 844.002.3
Permit No: WS7732-2014
Amendment No: I

APPENDIX A
Terms and Conditions for Amendment

1. Forcemains shall enter the gravity sewer at a point not more than 600 mm above the flow line of the receiving manhole.
2. The direct connection of sanitary sewer services to sewage lift stations is not permitted. Connection may be made to a sanitary sewer main leading to a lift station, or to a manhole immediately prior to the sewage lift station provided the sanitary sewer lateral enters the manhole at the flow line.
3. Because the forcemain in this project is constructed of the same material as the watermain which might cause the forcemain to be confused with the watermain, then the forcemain shall be appropriately identified.

- cc: Mr. Scott Smith, P. Eng.
Meridian Engineering Inc.
10 Thompson Street
Clareville, NL A5A 1Y9
ssmith@meridianengineering.ca
- cc: Mr. Calvin Adams, Regional Manager
GSC - Harbour Grace, Service NL
7-9 Roddick Cres, P.O. Box 512
Harbour Grace, NL A0A 2M0
calvinadams@gov.nl.ca
- cc: Mr. Inayat Rehman, P.Eng.
District Engineer
Department of Municipal Affairs
Main Floor, West Block, Confederation Bldg.
P.O. Box 8700
St. John's, NL A1B 4J6
inayatrehman@gov.nl.ca