

Government of Newfoundland and Labrador
Department of Municipal Affairs and Environment
Water Resources Management Division

File No: <u>844.097.016</u> Permit No: <u>WS9961-2018</u>

PERMIT TO CONSTRUCT

Pursuant to the Water Resources Act, SNL 2002 cW-4.01, specifically Section(s) 36

Date:

OCTOBER 10, 2018

Permit Holder:

City of St. John's

P.O. Box 908

St. John's NL A1C 5M2

Attention:

Mr. Scott Winsor, P. Eng.

Re:

St. John's - Goulds Sewage Pumping Station Shoal Bay Road Forcemain Replacement

Permission is hereby given for: the installation of 550 m of 250 mm PVC sanitary sewer forcemain as described in the drawings titled, "Goulds Sewage Pumping Station: Shoal Bay Road Forcemain Replacement - CP2" as received from R.V. Anderson Associates Limited on October 2, 2018.

- This Permit does not release the Permit Holder from the obligation to obtain appropriate approvals from other concerned municipal, provincial and federal agencies.
- The Permit Holder must obtain the approval of the Crown Lands Administration Division if the project is being carried out on Crown Land.
- This Permit is subject to the terms and conditions indicated in Appendices A and B (attached).
- It should be noted that prior to any significant changes in the design or installation of the proposed works, or in event of changes in
 ownership or management of the project, an amendment to this Permit must be obtained from the Department of Municipal Affairs and
 Environment under Section 49 of the Water Resources Act.

MINISTER

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR Department of Municipal Affairs and Environment

File No: <u>844.097.016</u> Permit No: <u>WS9961-2018</u>

APPENDIX A Terms and Conditions for Permit

Water & Sewer General

- Water pumped from excavations or work areas, or any runoff or effluent directed out of work sites, must have silt and turbidity removed by settling ponds, filtration, or other suitable treatment before discharging to a body of water. Effluent discharged into receiving waters must comply with the Environmental Control Water and Sewage Regulations, 2003.
- 2. All operations must be carried out in a manner that prevents damage to land, vegetation, and watercourses, and which prevents pollution of bodies of water.
- Any areas adversely affected by this project must be restored to a state that resembles local natural conditions. Further remedial measures to mitigate environmental impacts on water resources can and will be specified, if considered necessary in the opinion of this Department.
- 4. All waste materials resulting from this project must be disposed of at a site approved by the Department of Service NL.
- 5. The works proposed must satisfy the requirements of the latest applicable codes and standards, and be consistent with or otherwise address the design criteria set out in the Department of Municipal Affairs and Environment publication *Guidelines for The Design*, Construction, and Operation of Water and Sewerage Systems, 2005, and as amended from time to time.
- 6. The work must be undertaken in strict compliance with the submitted documents and the latest version of the Municipal Water, Sewer and Roads Master Construction Specifications. A copy of all documents, including the Municipal Water, Sewer and Roads Master Construction Specifications must be available for viewing at the construction site office at all times.
- Liaison is to be maintained with the Environmental Scientist representing the Drinking Water and Wastewater Section of this
 Department, during the construction and operation of the project. They shall be notified of the pre-construction and post-construction
 meetings so that they may attend, if deemed necessary. They can be reached at telephone (709) 729-2558.
- 8. Officials of this Department may visit the project from time to time to ensure that work is carried out within the provisions of this Permit, and is not creating any environmental hazard.
- 9. Any changes in the approved works, or works other than those specified in the application, must be submitted, in writing, to this Department, and approved, in the form of an Amendment to this Permit, prior to any work.
- 10. Copies of this Permit, as well as any subsequent Amendments, must be provided to the contractor(s) who will be carrying out these works, and to the engineer's site representative.
- 11. The attached Completion Report (Appendix C) for Permit No. 9961 must be completed and returned to this Department upon completion of the approved works. Pictures must be submitted along with the completion report, showing the project site prior to and after development.
- 12. This Permit is valid for two years from the date of issue. Work must be completed by that date or the application and approval procedure must be repeated.
- 13. The wastewater system shall be operated and maintained in accordance with the Permit to Operate issued by this Department.
- 14. Management of stormwater is the responsibility of the municipality or LSD. Stormwater management should focus on ensuring that the post-development stormwater runoff rate will be equal to or less than the pre-development runoff rate. Any stormwater runoff has the potential to contribute to flooding downstream which may have liability issues for the municipality or LSD if not managed properly.
- 15. The Owner must update any drawings maintained of the wastewater system to reflect the modification or replacement of the works, where applicable.

Sewer Systems

16. In the event that private or existing sewer lines are disturbed during construction, the lines are to be restored to their original working condition. Care shall be taken to ensure that soil or other material does not enter the lines to cause blockage.

17. All sanitary sewers shall be laid or covered with sufficient depth of suitable material to prevent frost penetration and damage from traffic loading.

Lift Stations and Forcemains

- 18. There shall be at least 3.0 m horizontal separation between water mains and sanitary sewer forcemains. Watermains crossing forcemains shall be laid to provide a minimum vertical separation of 450 mm between the crown of the forcemain and the invert of the watermain. Also in this regard, one full length of watermain should be centered over the forcemain so that both joints will be as far from the forcemain as possible.
- 19. Automatic air relief valves shall be placed at all high points in the forcemain to prevent air locking
- 20. Provision must be provided for the temporary pumping of sewage to the existing receiving manhole while the sewage pumping station and forcemain is being upgraded. Pumping to any other location will not be considered for this project.
- All septic sludge and grit removed from the lift station chamber must be disposed of by a licensed hauler to an approved waste disposal site.

Miscellaneous

- 22. The Permit Holder must prevent erosion of drainage ditches, streams or other natural bodies of water by installing rip-rap and/or sodding.
- 23. This project involves the handling and/or dealing with asbestos cement pipe from certain portions of the work area. Any removal, handling or transport and disposal of asbestos must be carried out in accordance with the Asbestos Abatement Regulations 1998 under the Occupational Health and Safety Act. For further information, contact a Hazardous Materials Officer with Service NL, Occupational Health & safety Division at (709) 729-5536 or 729-7037.
- 24. All drains and vents shall be equipped with screens to prevent the entry of insects, birds and rodents.
- 25. The ends of drains and overflows shall be located so as to prevent erosion. Where necessary, concrete or similar splash plates shall be located below the end of the overflow, and the immediate surrounding area shall be filled to a depth of 10 cm with 19 mm minus stone to prevent ponding.

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR Department of Municipal Affairs and Environment

File No: <u>844.097.016</u> Permit No: <u>WS9961-2018</u>

APPENDIX B

Special Terms and Conditions for Permit

- 1. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall keep all systems and works in good condition and repair and in accordance with all laws, by-laws, directions, rules and regulations of any governmental authority. The Permit Holder or its agent(s), subcontractor(s), or consultant(s) shall immediately notify the Minister if any problem arises which may threaten the structural stability of the systems and works, endanger public safety and/or the environment or adversely affect others and/or any body of water either in or outside the said Project areas. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall be responsible for all damages suffered by the Minister and Government resulting from any defect in the systems and works, operational deficiencies/inadequacies, or structural failure.
- 2. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall operate the said Project and its systems and works in a manner which does not cause any water related and/or environmental problems, including but not limited to problems of erosion, deposition, flooding, and deterioration of water quality and groundwater depletion, in or outside the said Project areas. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) shall be responsible for any and all damages associated with these problems caused as a result of changes, deficiencies, and inadequacies in the operational procedures by the Permit Holder or its agent(s), subcontractor(s), or consultant(s).
- 3. If the Permit Holder or its agent(s), subcontractor(s), or consultant(s) fails to perform, fulfil, or observe any of the terms and conditions, or provisions of this Permit, as determined by this Department, the Minister may, without notice, amend, modify, suspend or cancel this Permit in accordance with the *Water Resources Act*.
- 4. The Permit Holder and its agent(s), subcontractor(s), and consultant(s) indemnify and hold the Minister and Government harmless against any and all liabilities, losses, claims, demands, damages or expenses including legal expenses of any nature whatsoever whether arising in tort, contract, statute, trust or otherwise resulting directly or indirectly from granting this Permit, systems and works in or outside the said Project areas, or any act or omission of the Permit Holder or its agent(s), subcontractor(s), or consultant(s) in or outside the said Project areas, or arising out of a breach or non-performance of any of the terms and conditions, or provisions of this Permit by the Permit Holder or its agent(s), subcontractor(s), or consultant(s).
- 5. This Permit is subject to all provisions of the Water Resources Act and any regulations in effect either at the date of this Permit or hereafter made pursuant thereto or any other relevant legislation enacted by the Province of Newfoundland and Labrador in the future.
- 6. This Permit shall be construed and interpreted in accordance with the laws of the Province of Newfoundland and Labrador.

File No: <u>844.097.016</u> Permit No: <u>WS9961-2018</u>

Ms. Deneen Spracklin, P.Eng.
Environmental Engineer, Drinking Water and Wastewater Section
Water Resources Management Division
Department of Municipal Affairs and Environment
P.O. Box 8700
4th Floor, West Block, Confederation Building
St. John's, NL A1B 4J6
dspracklin@gov.nl.ca

Mr. Inayat Rehman, P.Eng. District Engineer Department of Municipal Affairs and Environment Main Floor, West Block, Confederation Bldg. P.O. Box 8700 St. John's, NL A1B 4J6 inayatrehman@gov.nl.ca

Mr. Rick Curran (Eastern)
Director of Regional Operations Avalon, Service NL
149 Smallwood Drive, MountPearl
PO Box 8700
St. John's NL A1B 4J6
rjcurran@gov.nl.ca

Mr. Chris Newman, P.Tech
R.V. Anderson Associates Limited
74 O'Leary Avenue, Suite 201
P.O. Box 13039, Stn. A
St. John's, NL A1B 3V8
cnewman@rvanderson.com



Date:

Government of Newfoundland and Labrador
Department of Municipal Affairs and Environment
Water Resources Management Division

Appendix C - Completion Report

Pursuant to the IV	ater Resources Act, SNL 2002 cW-4.	01, specifically Section(s) 36
Date:	OCTOBER 10, 2018	File No: <u>844.097.016</u> Permit No: <u>WS9961-2018</u>
Permit Holder:	City of St. John's P.O. Box 908 St. John's NL A1C 5M2	
Attention:	Mr. Scott Winsor, P. Eng.	
Re:	St. John's - Goulds Sewage Pumping Station Shoal Bay Road Forcemain Replacement	
		f 250 mm PVC sanitary sewer forcemain as described in the drawings titled, "Goulds in Replacement - CP2" as received from R.V. Anderson Associates Limited on Octobe
described Affairs a	d above was completed in accordanc	nuthorized to represent the Permit Holder) do hereby certify that the project be with the plans and specifications submitted to the Department of Municipal was carried out in strict compliance with the terms and conditions of the Permit

This completion report must be completed and forwarded to the following address upon completion of the approved work.

Signature:

Department of Municipal Affairs and Environment Water Resources Management Division PO Box 8700 St. John's NL A1B 4J6