

AMENDMENT TO PERMIT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 49

Date: MAY 12, 2016

File No: 550-01-01-07-054
Permit No: PRO7443-2014
Amendment No: 3

Permit Holder: Labrador Island Link Corporation
P.O. Box 12800
Hydro Place, 500 Columbus Drive
St. Johns, NL A1B 0C9


Attention: Peter Madden

Re: Clarenville - Shoal Harbour River PPWSA -Transmission Line - Labrador Island Link Corporation

The original Permit dated MAY 01, 2014 is amended as follows:

Term and Conditions number 23 is to be replaced with Appendix A attached.

All other terms and conditions of the original Permit will apply and failure to comply with the terms and conditions of this amendment and the original Permit will render this Permit null and void, place the Permit Holder and their agent(s) in violation of the *Water Resources Act* and make the Permit Holder responsible for taking any remedial measures as may be prescribed by this Department.



MINISTER

File No: 550-01-01-07-054
Permit No: PRO7443-2014
Amendment No: 3

- cc: Town of Clarendville
Attn. Marie Blackmore, Town Clerk
99 Pleasant Street
Clarendville NL A5A 1V9
- cc: Mr. Ben Hammond
Environmental Scientist, Surface Water Section
Water Resources Management Division
Department of Environment and Conservation
P.O. Box 8700, Confederation Building
4th Floor, West Block, St. John's, NL
A1B 4J6
- cc: Ms. Paula Dawe, P.Eng.
Manager, Drinking Water and Wastewater Section
Water Resources Management Division
Dept. of Environment and Conservation
PO Box 8700
St. John's, NL A1B 4J6

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR
Department of Environment and Conservation

File No: 550-01-01-07-054
Permit No: PRO7443-2014
Amendment No: 3

APPENDIX A
Terms and Conditions for Amendment

There shall be no bulk fuel storage associated with this project within the protected public water supply area. A maximum of 9,500 liters of fuel may be brought into the operating area at any given time, contained in tanks housed in no more than three (3) vehicles for transfer to equipment and machinery. Spill/drip trays shall be used during fuel transfers. Spill kits shall be carried on all equipment and trucks. Multiple large spill cache barrels shall be placed at strategic high traffic allocation throughout the protected public water supply area. One Springdale Forest Resources and one Nalcor Environmental Monitor shall provide spill response and oversight. Tanks shall be inspected for potential leaks at all fuelling/re-fuelling stops. When possible, refueling should occur over an impervious surface. Vehicles containing fuel storage shall not be left unattended while inside the protected public water supply. Secondary containment shall be inspected daily for liquids, any water shall be removed and all leaks shall be reported to the Environmental Monitors immediately. All refueling sites shall be located at least 150m from any water body or wetland. The proponent is hereby informed that fuel storage and handling requires a separate approval under the Storage and Handling of Gasoline and Associated Products Regulations, 2003.