

AMENDMENT TO PERMIT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 49

Date: AUGUST 25, 2016

File No: 550-01-03-07-016
Permit No: PRO7470-2014
Amendment No: 4

Permit Holder: Labrador-Island Link Corporation
P.O. Box 12800
Hydro Place, 500 Columbus Drive
St. John's NL A1B 0C9



Attention: Mr. Peter Madden

Re: Flowers Cove - French Island Pond PWSA - Linear Development - Labrador Island Link Corporation

The original Permit dated MAY 21, 2014 is amended as follows:

Diversion of a non-NTS stream to facilitate construction of structure S3-29 is permitted based on additional conditions in Appendix A attached.

All other terms and conditions of the original Permit will apply and failure to comply with the terms and conditions of this amendment and the original Permit will render this Permit null and void, place the Permit Holder and their agent(s) in violation of the *Water Resources Act* and make the Permit Holder responsible for taking any remedial measures as may be prescribed by this Department.



MINISTER

File No: 550-01-03-07-016
Permit No: PRO7470-2014
Amendment No: 4

- cc: Town of Flower's Cove
Mr. Bruce Way
P.O. Box 149
Flower's Cove, NL A0K 2N0
townofflowerscove@nf.aibn.com
- cc: Ms. Carla Hayes, P.Tech
Environmental Scientist , Drinking Water and Wastewater Section

Water Resources Management Division
Department of Environment and Climate Change
P.O. Box 2006
Corner Brook, NL A2H 6J8
CarlaHayes@gov.nl.ca
- cc: Ms. Paula Dawe, P.Eng.
Manager, Drinking Water and Wastewater Section
Water Resources Management Division
Department of Environment and Climate Change
P.O. Box 8700
4th Floor, West Block, Confederation Building
St. John's, NL A1L 4J6
pauladawe@gov.nl.ca

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR
Department of Environment and Conservation

File No: 550-01-03-07-016
Permit No: PRO7470-2014
Amendment No: 4

APPENDIX A
Terms and Conditions for Amendment

1. Any work that must be performed below the high water mark must be carried out during a period of low water levels.
2. Sediment and erosion control measures must be installed before starting work. All control measures must be inspected regularly and any necessary repairs made if damage is discovered.
3. Inspections of the natural streambed and diverted streambed must be conducted after any significant precipitation event to ensure all sediment and erosion control measures are operating effectively.
4. The bed, banks and floodplains of watercourses, or other vulnerable areas affected by this project, must be adequately protected from erosion by seeding, sodding or placing of rip-rap.
5. Fill material must be of good quality, free of fines or other substances including metals, organics, or chemicals that may be harmful to the receiving waters.
6. Pictures must be submitted showing the project site prior to and after development.