



Government of Newfoundland and Labrador  
Department of Environment and Climate Change  
Water Resources Management Division

## AMENDMENT TO PERMIT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 49

Date: **NOVEMBER 01, 2016**

File No: **550-01-03-07-016**  
Permit No: **PRO7470-2014**  
Amendment No: **5**

Permit Holder: **Labrador-Island Link Corporation**  
**P.O. Box 12800**  
**Hydro Place, 500 Columbus Drive**  
**St. John's NL A1B 0C9**

Attention: **Mr. Peter Madden**


Re: **Flowers Cove - French Island Pond PWSA - Linear Development - Labrador Island Link Corporation**

**The original Permit dated MAY 21, 2014 is amended as follows:**

Terms and Conditions number 22 & 24 are to be replaced with Appendix A attached.

**All other terms and conditions of the original Permit will apply and failure to comply with the terms and conditions of this amendment and the original Permit will render this Permit null and void, place the Permit Holder and their agent(s) in violation of the *Water Resources Act* and make the Permit Holder responsible for taking any remedial measures as may be prescribed by this Department.**



  
MINISTER

cc: Ms. Carla Hayes, P.Tech  
Environmental Scientist, Drinking Water and Wastewater Section

Water Resources Management Division  
Department of Environment and Climate Change  
P.O. Box 2006  
Corner Brook, NL A2H 6J8  
CarlaHayes@gov.nl.ca

cc: Ms. Paula Dawe, P.Eng.  
Manager, Drinking Water and Wastewater Section  
Water Resources Management Division  
Department of Environment and Climate Change  
P.O. Box 8700  
4th Floor, West Block, Confederation Building  
St. John's, NL A1B 4J6  
pauladawe@gov.nl.ca

cc: Town of Flower's Cove  
Mr. Bruce Way  
P.O. Box 149  
Flower's Cove, NL A0K 2N0  
townofflowerscove@nf.aibn.com

**APPENDIX A**  
**Terms and Conditions for Amendment**

---

- There shall be no bulk fuel storage associated with this project within the protected public water supply area. A maximum of 5,500 liters of fuel may be brought into the operating area at any given time, contained in tanks housed in no more than three (3) vehicles for transfer to equipment and machinery. Spill drip trays shall be used during fuel transfers. Spill kits shall be carried on all equipment and trucks. Multiple large spill catch barrels shall be placed at strategic high traffic allocation throughout the protected public water supply area. One Valard and one Nalcor Environmental Monitor shall provide spill response and oversight. Tanks shall be inspected for potential leaks at all fuelling/re-fuelling stops. When possible, refueling should occur over an impervious surface. Vehicles containing fuel storage shall not be left unattended while inside the protected public water supply. Secondary containment shall be inspected daily for liquids, any water shall be removed and all leaks shall be reported to the Environmental Monitors immediately. All refueling sites shall be located at least 150m from any water body or wetland. The proponent is hereby informed that fuel storage and handling requires a separate approval under the Storage and Handling of Gasoline and Associated Products Regulations, 2003.
  
- A complete oil spill clean-up kit must be on site at all times when gasoline or fuel powered equipment is being used or refueled. The kit must contain the following:
  - Fire pump and 100 metres of hose
  - Two hand operated fuel pumps
  - Six recovery containers such as empty 205 litre drums
  - Four shovels
  - Two pick axes
  - Ten metres of containment boom
  - Twenty-five absorbent pads
  - One hundred litres of loose absorbent material