



Tap Water Quality for Public Water Supplies in Newfoundland and Labrador Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	C	C	A	C	A	C	A	C	A	C	A	C	A
Aesthetic (A) or Contaminant (C) Parameter																		
Anchor Point																		
Anchor Point	Well Cove Brook	Sep 17, 2019	106.00	10	243.0	120.00	8.28	158		0.60	LTD	LTD	25.00	13	LTD	LTD	7	1
Appleton																		
Appleton (+Glenwood)	Gander Lake (The Outflow)	Aug 12, 2019	LTD	<u>26</u>	33.0	2.00	<u>5.16</u>	21		0.60	LTD	LTD	1.00	7	LTD	LTD	LTD	1
Aquaforte																		
Aquaforte	Davies Pond	Aug 21, 2019	12.00	14	107.0	LTD	7.79	70		0.40	LTD	LTD	LTD	24	LTD	LTD	14	2
Arnold's Cove																		
Arnold's Cove	Steve's Pond (2 Intakes)	Aug 21, 2019	12.00	10	61.0	5.00	7.21	40		0.60	LTD	LTD	2.00	13	LTD	LTD	9	1
Avondale																		
Avondale	Lee's Pond	Sep 05, 2019	14.00	2	88.0	12.00	8.25	57		0.40	LTD	LTD	5.00	15	LTD	LTD	11	1
Baie Verte																		
Baie Verte	Southern Arm Pond	Sep 26, 2019	LTD	<u>19</u>	34.0	5.00	<u>5.05</u>	22		0.20	LTD	LTD	2.00	7	LTD	LTD	2	1
Baine Harbour																		
Baine Harbour	Baine Harbour Pond	Aug 29, 2019	8.00	<u>83</u>	38.0	5.00	7.33	25		0.40	LTD	LTD	2.00	4	LTD	LTD	4	2
Bartletts Harbour																		
Bartletts Harbour	Long Pond (same as Castors River North)	Sep 18, 2019	96.00	<u>23</u>	265.0	112.00	8.42	172		0.50	LTD	LTD	25.00	22	LTD	LTD	12	3
Bauline																		
Bauline	#1 Brook Path Well	Aug 15, 2019	54.00	12	362.0	100.00	7.87	235		0.20	0.01	LTD	30.00	70	LTD	LTD	28	9
Bay L'Argent																		
Bay L'Argent	Sugarloaf Hill Pond	Sep 05, 2019	11.00	<u>73</u>	52.0	5.00	7.38	34		0.50	LTD	LTD	2.00	7	LTD	LTD	6	LTD
Bay Roberts																		
Bay Roberts, Spaniard's Bay	Rocky Pond	Aug 27, 2019	LTD	3	77.0	5.00	6.81	50		0.70	LTD	LTD	2.00	17	LTD	LTD	10	2
Bay de Verde																		
Bay de Verde	Island Pond	Sep 27, 2019	LTD	9	56.0	LTD	<u>5.55</u>	36		0.60	LTD	LTD	LTD	14	LTD	LTD	7	3
Bay de Verde	Island Pond	Sep 27, 2019	LTD	7	58.0	LTD	<u>5.01</u>	38		0.80	LTD	LTD	LTD	14	LTD	LTD	7	3

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Aesthetic (A) or Contaminant (C) Parameter				A			A	A		C	C			A	C		A	A
Beaches																		
Beaches	Grassey Pond Brook	Aug 13, 2019	17.00	<u>45</u>	49.0	15.00	7.45	32		0.70	LTD	LTD	6.00	5	LTD	1.000	3	1
Bellburns																		
Bellburns	Bound Brook Tributary	Sep 30, 2019	151.00	<u>31</u>	350.0	171.00	8.05	228		0.30	LTD	LTD	47.00	21	LTD	LTD	10	4
Belleoram																		
Belleoram	Rabbits Pond	Sep 24, 2019	LTD	<u>104</u>	58.0	LTD	<u>5.07</u>	38		0.60	0.01	LTD	LTD	14	LTD	LTD	9	2
Bellevue																		
Bellevue	Big Pond	Sep 16, 2019	9.00	14	92.0	7.00	7.39	60		0.50	LTD	LTD	3.00	19	LTD	LTD	11	2
Bellevue Beach																		
Bellevue Beach	Unnamed Brook	Sep 16, 2019	12.00	<u>122</u>	63.0	5.00	7.09	41		0.60	LTD	LTD	2.00	9	LTD	LTD	6	2
Benton																		
Benton	Little Pond	Aug 14, 2019	LTD	<u>62</u>	178.0	5.00	<u>6.49</u>	116		0.60	LTD	LTD	2.00	48	LTD	LTD	29	LTD
Birchy Bay																		
Birchy Bay	Jumper's Pond	Aug 13, 2019	20.00	<u>29</u>	86.0	12.00	7.51	56		0.50	LTD	LTD	5.00	13	LTD	LTD	9	LTD
Bird Cove																		
Bird Cove (+Brig Bay)	Inner Gilmour Pond	Sep 17, 2019	119.00	<u>20</u>	259.0	121.00	8.50	168		0.50	LTD	LTD	27.00	13	LTD	LTD	10	1
Biscay Bay																		
Biscay Bay	Unnamed Pond	Aug 21, 2019	11.00	<u>43</u>	63.0	LTD	7.63	41		0.60	LTD	LTD	LTD	15	LTD	LTD	6	2
Bishop's Falls																		
Bishop's Falls	Northern Arm Lake	Aug 15, 2019	6.00	LTD	59.0	20.00	7.31	38		0.90	LTD	LTD	8.00	4	LTD	LTD	LTD	11
Black Duck Cove																		
Black Duck Cove	Long Pond - Black Duck Cove Intake	Sep 17, 2019	84.00	<u>17</u>	206.0	97.00	8.36	134		0.60	LTD	LTD	19.00	13	LTD	LTD	7	1
Black Tickle-Domino																		
Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	Aug 15, 2019	39.00	<u>72</u>	176.0	41.00	7.14	114		12.20	0.02	LTD	10.00	30	LTD	1.000	17	1
Black Tickle-Domino - PWDU	Martin's Pond - Tap at Pumphouse	Aug 15, 2019	11.00	14	128.0	12.00	6.73	83		0.60	0.02	LTD	LTD	32	LTD	2.000	16	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C			A	C		A	A
Aesthetic (A) or Contaminant (C) Parameter																		
Bonavista																		
Bonavista	Long Pond	Aug 13, 2019	31.00	8	139.0	5.00	<u>9.36</u>	90		0.70	LTD	LTD	2.00	20	LTD	LTD	25	2
Botwood																		
Botwood	Northern Arm Lake	Aug 15, 2019	12.00	LTD	71.0	22.00	8.13	46		0.70	LTD	LTD	9.00	4	LTD	LTD	LTD	11
Branch																		
Branch	Valley Pond	Sep 11, 2019	LTD	<u>103</u>	58.0	9.00	6.62	38		1.30	LTD	LTD	2.00	12	LTD	LTD	7	2
Brent's Cove																		
Brent's Cove	Paddy's Pond	Aug 14, 2019	6.00	<u>175</u>	80.0	2.00	6.57	52		1.10	LTD	LTD	1.00	17	LTD	LTD	11	1
Brig Bay																		
Brig Bay	Inner Gilmour Pond	Sep 18, 2019	112.00	<u>20</u>	270.0	125.00	8.49	176		0.40	LTD	LTD	27.00	15	LTD	LTD	12	1
Brigus																		
Brigus (+Cupids, +South River)	Brigus Long Pond (to Brigus)	Aug 27, 2019	LTD	13	52.0	LTD	6.58	34		0.30	LTD	LTD	LTD	11	LTD	LTD	LTD	2
Buchans																		
Buchans - PWDU	Buchans Lake aka Sandy Lake	Sep 23, 2019	LTD	15	18.0	5.00	<u>6.46</u>	12		0.60	LTD	LTD	2.00	2	LTD	LTD	LTD	LTD
Buchans Junction																		
Buchans Junction	Lapland Pond	Sep 23, 2019	LTD	<u>16</u>	34.0	5.00	6.61	22		0.80	LTD	LTD	2.00	6	LTD	LTD	4	LTD
Burgeo																		
Burgeo	Long Pond	Sep 20, 2019	17.00	<u>16</u>	87.0	2.00	7.49	57		0.50	0.02	LTD	1.00	12	LTD	LTD	14	LTD
Burgoyne's Cove																		
Burgoyne's Cove	Lower Rocky Pond	Sep 03, 2019	6.00	7	33.0	5.00	6.92	21		0.30	LTD	LTD	2.00	5	LTD	LTD	4	1
Burin																		
Burin (+Lewin's Cove)	Big Pond	Aug 28, 2019	LTD	<u>20</u>	61.0	7.00	<u>6.47</u>	40		0.40	LTD	LTD	3.00	14	LTD	LTD	6	2
Burin	Long Pond	Aug 28, 2019	LTD	13	56.0	7.00	<u>6.34</u>	36		0.40	LTD	LTD	3.00	13	LTD	LTD	6	5
Port au Bras	Gripe Cove Pond	Aug 28, 2019	6.00	10	96.0	17.00	6.87	62		0.20	LTD	LTD	5.00	20	LTD	LTD	10	4

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C			A	C		A	A
Aesthetic (A) or Contaminant (C) Parameter																		
Burlington																		
Burlington	Eastern Island Pond	Sep 26, 2019	7.00	<u>33</u>	58.0	7.00	<u>6.44</u>	38		0.40	LTD	LTD	3.00	10	LTD	LTD	8	LTD
Burnt Islands																		
Burnt Islands	Long Lake	Sep 10, 2019	LTD	<u>40</u>	71.0	10.00	<u>5.44</u>	46		0.30	LTD	LTD	4.00	17	LTD	LTD	5	4
Burnt Islands - PWDU	Long Lake	Sep 10, 2019	11.00	LTD	25.0	LTD	7.30	16		0.20	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
Cape Freels North																		
Cape Freels North	Long Pond	Aug 20, 2019	5.00	<u>163</u>	98.0	4.00	7.02	64		1.40	LTD	LTD	LTD	25	LTD	LTD	12	2
Cape St. George																		
Cape St. George, Red Brook, De-Grau, Marches Point	Rouzes Brook	Sep 24, 2019	203.00	2	439.0	230.00	<u>8.76</u>	285		0.20	0.01	LTD	59.00	20	LTD	LTD	12	5
Caplin Cove-Southport																		
Southport	Southport Pond	Sep 09, 2019	16.00	<u>19</u>	66.0	9.00	7.16	43		0.40	LTD	LTD	2.00	12	LTD	LTD	8	2
Carbonear																		
Carbonear	Island Pond / Flings Long Pond	Aug 26, 2019	LTD	2	41.0	2.00	6.88	27		0.50	LTD	LTD	1.00	8	LTD	LTD	4	1
Carmanville																		
Carmanville	Grandfathers Pond	Aug 14, 2019	7.00	3	57.0	5.00	7.23	37		0.50	LTD	LTD	2.00	12	LTD	LTD	7	LTD
Cartwright																		
Cartwright	Burdett's Pond	Aug 06, 2019	LTD	<u>99</u>	31.0	LTD	6.54	20		0.50	LTD	LTD	LTD	6	LTD	LTD	5	LTD
Cartwright - PWDU	Burdett's Pond	Aug 06, 2019	LTD	LTD	LTD	LTD	<u>6.29</u>	LTD		0.20	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
Castor River North																		
Castor River North	Long Pond (same as Bartletts Harbour)	Sep 18, 2019	96.00	<u>23</u>	263.0	112.00	8.50	171		0.30	LTD	LTD	25.00	22	LTD	LTD	12	3
Castor River South																		
Castor River South	Unnamed	Sep 18, 2019	217.00	7	447.0	231.00	8.44	291		0.40	LTD	LTD	61.00	13	LTD	LTD	8	2
Cavendish																		
Cavendish	Long Pond	Sep 12, 2019	5.00	5	64.0	9.00	6.86	42		0.30	LTD	LTD	2.00	14	LTD	LTD	8	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	A						
Centreville-Wareham-Trinity																		
Centreville-Wareham	Northwest Pond	Aug 13, 2019	LTD	14	41.0	5.00	<u>6.43</u>	27		0.40	LTD	LTD	2.00	9	LTD	LTD	5	LTD
Trinity	Southwest Feeder Pond	Aug 13, 2019	LTD	<u>28</u>	40.0	5.00	6.58	26		0.30	LTD	LTD	2.00	9	LTD	LTD	5	LTD
Channel-Port aux Basques																		
Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Sep 10, 2019	LTD	<u>19</u>	125.0	40.00	6.88	81		0.30	LTD	LTD	16.00	11	LTD	LTD	5	29
Charlottetown (Labrador)																		
Charlottetown (Labrador)	Middle Pond	Aug 08, 2019	8.00	<u>52</u>	34.0	2.00	7.22	22		0.60	LTD	LTD	1.00	5	LTD	LTD	LTD	LTD
Charlottetown (Labrador) - PWDU	Middle Pond	Aug 08, 2019	8.00	LTD	19.0	LTD	7.76	12		0.10	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
Churchill Falls																		
Churchill Falls	Smallwood Reservoir	Aug 29, 2019	12.00	9	37.0	7.00	7.72	24		1.40	LTD	LTD	3.00	3	LTD	LTD	LTD	LTD
Clarenville																		
Clarenville, Shoal Harbour	Shoal Harbour River	Aug 14, 2019	13.00	3	91.0	12.00	7.38	59		0.20	LTD	LTD	5.00	10	LTD	LTD	12	10
Clarke's Beach																		
Clarke's Beach	Clarke's Pond	Aug 27, 2019	6.00	4	48.0	5.00	7.13	31		0.30	LTD	LTD	2.00	9	LTD	LTD	4	1
Come By Chance																		
Come By Chance	Butchers Brook	Aug 21, 2019	25.00	LTD	89.0	18.00	7.58	58		0.30	LTD	LTD	7.00	12	LTD	LTD	9	LTD
Conception Bay South																		
Conception Bay South	Bay Bulls Big Pond	Aug 15, 2019	20.00	10	93.0	22.00	7.62	60		0.10	LTD	LTD	9.00	15	LTD	LTD	7	1
Conche																		
Conche	Martin's Brook	Aug 19, 2019	8.00	<u>111</u>	43.0	10.00	7.35	28		0.70	LTD	LTD	4.00	10	LTD	LTD	4	LTD
Conne River																		
Conne River	Southwest Brook	Sep 24, 2019	LTD	2	17.0	LTD	6.67	11		0.10	LTD	LTD	LTD	3	LTD	LTD	3	LTD
Cook's Harbour																		
Cook's Harbour	Unnamed Pond	Sep 16, 2019	83.00	7	348.0	119.00	8.11	226		0.90	LTD	LTD	41.00	52	LTD	LTD	23	4
Corner Brook																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	C	C	A	C	A	C	A	C	A	C	A	C	A
Aesthetic (A) or Contaminant (C) Parameter																		
Corner Brook																		
Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Sep 25, 2019	18.00	LTD	87.0	22.00	7.23	57		0.20	LTD	LTD	7.00	13	LTD	LTD	9	3
Cottrell's Cove																		
Cottrell's Cove	Cottrell's Pond	Aug 20, 2019	47.00	9	139.0	48.00	7.69	90		0.50	0.03	LTD	16.00	13	LTD	LTD	9	1
Cow Head																		
Cow Head	Short Cat Path Pond	Sep 30, 2019	16.00	10	117.0	33.00	6.74	76		2.60	LTD	LTD	10.00	24	LTD	LTD	9	2
Cow Head - PWDU	Short Cat Path Pond	Sep 30, 2019	LTD	LTD	8.0	LTD	6.17	5		0.20	LTD	LTD	LTD	4	LTD	LTD	LTD	LTD
Cox's Cove																		
Cox's Cove	Cox's Brook	Sep 25, 2019	16.00	26	70.0	26.00	7.15	46		0.40	LTD	LTD	7.00	9	LTD	LTD	5	2
Crow Head																		
Crow Head	Oars Pond	Aug 22, 2019	16.00	9	267.0	34.00	7.00	174		0.60	0.02	LTD	7.00	64	LTD	LTD	35	5
Cupids																		
Cupids	Brigus Long Pond (to Brigus)	Aug 27, 2019	LTD	8	59.0	5.00	6.50	38		0.30	LTD	LTD	2.00	13	LTD	LTD	7	2
Daniel's Harbour																		
Daniel's Harbour	Unnamed Spring & Brook	Sep 30, 2019	180.00	5	565.0	203.00	7.96	367		0.50	0.01	LTD	50.00	72	LTD	1.000	35	6
Deadman's Bay																		
Deadman's Bay	Deadman's Pond	Aug 20, 2019	6.00	19	41.0	LTD	7.15	27		0.80	LTD	LTD	LTD	10	LTD	LTD	4	LTD
Deep Bight																		
Deep Bight	Deep Bight River	Aug 26, 2019	16.00	5	98.0	18.00	7.35	64		0.50	LTD	LTD	7.00	19	LTD	LTD	7	LTD
Deep Bight	Deep Bight River	Aug 26, 2019	15.00	16	90.0	18.00	7.31	58		0.40	LTD	LTD	7.00	18	LTD	LTD	7	LTD
Deep Bight	Deep Bight River	Aug 26, 2019	13.00	5	157.0	18.00	7.11	102		0.30	LTD	LTD	7.00	41	LTD	LTD	18	LTD
Deep Bight	Deep Bight River	Aug 26, 2019	20.00	18	89.0	18.00	7.39	58		0.30	LTD	LTD	7.00	15	LTD	LTD	5	LTD
Deer Lake																		
Deer Lake (+Reidville)	Humber Canal, Grand Lake	Sep 05, 2019	10.00	21	42.0	10.00	7.16	27		0.30	LTD	LTD	4.00	5	LTD	LTD	2	1

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	5.0	1.0	5.0	250	1.5	200	500			
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	C	A	C	A	A	A	A
Dildo																		
Dildo, Broad Cove (+South Dildo)	Broad Cove Pond	Sep 12, 2019	LTD	7	48.0	2.00	<u>5.71</u>	31		0.50	LTD	LTD	1.00	12	LTD	LTD	4	1
Dover																		
Dover	Hare Bay Pond	Aug 13, 2019	LTD	<u>41</u>	43.0	LTD	6.65	28		0.60	LTD	LTD	LTD	9	LTD	LTD	5	LTD
Eddies Cove West																		
Eddies Cove West	Unnamed	Sep 18, 2019	123.00	<u>74</u>	276.0	135.00	<u>8.57</u>	179		1.90	LTD	LTD	36.00	13	LTD	LTD	8	1
Elliston																		
Elliston	Big Pond	Aug 13, 2019	LTD	2	102.0	9.00	<u>6.45</u>	66		0.60	LTD	LTD	2.00	25	LTD	LTD	15	3
Embree																		
Embree (+Little Burnt Bay)	Troke's Cove Pond	Aug 06, 2019	6.00	5	79.0	12.00	7.05	51		0.80	LTD	LTD	5.00	17	LTD	LTD	8	2
Englee																		
Englee	Island Cove Pond	Aug 19, 2019	12.00	<u>58</u>	58.0	7.00	7.53	38		1.50	LTD	LTD	3.00	11	LTD	LTD	3	LTD
Fairbanks-Hillgrade																		
Fairbanks-Hillgrade	Saltine's Pond	Sep 18, 2019	14.00	<u>22</u>	91.0	21.00	7.12	59		0.30	0.01	LTD	5.00	17	LTD	LTD	10	LTD
Fermeuse																		
Fermeuse, Kingman's	Merrymeeting Pond, Bear Cove Pond (2 intakes)	Aug 21, 2019	14.00	3	83.0	7.00	7.73	54		0.40	LTD	LTD	3.00	15	LTD	LTD	10	2
Ferryland																		
Ferryland	Deep Cove Pond	Aug 21, 2019	11.00	<u>21</u>	89.0	5.00	7.55	58		0.60	LTD	LTD	2.00	19	LTD	LTD	11	2
Fleur de Lys																		
Fleur De Lys	First Pond, Narrow Pond	Sep 27, 2019	10.00	<u>32</u>	96.0	17.00	6.79	62		0.70	LTD	LTD	5.00	18	LTD	LTD	11	3
Flower's Cove																		
Flower's Cove (+Nameless Cove)	French Island Pond	Sep 17, 2019	98.00	<u>16</u>	226.0	113.00	8.27	147		0.50	LTD	LTD	24.00	11	LTD	LTD	6	1
Fogo Island																		
Joe Batt's Arm-Barr'd Islands-Shoal Bay	Long Pond	Sep 30, 2019	LTD	5	104.0	11.00	<u>4.68</u>	68		0.30	0.01	LTD	1.00	26	LTD	LTD	12	3
Seldom-Little Seldom	Bullock Cove Pond	Sep 30, 2019	LTD	<u>18</u>	103.0	12.00	<u>5.71</u>	67		0.70	0.01	LTD	3.00	26	LTD	LTD	13	1

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	A	C	C	A	C	A	A						
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	A						
Fogo Island																		
Tilting	Sandy Cove Pond	Sep 30, 2019	LTD	8	96.0	7.00	<u>6.38</u>	62		0.90	0.01	LTD	1.00	23	LTD	LTD	14	1
Forrester's Point																		
Forrester's Point	Rudges Pond	Sep 17, 2019	104.00	<u>17</u>	314.0	118.00	<u>8.52</u>	204		1.00	LTD	LTD	26.00	32	LTD	LTD	21	3
Forteau																		
Forteau	Trout Brook	Aug 07, 2019	139.00	3	271.0	139.00	8.48	176		0.50	LTD	LTD	41.00	5	LTD	LTD	4	2
Fortune																		
Fortune (+Grand Bank)	Horsebrook	Aug 27, 2019	LTD	<u>21</u>	51.0	2.00	<u>6.30</u>	33		0.60	LTD	LTD	1.00	15	LTD	LTD	7	2
Fox Roost-Margaree																		
Fox Roost-Margaree	Drilled Well and Margaree Pond	Sep 10, 2019	LTD	<u>236</u>	55.0	LTD	<u>5.89</u>	36		1.10	LTD	LTD	LTD	12	LTD	LTD	8	2
Fox Roost-Margaree - PWDU	Drilled Well and Margaree Pond	Sep 10, 2019	5.00	7	16.0	LTD	6.92	10		LTD	LTD	LTD	LTD	1	LTD	LTD	LTD	LTD
Francois																		
Francois	Our Pond	Aug 20, 2019	LTD	<u>70</u>	31.0	LTD	6.70	20		0.70	LTD	LTD	LTD	8	LTD	LTD	3	1
Gallants																		
Gallants	Gallant's Brook	Sep 26, 2019	155.00	2	323.0	167.00	8.02	210		0.30	LTD	LTD	47.00	8	LTD	LTD	4	2
Gambo																		
Gambo	Dark Cove Pond	Aug 13, 2019	12.00	8	94.0	7.00	7.58	61		0.70	LTD	LTD	3.00	19	LTD	LTD	15	1
Gander																		
Gander	Gander Lake	Jul 24, 2019	29.00	12	80.0	2.00	7.37	52		0.70	LTD	LTD	1.00	LTD	LTD	LTD	12	LTD
Gander	Gander Lake	Aug 12, 2019	30.00	10	80.0	2.00	7.67	52		0.30	LTD	LTD	1.00	6	LTD	LTD	14	LTD
Gander Bay South																		
George's Point, Harris Point	Barry's Brook	Aug 14, 2019	12.00	<u>22</u>	52.0	16.00	7.22	34		0.40	LTD	LTD	3.00	7	LTD	LTD	4	LTD
Gander Bay South - PWDU	Barry's Brook	Aug 14, 2019	LTD	LTD	6.0	LTD	6.56	4		0.10	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
Garden Cove																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate		
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	
			Units			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Guidelines for Canadian Drinking Water Quality			Aesthetic (A) or Contaminant (C) Parameter	A			A	A	C	C			A	C		A	A
Garden Cove																				
Garden Cove	Arch Cove Pond	Sep 05, 2019	8.00	<u>47</u>	52.0	2.00	7.07	34		0.40	LTD	LTD	1.00	9	LTD	LTD	7	LTD		
Garnish																				
Garnish	Witchazel Pond	Aug 28, 2019	LTD	14	81.0	12.00	<u>5.59</u>	53		0.50	LTD	LTD	3.00	19	LTD	LTD	8	2		
Gaskiers																				
Gaskiers-Point La Haye	Big Hare Hill Pond	Aug 19, 2019	14.00	<u>24</u>	96.0	13.00	7.87	62		0.70	LTD	LTD	2.00	17	LTD	LTD	10	2		
Gaultois																				
Gaultois	Piccaire Pond	Sep 23, 2019	LTD	<u>249</u>	45.0	LTD	<u>5.24</u>	29		0.70	LTD	LTD	LTD	9	LTD	LTD	6	2		
Gaultois - PWDU	Piccaire Pond	Sep 23, 2019	LTD	8	82.0	18.00	<u>5.99</u>	53		0.30	LTD	LTD	4.00	9	LTD	LTD	6	3		
George's Brook-Milton																				
George's Brook-Milton	George's Brook	Sep 04, 2019	9.00	<u>20</u>	61.0	7.00	7.00	40		0.60	LTD	LTD	3.00	10	LTD	LTD	9	1		
Georgetown																				
Georgetown	Third Pond	Sep 05, 2019	5.00	2	85.0	5.00	6.76	55		0.40	LTD	LTD	2.00	19	LTD	LTD	13	2		
Gillams																				
Gillams	Meaters Pond	Sep 25, 2019	12.00	13	66.0	19.00	7.12	43		0.40	LTD	LTD	6.00	10	LTD	LTD	5	2		
Glenburnie-Birchy Head-Shoal Brook																				
Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Sep 27, 2019	13.00	<u>109</u>	60.0	18.00	7.20	39		0.80	LTD	LTD	4.00	8	LTD	LTD	5	1		
Glenwood																				
Glenwood	Gander Lake (The Outflow)	Aug 12, 2019	LTD	<u>25</u>	31.0	5.00	<u>5.16</u>	20		0.80	LTD	LTD	2.00	7	LTD	LTD	LTD	1		
Glovertown																				
Glovertown	Northwest Pond	Aug 19, 2019	7.00	<u>32</u>	45.0	5.00	7.14	29		0.80	LTD	LTD	2.00	11	LTD	LTD	5	LTD		
Goobies																				
Goobies	Water Pond	Sep 09, 2019	7.00	<u>22</u>	40.0	2.00	7.06	26		0.50	LTD	LTD	1.00	7	LTD	LTD	5	LTD		
Goose Cove East																				
Goose Cove East	Jack's Pond	Aug 20, 2019	36.00	<u>46</u>	112.0	24.00	8.16	73		0.50	LTD	LTD	8.00	15	LTD	LTD	10	1		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C			A	C		A	A
Aesthetic (A) or Contaminant (C) Parameter																		
Grand Bank																		
Grand Bank	Horsebrook	Aug 27, 2019	LTD	15	57.0	5.00	<u>5.76</u>	37		0.50	LTD	LTD	2.00	14	LTD	LTD	6	2
Grand Falls-Windsor																		
Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Aug 15, 2019	8.00	LTD	64.0	22.00	7.50	42		2.40	LTD	LTD	9.00	4	LTD	LTD	LTD	12
Grand Le Pierre																		
Grand Le Pierre	Nip Nose Pond	Sep 04, 2019	8.00	<u>169</u>	28.0	2.00	6.91	18		0.80	LTD	LTD	1.00	2	LTD	LTD	2	LTD
Great Brehat																		
Great Brehat	Little Steady Pond	Sep 16, 2019	12.00	<u>87</u>	87.0	17.00	7.15	57		1.10	LTD	LTD	5.00	14	LTD	LTD	10	3
Green Island Brook																		
Green Island Brook	Green Island Brook	Sep 17, 2019	94.00	<u>17</u>	196.0	98.00	8.37	127		0.50	LTD	LTD	21.00	8	LTD	LTD	5	LTD
Greenspond																		
Greenspond	Shambler's Cove Pond	Aug 13, 2019	LTD	<u>43</u>	95.0	2.00	<u>4.97</u>	62		0.60	LTD	LTD	1.00	23	LTD	LTD	12	4
Hampden																		
Hampden	Elliot Brook	Aug 13, 2019	33.00	<u>16</u>	95.0	34.00	7.79	62		0.60	LTD	LTD	12.00	7	LTD	LTD	3	1
Hant's Harbour																		
Hant's Harbour	Eastern Pond (Halfway Brook)	Sep 17, 2019	LTD	5	48.0	2.00	6.70	31		1.50	LTD	LTD	1.00	11	LTD	LTD	5	2
Happy Adventure																		
Happy Adventure	Goose Neck Pond	Aug 19, 2019	6.00	<u>40</u>	34.0	5.00	7.01	22		0.60	LTD	LTD	2.00	8	LTD	LTD	3	LTD
Happy Valley-Goose Bay																		
Happy Valley-Goose Bay	Spring Gulch	Jul 30, 2019	12.00	LTD	38.0	12.00	7.14	25		0.90	LTD	LTD	3.00	2	0.450	1.000	LTD	LTD
Happy Valley-Goose Bay	Well Field (connect summer 2002)	Jul 30, 2019	48.00	LTD	374.0	71.00	7.38	243		0.60	0.02	LTD	12.00	78	LTD	4.000	42	9
Harbour Breton																		
Harbour Breton	Connaigra Pond, Hutchings Pond	Sep 24, 2019	13.00	<u>16</u>	99.0	28.00	6.73	64		0.30	0.01	LTD	8.00	19	LTD	LTD	8	2
Harbour Grace																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality																		
Aesthetic (A) or Contaminant (C) Parameter				A			A	A		C	C			A	C		A	A
Harbour Grace																		
Harbour Grace, Harbour Grace South (+Riverhead)	Bannerman Lake	Aug 26, 2019	LTD	LTD	44.0	5.00	6.80	29		0.50	LTD	LTD	2.00	9	LTD	LTD	4	2
Harbour Main-Chapel's Cove-Lakeview																		
Harbour Main, Chapel's Cove, Lakeview	Maloney's River	Sep 05, 2019	23.00	LTD	132.0	18.00	7.76	86		0.30	LTD	LTD	7.00	24	LTD	LTD	17	2
Harbour Mille-Little Harbour East																		
Harbour Mille, Little Harbour East (Fortune Bay)	Head Pond	Sep 05, 2019	LTD	<u>258</u>	110.0	8.00	<u>5.13</u>	72		1.00	0.01	LTD	LTD	26	LTD	LTD	16	3
Hare Bay																		
Hare Bay (+Dover)	Hare Bay Pond	Aug 13, 2019	LTD	<u>40</u>	38.0	LTD	<u>5.98</u>	25		0.50	LTD	LTD	LTD	9	LTD	LTD	5	LTD
Hawke's Bay																		
Hawke's Bay	Torrent River	Sep 18, 2019	15.00	<u>16</u>	67.0	23.00	7.54	44		0.30	LTD	LTD	6.00	10	LTD	LTD	3	2
Heart's Content																		
Heart's Content	Southern Cove Pond	Sep 12, 2019	LTD	8	49.0	LTD	6.81	32		0.50	LTD	LTD	LTD	12	LTD	LTD	7	1
Heart's Delight-Islington																		
Heart's Delight-Islington	Long Pond	Sep 12, 2019	10.00	LTD	99.0	2.00	7.23	64		0.10	LTD	LTD	1.00	21	LTD	LTD	16	3
Heart's Desire																		
Heart's Desire	Terrence Pond	Sep 12, 2019	LTD	3	65.0	5.00	6.51	42		0.20	LTD	LTD	2.00	16	LTD	LTD	8	2
Herring Neck																		
Herring Neck, Hatchet Harbour, Salt Harbour, Shoal Cove, Sunnyside	Gut Pond	Sep 16, 2019	25.00	6	261.0	44.00	7.35	170		0.40	0.02	LTD	11.00	60	LTD	LTD	34	5
Hickman's Harbour-Robinson Bight																		
Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Sep 04, 2019	9.00	9	48.0	7.00	7.07	31		0.40	LTD	LTD	3.00	7	LTD	LTD	5	2
Hopedale																		
Hopedale	American Pond	Aug 13, 2019	LTD	<u>24</u>	35.0	7.00	6.50	23		0.60	LTD	LTD	3.00	7	LTD	LTD	3	LTD
Howley																		
Howley	Sandy Lake	Sep 04, 2019	5.00	<u>48</u>	35.0	5.00	6.65	23		0.70	LTD	LTD	2.00	6	LTD	LTD	5	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	A						
Howley																		
Howley - PWDU	Sandy Lake	Sep 04, 2019	8.00	LTD	17.0	LTD	7.18	11		0.10	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
Hughes Brook																		
Hughes Brook	Reservoir	Sep 20, 2019	168.00	6	327.0	186.00	8.19	213	1.20	LTD	LTD	40.00	9	LTD	LTD	LTD	5	3
Humber Arm South																		
Halfway Point, Benoit's Cove, John's Beach	Dormody's Brook	Sep 24, 2019	48.00	2	120.0	56.00	7.80	78		0.20	LTD	LTD	1.00	9	LTD	LTD	5	LTD
Frenchman's Cove Area	Gurges Pond	Sep 24, 2019	17.00	3	100.0	23.00	7.35	65		1.00	LTD	LTD	6.00	16	LTD	LTD	10	4
Indian Bay																		
Indian Bay	Indian Bay Brook	Aug 13, 2019	LTD	8	46.0	2.00	6.77	30		0.50	LTD	LTD	1.00	9	LTD	LTD	6	LTD
Irishtown-Summerside																		
Irishtown	Irishtown Brook	Sep 26, 2019	24.00	<u>49</u>	74.0	28.00	7.41	48		0.40	LTD	LTD	8.00	7	LTD	LTD	4	1
Summerside	Pynn's Pond	Sep 26, 2019	7.00	<u>43</u>	46.0	7.00	6.88	30		0.40	LTD	LTD	3.00	8	LTD	LTD	4	1
Isle aux Morts																		
Isle aux Morts - PWDU	Burnt Ground Pond	Sep 11, 2019	11.00	2	43.0	LTD	7.65	28		0.10	LTD	LTD	LTD	6	LTD	LTD	LTD	LTD
Jackson's Arm																		
Jackson's Arm	Unnamed Brook	Sep 25, 2019	LTD	13	38.0	7.00	<u>5.95</u>	25		0.40	LTD	LTD	3.00	9	LTD	LTD	2	1
Jackson's Arm - PWDU	Unnamed Brook	Sep 25, 2019	LTD	LTD	LTD	LTD	<u>6.28</u>	LTD		0.10	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
Jackson's Cove-Langdon's Cove-Silverdale																		
Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Sep 25, 2019	13.00	10	106.0	19.00	7.02	69		0.30	LTD	LTD	6.00	20	LTD	LTD	12	3
Keels																		
Keels	Boland's Pond	Aug 13, 2019	7.00	<u>23</u>	198.0	4.00	6.63	129		0.80	LTD	LTD	LTD	49	LTD	LTD	36	1
King's Point																		
King's Point	Bulley's Pond	Sep 25, 2019	LTD	<u>26</u>	22.0	5.00	<u>5.48</u>	14		0.40	LTD	LTD	2.00	4	LTD	LTD	LTD	LTD
L'Anse au Clair																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500	Aesthetic (A) or Contaminant (C) Parameter					
				A	A	C	C	A	C	A	A							
L'Anse au Clair																		
L'Anse au Clair	Park Pond	Aug 07, 2019	103.00	LTD	213.0	100.00	8.33	138		0.40	LTD	LTD	30.00	6	LTD	LTD	4	1
L'Anse au Loup																		
L'Anse au Loup	L'anse Au Loup River	Aug 08, 2019	16.00	<u>24</u>	51.0	7.00	8.10	33		0.50	LTD	LTD	3.00	4	LTD	LTD	3	LTD
La Poile																		
La Poile	Black Duck Pond	Sep 16, 2019	10.00	<u>248</u>	42.0	2.00	6.75	27		0.60	LTD	LTD	1.00	7	LTD	LTD	5	2
LaScie																		
La Scie	Stakes Pond	Aug 14, 2019	LTD	<u>53</u>	58.0	5.00	6.80	38		0.60	LTD	LTD	2.00	13	LTD	LTD	7	2
Labrador City																		
Labrador City	Beverly Lake	Jul 18, 2019	46.00	5	88.0	41.00	7.85	57		0.30	LTD	LTD	10.00	4	LTD	LTD	LTD	2
Lamaline																		
Lamaline	Upper Hodges Pond	Aug 27, 2019	12.00	<u>49</u>	63.0	10.00	7.41	41		0.50	LTD	LTD	4.00	12	LTD	LTD	6	3
Lamaline - PWDU	Upper Hodges Pond	Aug 27, 2019	LTD	2	10.0	LTD	7.05	6		0.30	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
Lark Harbour																		
Lark Harbour	Fairfax Brook	Sep 24, 2019	16.00	<u>32</u>	119.0	29.00	7.32	77		0.60	0.01	LTD	5.00	21	LTD	LTD	12	3
Lawn																		
Lawn	Brazil Pond	Aug 27, 2019	8.00	LTD	49.0	5.00	7.17	32		0.70	LTD	LTD	2.00	11	LTD	LTD	5	1
Lawn - PWDU	Brazil Pond	Aug 27, 2019	LTD	LTD	26.0	LTD	7.13	17		0.20	LTD	LTD	LTD	5	LTD	LTD	3	LTD
Leading Ticksles																		
Leading Ticksles	Cook's Pond	Aug 20, 2019	14.00	<u>44</u>	77.0	12.00	7.16	50		0.50	LTD	LTD	3.00	12	LTD	LTD	8	1
Leading Ticksles - PWDU	Cook's Pond	Aug 20, 2019	6.00	4	16.0	LTD	6.90	10		0.40	LTD	LTD	LTD	1	LTD	LTD	LTD	LTD
Lewin's Cove																		
Lewin's Cove	Big Pond	Aug 28, 2019	LTD	<u>19</u>	64.0	7.00	6.83	42		0.30	LTD	LTD	3.00	14	LTD	LTD	6	2
Lewisporte																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	5.0	250	1.5	200	500					
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	C	A	A	A	A	A	A
Lewisporte																		
Lewisporte	Stanhope Pond	Aug 06, 2019	14.00	14	63.0	12.00	7.57	41		0.80	LTD	LTD	5.00	9	LTD	LTD	4	LTD
Little Burnt Bay																		
Little Burnt Bay	Troke's Cove Pond	Aug 06, 2019	7.00	2	86.0	12.00	7.17	56		0.50	LTD	LTD	5.00	18	LTD	LTD	10	2
Little Harbour East																		
Little Harbour East (Placentia Bay)	Unnamed Pond	Aug 21, 2019	15.00	<u>29</u>	68.0	14.00	7.54	44		0.30	LTD	LTD	4.00	12	LTD	LTD	6	2
Long Harbour-Mount Arlington Heights																		
Long Harbour-Mount Arlington Heights	Shingle Pond and/or Trout Pond (2 Intakes)	Sep 16, 2019	7.00	2	99.0	5.00	7.20	64		0.10	LTD	LTD	2.00	21	LTD	LTD	14	3
Loon Bay																		
Loon Bay	Southeast Pond	Sep 18, 2019	22.00	5	74.0	22.00	6.92	48		0.20	LTD	LTD	7.00	8	LTD	LTD	6	LTD
Lourdes																		
Lourdes (+West Bay)	Victor's Brook	Sep 24, 2019	127.00	5	374.0	164.00	8.08	243		0.30	0.03	LTD	51.00	38	LTD	LTD	16	9
Lower Lance Cove																		
Lower Lance Cove	Big Long Pond	Sep 04, 2019	LTD	4	77.0	5.00	<u>4.47</u>	50		0.30	LTD	LTD	2.00	8	LTD	LTD	6	13
Lumsden																		
Lumsden	Gull Pond	Aug 20, 2019	26.00	2	194.0	LTD	7.49	126		0.80	LTD	LTD	LTD	14	LTD	LTD	35	40
Main Brook																		
Main Brook	Joe Burt's Pond	Aug 19, 2019	45.00	<u>17</u>	99.0	45.00	8.11	64		0.90	LTD	LTD	13.00	4	LTD	LTD	3	LTD
Mainland																		
Mainland	Caribou Brook	Sep 24, 2019	174.00	3	414.0	203.00	<u>8.62</u>	269		0.40	0.02	LTD	63.00	22	LTD	LTD	14	10
Makkovik																		
Makkovik	Ranger Bight Pond	Aug 14, 2019	LTD	<u>53</u>	26.0	5.00	6.67	17		0.90	LTD	LTD	2.00	4	0.130	LTD	2	LTD
Makkovik - PWDU	Ranger Bight Pond	Aug 14, 2019	7.00	10	23.0	LTD	7.44	15		0.20	LTD	LTD	LTD	2	LTD	LTD	LTD	LTD
Mary's Harbour																		
Mary's Harbour	St. Mary's River	Aug 07, 2019	9.00	<u>43</u>	41.0	LTD	7.78	27		0.40	LTD	LTD	LTD	5	LTD	LTD	4	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	C	A	C	A	C	A	C	A	C	
Mary's Harbour																		
Mary's Harbour - PWDU	St. Mary's River	Aug 07, 2019	7.00	LTD	20.0	LTD	7.82	13		0.10	LTD	LTD	LTD	1	LTD	LTD	LTD	LTD
Marystown																		
Marystown	Fox Hill Reservoir / Clam Pond	Aug 28, 2019	13.00	LTD	108.0	7.00	7.71	70		LTD	LTD	LTD	3.00	20	LTD	LTD	15	3
Massey Drive																		
Massey Drive	Trout Pond, Third Pond (2 intakes)	Sep 25, 2019	18.00	LTD	88.0	22.00	7.26	57		0.30	LTD	LTD	7.00	13	LTD	LTD	9	3
McCallum																		
McCallum	Drilled	Aug 14, 2019	26.00	<u>271</u>	250.0	24.00	6.70	162		0.90	LTD	LTD	8.00	58	LTD	LTD	40	3
Mclvers																		
Mclvers	Mclvers Brook	Sep 26, 2019	43.00	<u>18</u>	136.0	48.00	7.66	88		0.60	LTD	LTD	16.00	13	LTD	LTD	10	3
Meadows																		
Meadows, Summerside West	Meaters Pond	Sep 26, 2019	11.00	9	70.0	19.00	7.04	46		0.50	LTD	LTD	6.00	12	LTD	LTD	5	2
Millertown																		
Millertown	Water Pond	Sep 23, 2019	10.00	10	46.0	10.00	6.70	30		0.30	LTD	LTD	4.00	7	LTD	LTD	5	LTD
Ming's Bight																		
Ming's Bight	Middle Brook Pond	Sep 27, 2019	12.00	8	64.0	22.00	6.87	42		0.30	LTD	LTD	7.00	9	LTD	LTD	4	2
Mount Moriah																		
Mount Moriah	Trout Pond, Third Pond (2 intakes)	Sep 25, 2019	18.00	LTD	88.0	22.00	7.30	57		0.30	LTD	LTD	7.00	13	LTD	LTD	9	3
Mount Pearl																		
Mount Pearl	Bay Bulls Big Pond	Aug 15, 2019	20.00	3	93.0	22.00	7.59	60		0.10	LTD	LTD	9.00	15	LTD	LTD	7	1
Musgrave Harbour																		
Musgrave Harbour	Rocky Pond	Aug 20, 2019	12.00	LTD	114.0	2.00	7.19	74		0.30	LTD	LTD	1.00	23	LTD	LTD	17	3
Nain																		
Nain	Trouser Lake	Aug 14, 2019	11.00	14	38.0	5.00	7.77	25		0.70	LTD	LTD	2.00	3	LTD	LTD	LTD	2
Nameless Cove																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				Units														
				Guidelines for Canadian Drinking Water Quality	15		6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
				Aesthetic (A) or Contaminant (C) Parameter	A		A	A		C	C			A	C		A	A
Nameless Cove																		
Nameless Cove / Flower Cove	French Island Pond	Sep 17, 2019	97.00	14	226.0	113.00	8.26	147		0.50	LTD	LTD	24.00	11	LTD	LTD	6	1
Natuashish																		
Natuashish (Sango Bay)	Sango Brook and Wellfield	Aug 13, 2019	80.00	10	1,320.0	121.00	8.07	<u>858</u>		0.60	0.26	0.83	17.00	<u>337</u>	<u>2.580</u>	12.000	198	54
New Chelsea-New Melbourne-Brownsdale-Sibley's Cove-I																		
Sibley's Cove, Lead Cove	Sibley's Cove Pond	Sep 17, 2019	6.00	4	56.0	2.00	7.19	36		<u>1.10</u>	LTD	LTD	1.00	11	LTD	LTD	6	2
New Perican																		
New Perican	New Perican River	Sep 17, 2019	12.00	12	59.0	5.00	7.62	38		0.40	LTD	LTD	2.00	8	LTD	LTD	5	1
New-Wes-Valley																		
Newtown-Templeton	Carter's Pond	Sep 11, 2019	29.00	<u>80</u>	171.0	LTD	6.97	111		<u>1.90</u>	LTD	LTD	LTD	34	LTD	LTD	32	1
Newtown-Templeton	Carter's Pond	Sep 11, 2019	38.00	<u>33</u>	203.0	LTD	7.21	132		<u>2.40</u>	LTD	LTD	LTD	41	LTD	LTD	38	1
Newtown-Templeton	Carter's Pond	Sep 11, 2019	33.00	<u>17</u>	214.0	LTD	6.97	139		<u>1.60</u>	LTD	LTD	LTD	47	LTD	LTD	42	1
Newtown-Templeton	Carter's Pond	Sep 11, 2019	30.00	<u>18</u>	204.0	LTD	6.88	133		<u>1.50</u>	LTD	LTD	LTD	45	LTD	LTD	41	1
Newtown-Templeton	Carter's Pond	Sep 11, 2019	31.00	<u>31</u>	199.0	LTD	6.97	129		<u>1.60</u>	LTD	LTD	LTD	41	LTD	LTD	38	1
Newtown-Templeton	Carter's Pond	Sep 11, 2019	40.00	<u>28</u>	209.0	LTD	7.29	136		<u>1.70</u>	0.01	LTD	LTD	40	LTD	LTD	38	1
Wesleyville-Badger's Quay-Pool's Island, Brookfield-Poundcove	Little Northwest Pond	Aug 13, 2019	26.00	<u>34</u>	114.0	LTD	7.72	74		0.50	LTD	LTD	LTD	18	LTD	LTD	21	LTD
Newman's Cove																		
Newman's Cove	Heale Pond Brook	Aug 13, 2019	9.00	<u>61</u>	79.0	7.00	6.81	51		0.50	LTD	LTD	1.00	16	LTD	LTD	9	1
Newman's Cove	Heale Pond Brook	Sep 03, 2019	LTD	<u>43</u>	74.0	7.00	<u>6.37</u>	48		0.50	LTD	LTD	1.00	16	LTD	LTD	11	1
Nippers Harbour																		
Nippers Harbour	Blackhead Pond Brook	Sep 27, 2019	LTD	<u>59</u>	27.0	5.00	<u>6.41</u>	18		0.40	LTD	LTD	2.00	4	LTD	LTD	2	LTD
Norman's Cove-Long Cove																		
Norman's Cove-Long Cove	John Newhooks Pond	Sep 16, 2019	13.00	10	76.0	18.00	8.37	49		0.70	LTD	LTD	7.00	12	LTD	LTD	7	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality																		
Aesthetic (A) or Contaminant (C) Parameter				A			A	A		C	C			A	C		A	A
Norris Point																		
Norris Point	Neddy Harbour Pond	Sep 20, 2019	117.00	4	260.0	145.00	8.04	169		0.30	LTD	LTD	30.00	14	LTD	LTD	6	2
North Harbour																		
North Harbour	Grandfather's Pond	Sep 05, 2019	LTD	<u>69</u>	46.0	LTD	6.52	30		0.80	LTD	LTD	LTD	10	LTD	LTD	7	2
North West River																		
North West River	Wellfield (#1 & #3 Well) + #2 Well	Jul 30, 2019	73.00	5	198.0	93.00	7.97	129		0.20	0.03	LTD	29.00	1	0.490	4.000	3	23
Northern Arm																		
Northern Arm	Northern Arm Lake	Aug 15, 2019	12.00	LTD	69.0	22.00	7.96	45		0.30	LTD	LTD	9.00	4	LTD	LTD	LTD	12
Old Perican																		
Old Perican	Bell Pond	Sep 17, 2019	LTD	LTD	84.0	2.00	<u>5.61</u>	55		0.40	LTD	LTD	1.00	21	LTD	LTD	11	2
Pacquet																		
Pacquet	Big Brook	Aug 14, 2019	LTD	<u>121</u>	36.0	LTD	<u>6.35</u>	23		0.50	LTD	LTD	LTD	7	LTD	LTD	5	LTD
Pacquet - PWDU	Big Brook	Aug 14, 2019	LTD	<u>22</u>	6.0	LTD	<u>6.25</u>	4		0.30	LTD	LTD	LTD	1	LTD	LTD	LTD	LTD
Paradise																		
Paradise	Bay Bulls Big Pond	Aug 15, 2019	22.00	6	97.0	25.00	7.74	63		0.10	LTD	LTD	10.00	15	LTD	LTD	7	1
Parkers Cove																		
Parkers Cove	Unnamed brook	Aug 29, 2019	LTD	<u>46</u>	74.0	LTD	7.07	48		0.50	LTD	LTD	LTD	16	LTD	LTD	12	LTD
Parson's Pond																		
Parson's Pond	Cold Brook	Sep 27, 2019	240.00	7	718.0	277.00	7.86	467		0.20	0.03	LTD	88.00	80	LTD	2.000	40	10
Pasadena																		
Pasadena	Blue Gulch Pond	Sep 20, 2019	13.00	5	59.0	18.00	6.99	38		0.30	LTD	LTD	7.00	8	LTD	LTD	3	1
Peterview																		
Peterview	Northern Arm Lake	Aug 15, 2019	9.00	LTD	64.0	22.00	7.74	42		0.30	LTD	LTD	9.00	4	LTD	LTD	LTD	11
Petit Forte																		
Petit Forte	Reddy's Pond	Aug 29, 2019	10.00	<u>46</u>	66.0	LTD	7.66	43		0.30	LTD	LTD	LTD	12	LTD	LTD	7	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				Units															
				mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500							
				Aesthetic (A) or Contaminant (C) Parameter	A	A	C	C	A	C	A	A							
Petty Harbour-Maddox Cove																			
Petty Harbour-Maddox Cove	Western Barrens Pond	Aug 13, 2019	12.00	6	61.0	LTD	7.45	40		0.60	LTD	LTD	LTD	10	LTD	LTD	9	1	
Piccadilly Head																			
Piccadilly Head (+West Bay)	Unnamed Brook	Sep 26, 2019	78.00	<u>109</u>	266.0	115.00	7.88	173		4.50	0.01	LTD	38.00	29	LTD	LTD	10	6	
Pidgeon Cove-St. Barbe																			
Pigeon Cove - St. Barbe	Long Pond	Sep 17, 2019	83.00	<u>19</u>	219.0	97.00	8.41	142		0.80	LTD	LTD	19.00	16	LTD	LTD	10	1	
Placentia																			
Dunville	Wyses Pond	Sep 16, 2019	13.00	12	103.0	7.00	7.82	67		0.50	LTD	LTD	3.00	19	LTD	LTD	8	2	
Placentia, Jersey side, SE Placentia	Larkins Pond	Sep 11, 2019	11.00	10	132.0	22.00	7.14	86		0.60	LTD	LTD	7.00	30	LTD	LTD	15	3	
Freshwater, Argentinia site	Clarkes Pond	Sep 11, 2019	11.00	8	116.0	18.00	7.08	75		0.70	LTD	LTD	7.00	25	LTD	LTD	12	3	
Plum Point																			
Plum Point	Grand Pond	Sep 17, 2019	86.00	<u>19</u>	256.0	98.00	8.29	166		0.70	LTD	LTD	21.00	25	LTD	LTD	15	2	
Point Lance																			
Point Lance	Unnamed Pond	Sep 11, 2019	8.00	<u>168</u>	73.0	13.00	6.78	47		1.20	LTD	LTD	2.00	14	LTD	LTD	9	3	
Point May																			
Point May	Short's Pond	Aug 27, 2019	10.00	LTD	88.0	5.00	7.33	57		1.10	LTD	LTD	2.00	20	LTD	LTD	13	1	
Point May - PWDU	Short's Pond	Aug 27, 2019	8.00	LTD	66.0	LTD	7.08	43		0.20	LTD	LTD	LTD	15	LTD	LTD	10	LTD	
Point of Bay																			
Point of Bay	Indian Cove Pond	Aug 20, 2019	11.00	14	61.0	10.00	7.11	40		0.30	LTD	LTD	4.00	10	LTD	LTD	7	LTD	
Pollards Point																			
Pollards Point, Country Cove	Country Cove Pond	Sep 25, 2019	20.00	<u>17</u>	89.0	20.00	7.52	58		0.40	LTD	LTD	8.00	17	LTD	LTD	8	1	
Pollards Point East	George Ricks Pond	Sep 25, 2019	6.00	<u>27</u>	27.0	5.00	6.94	18		0.50	LTD	LTD	2.00	3	LTD	LTD	2	LTD	
Pool's Cove																			
Pool's Cove	Widgeon Pond	Sep 24, 2019	12.00	<u>24</u>	77.0	14.00	6.92	50		0.40	0.01	LTD	4.00	13	LTD	LTD	10	LTD	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500	
Guidelines for Canadian Drinking Water Quality																			
Aesthetic (A) or Contaminant (C) Parameter				A			A	A		C	C			A	C		A	A	
Port Albert																			
Port Albert	Beaverton Pond	Sep 17, 2019	24.00	14	242.0	44.00	7.29	157		0.60	0.02	LTD	11.00	56	LTD	LTD	30	5	
Port Blandford																			
Port Blandford	Noseworthy's Pond	Aug 12, 2019	10.00	LTD	180.0	10.00	7.22	117		0.50	LTD	LTD	4.00	45	LTD	LTD	26	2	
Port Hope Simpson																			
Port Hope Simpson	Arnold's Brook and Pond	Aug 07, 2019	LTD	<u>68</u>	52.0	2.00	6.72	34		0.50	LTD	LTD	1.00	10	LTD	LTD	8	LTD	
Port Saunders																			
Port Saunders	Tom Taylor's Pond	Sep 18, 2019	91.00	11	249.0	110.00	8.45	162		0.90	LTD	LTD	26.00	20	LTD	LTD	9	2	
Port Saunders - PWDU	Tom Taylor's Pond	Sep 18, 2019	46.00	LTD	153.0	56.00	8.22	99		0.30	LTD	LTD	14.00	17	LTD	LTD	7	LTD	
Port au Choix																			
Port au Choix	Winterhouse Pond	Sep 18, 2019	112.00	4	312.0	136.00	8.44	203		0.50	LTD	LTD	38.00	27	LTD	LTD	12	3	
Port au Choix - PWDU	Winterhouse Pond	Sep 18, 2019	9.00	LTD	48.0	5.00	7.81	31		0.60	LTD	LTD	2.00	5	LTD	LTD	3	LTD	
Portland Creek																			
Portland Creek	Unnamed Streams	Sep 27, 2019	159.00	2	371.0	179.00	7.94	241		0.40	0.01	LTD	60.00	24	LTD	LTD	11	2	
Portugal Cove South																			
Portugal Cove South	Wrights Brook	Aug 21, 2019	8.00	7	72.0	9.00	7.40	47		0.50	LTD	LTD	2.00	18	LTD	LTD	9	3	
Portugal Cove-St. Phillips																			
Portugal Cove-St. Phillips	Bay Bulls Big Pond	Aug 15, 2019	26.00	3	101.0	25.00	7.93	66		0.30	LTD	LTD	10.00	15	LTD	LTD	7	1	
Postville																			
Postville	Big Pond	Aug 14, 2019	10.00	<u>32</u>	71.0	5.00	7.50	46		1.10	LTD	LTD	2.00	13	LTD	LTD	10	LTD	
Postville - PWDU	Big Pond	Aug 14, 2019	10.00	10	24.0	LTD	7.85	16		0.30	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD	
Pouch Cove																			
Pouch Cove	North Three Island Pond	Aug 13, 2019	13.00	LTD	64.0	9.00	7.97	42		0.30	LTD	LTD	2.00	11	LTD	LTD	7	LTD	
Purcell's Harbour																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	C	C	A	C	A	C	A	C	A	C	A	C	A
Aesthetic (A) or Contaminant (C) Parameter																		
Purcell's Harbour																		
Purcell's Harbour	Purcell's Harbour Pond	Aug 22, 2019	49.00	<u>38</u>	171.0	58.00	7.72	111		0.60	LTD	LTD	20.00	19	LTD	LTD	12	3
Pynn's Brook																		
Pynn's Brook	Pynn's Brook	Sep 20, 2019	49.00	<u>21</u>	128.0	58.00	7.82	83		0.20	LTD	LTD	20.00	7	LTD	LTD	5	5
Ramea																		
Ramea	Northwest Pond	Aug 15, 2019	10.00	<u>29</u>	501.0	55.00	7.10	326		0.60	0.03	LTD	12.00	121	LTD	3.000	64	37
Ramea - PWDU	Northwest Pond	Aug 15, 2019	LTD	<u>18</u>	36.0	LTD	<u>6.46</u>	23		LTD	0.03	LTD	LTD	10	LTD	LTD	6	LTD
Random Sound West																		
Queen's Cove	Reservoir	Sep 09, 2019	16.00	<u>46</u>	97.0	10.00	7.22	63		0.40	LTD	LTD	4.00	16	LTD	LTD	12	1
Rattling Brook																		
Rattling Brook	Mark's Pond Brook	Sep 25, 2019	LTD	<u>16</u>	85.0	2.00	6.54	55		0.20	LTD	LTD	1.00	19	0.120	LTD	15	LTD
Red Bay																		
Red Bay	Northern Brook	Aug 07, 2019	5.00	<u>50</u>	18.0	LTD	7.20	12		0.80	LTD	LTD	LTD	2	LTD	LTD	LTD	LTD
Reidville																		
Reidville	Humber Canal, Grand Lake	Sep 04, 2019	7.00	13	46.0	10.00	6.80	30		0.30	LTD	LTD	4.00	7	LTD	LTD	3	1
Rigolet																		
Rigolet	Rigolet Pond	Aug 15, 2019	LTD	<u>150</u>	18.0	5.00	<u>6.28</u>	12		0.80	LTD	LTD	2.00	1	LTD	LTD	LTD	LTD
Rigolet - PWDU	Rigolet Pond	Aug 15, 2019	LTD	<u>19</u>	LTD	LTD	<u>6.04</u>	LTD		0.30	LTD	LTD	LTD	LTD	LTD	LTD	LTD	LTD
River of Ponds																		
River of Ponds	Burnt Head Ponds	Sep 30, 2019	62.00	12	174.0	70.00	7.80	113		0.60	LTD	LTD	18.00	18	LTD	LTD	8	1
Rocky Harbour																		
Rocky Harbour	Gull Pond	Sep 20, 2019	59.00	13	166.0	79.00	7.69	108		0.30	LTD	LTD	20.00	14	LTD	LTD	6	2
Roddickton-Bide Arm																		
Bide Arm	First Clay Cove Pond	Aug 19, 2019	117.00	6	240.0	116.00	8.34	156		0.40	LTD	LTD	35.00	8	LTD	LTD	5	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	A	C	C	A	C	A	A						
Aesthetic (A) or Contaminant (C) Parameter																		
Roddickton-Bide Arm																		
Roddickton	East Brook Pond	Aug 19, 2019	67.00	8	147.0	71.00	8.17	96		0.40	LTD	LTD	22.00	6	LTD	LTD	2	LTD
Rose Blanche-Harbour Le Cou																		
Rose Blanche-Harbour Le Cou	Rose Blanche Brook	Sep 10, 2019	8.00	<u>118</u>	51.0	LTD	7.28	33		0.90	LTD	LTD	LTD	9	LTD	LTD	5	1
Rushoon																		
Rushoon	Big Pond Brook	Aug 29, 2019	12.00	<u>43</u>	67.0	2.00	8.06	44		0.20	LTD	LTD	1.00	11	LTD	LTD	7	1
Salmon Cove																		
Salmon Cove	Rocky Pond	Aug 26, 2019	11.00	4	61.0	5.00	7.86	40		0.40	LTD	LTD	2.00	10	LTD	LTD	6	1
Salvage																		
Salvage	Wild Cove Pond	Aug 19, 2019	12.00	<u>38</u>	148.0	12.00	7.23	96		0.50	LTD	LTD	3.00	35	LTD	LTD	20	3
Seal Cove (WB)																		
Seal Cove, W.B.	Seal Cove Brook & Long Pond	Sep 27, 2019	9.00	<u>62</u>	54.0	10.00	6.77	35		0.40	LTD	LTD	4.00	8	LTD	LTD	5	1
Sheaves Cove																		
Sheaves Cove	Unnamed Brook	Sep 24, 2019	143.00	13	327.0	167.00	8.36	213		0.20	LTD	LTD	52.00	14	LTD	LTD	8	6
Sheshatshiu																		
Sheshatshiu - Indian Band Council	Wells 1, 2 & 3	Jul 30, 2019	89.00	LTD	360.0	74.00	7.68	234		0.60	0.07	LTD	18.00	48	0.290	4.000	45	13
Small Point-Adam's Cove-Blackhead-Broad Cove																		
Adam's Cove	#1 Well - Reg Bursey Well	Jul 16, 2019	90.00	LTD	248.0	78.00	8.40	161		0.30	0.01	LTD	23.00	20	0.120	LTD	19	18
Smith's Harbour																		
Smith's Harbour	Fleshetts Brook	Sep 26, 2019	6.00	<u>52</u>	33.0	7.00	<u>6.45</u>	21		0.40	LTD	LTD	3.00	4	LTD	LTD	3	LTD
Sop's Arm																		
Sop's Arm	Little Tickle Pond	Sep 25, 2019	9.00	<u>63</u>	33.0	7.00	7.25	21		0.40	LTD	LTD	3.00	3	LTD	LTD	2	LTD
South Dildo																		
South Dildo	Broad Cove Pond	Sep 12, 2019	LTD	7	48.0	5.00	<u>6.25</u>	31		1.10	LTD	LTD	2.00	12	LTD	LTD	4	2
South River																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate		
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Units			15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500	Guidelines for Canadian Drinking Water Quality					
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	C	A	C	A	C	A	C	A	C			
South River																				
South River	Brigus Long Pond (to Brigus)	Aug 27, 2019	LTD	10	57.0	5.00	<u>6.35</u>	37		0.30	LTD	LTD	2.00	13	LTD	LTD	7	2		
Southern Harbour																				
Southern Harbour	Brigades Pond	Aug 21, 2019	9.00	<u>23</u>	49.0	10.00	7.02	32		0.90	LTD	LTD	4.00	9	LTD	LTD	5	2		
Spaniard's Bay																				
Spaniard's Bay (+Upper Island Cove, + Bryant's Cove)	Kelly's Pond (Spider's Pond)	Aug 26, 2019	LTD	2	39.0	2.00	<u>6.47</u>	25		0.80	LTD	LTD	1.00	9	LTD	LTD	4	1		
Springdale																				
Springdale	Sullivan's Pond (2 Intakes)	Sep 25, 2019	16.00	15	53.0	22.00	7.00	34		0.20	LTD	LTD	7.00	4	LTD	LTD	LTD	2		
St. Anthony																				
St. Anthony	St. Anthony Pond	Aug 20, 2019	25.00	<u>34</u>	76.0	22.00	7.69	49		0.40	LTD	LTD	2.00	12	LTD	LTD	3	1		
St. Anthony Bight																				
St. Anthony Bight	Cabbox Pond	Sep 16, 2019	10.00	<u>142</u>	68.0	5.00	6.56	44		0.60	LTD	LTD	2.00	13	LTD	LTD	10	LTD		
St. Bernard's-Jacques Fontaine																				
St. Bernard's-Jacques Fontaine	Rattle Brook	Sep 05, 2019	7.00	<u>81</u>	83.0	2.00	6.90	54		0.60	LTD	LTD	1.00	17	LTD	LTD	13	LTD		
St. Bride's																				
St. Bride's	North Side Brook	Sep 11, 2019	15.00	15	100.0	13.00	6.98	65		1.00	LTD	LTD	2.00	21	LTD	LTD	12	LTD		
St. Bride's	South Side Brook	Sep 11, 2019	15.00	<u>183</u>	69.0	21.00	7.03	45		1.20	LTD	LTD	5.00	10	LTD	LTD	7	LTD		
St. John's																				
St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Aug 15, 2019	25.00	LTD	100.0	22.00	7.90	65		0.20	LTD	LTD	9.00	15	LTD	LTD	7	1		
St. John's	Windsor Lake	Aug 13, 2019	23.00	LTD	128.0	28.00	7.66	83		0.30	LTD	LTD	11.00	23	LTD	LTD	13	2		
St. John's	Petty Harbour Long Pond	Aug 13, 2019	36.00	LTD	110.0	40.00	7.84	72		0.70	LTD	LTD	16.00	11	LTD	LTD	5	1		
St. Jude's																				
St. Jude's	Uncle Arthur Brook	Sep 20, 2019	38.00	<u>22</u>	106.0	42.00	7.62	69		0.40	0.03	LTD	12.00	6	LTD	LTD	7	6		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	C	A	C	A	C	A	C	A	C	
St. Jude's																		
St. Jude's	Chute Brook	Sep 20, 2019	33.00	12	85.0	38.00	7.67	55		0.10	LTD	LTD	12.00	5	LTD	LTD	4	1
St. Lawrence																		
St. Lawrence	St. Lawrence River	Aug 27, 2019	LTD	4	46.0	2.00	<u>6.23</u>	30		0.50	LTD	LTD	1.00	14	0.220	LTD	4	1
St. Lewis																		
St. Lewis	Tub Harbour Pond	Aug 07, 2019	13.00	<u>61</u>	66.0	7.00	7.66	43		0.60	LTD	LTD	3.00	10	LTD	LTD	5	1
St. Lunenburg																		
St. Lunenburg	Joe's Pond	Sep 17, 2019	8.00	<u>49</u>	93.0	17.00	7.44	60		0.60	LTD	LTD	5.00	16	LTD	LTD	6	1
Gunners Cove	Lookout Brook	Sep 17, 2019	46.00	<u>46</u>	161.0	55.00	8.00	105		1.30	LTD	LTD	17.00	16	LTD	LTD	11	1
St. Paul's																		
St. Paul's	Two Mile Pond	Sep 30, 2019	73.00	6	263.0	94.00	7.65	171		1.30	0.04	LTD	31.00	36	0.120	1.000	13	5
St. Shott's																		
St. Shott's	Unnamed Pond	Aug 19, 2019	15.00	<u>21</u>	116.0	11.00	7.69	75		0.70	LTD	LTD	1.00	22	LTD	LTD	13	2
Steady Brook																		
Steady Brook	Wellfield + Steady Brook	Sep 27, 2019	37.00	<u>51</u>	306.0	108.00	7.53	199		0.70	LTD	LTD	40.00	42	LTD	1.000	14	45
Stephenville																		
Stephenville	Well Field	Sep 23, 2019	164.00	LTD	383.0	171.00	8.42	249		0.20	0.02	LTD	52.00	19	LTD	LTD	13	7
Stoneville																		
Stoneville	Dog Bay Pond Brook	Sep 16, 2019	9.00	14	39.0	12.00	6.88	25		0.20	LTD	LTD	3.00	5	LTD	LTD	3	LTD
Straitsview																		
Straitsview	Saddle Hill Pond	Sep 17, 2019	16.00	<u>119</u>	114.0	26.00	7.57	74		0.70	LTD	LTD	7.00	19	LTD	LTD	12	3
Summerford																		
Summerford (+Cottlesville)	Rushy Cove Pond	Aug 22, 2019	39.00	<u>19</u>	173.0	56.00	7.47	112		0.50	LTD	LTD	19.00	24	LTD	LTD	12	4
Sunnyside (T.B.)																		
Sunnyside	Center Cove River	Aug 21, 2019	11.00	<u>20</u>	70.0	5.00	7.31	46		0.40	LTD	LTD	2.00	15	LTD	LTD	10	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500	Aesthetic (A) or Contaminant (C) Parameter					
				A	A	C	C	A	C	A	C	A	C	A	C	A	C	
Terrenceville																		
Terrenceville	Big Brook	Sep 04, 2019	LTD	<u>129</u>	66.0	2.00	<u>6.29</u>	43		0.70	LTD	LTD	1.00	13	LTD	LTD	12	LTD
Thornlea																		
Thornlea	Big Bakeapple Pond	Sep 16, 2019	26.00	<u>28</u>	64.0	2.00	8.11	42		0.10	LTD	LTD	1.00	8	LTD	LTD	5	2
Torbay																		
Torbay	North Pond	Aug 13, 2019	18.00	LTD	103.0	7.00	8.44	67		0.80	LTD	LTD	3.00	16	LTD	LTD	16	2
Trepassey																		
Trepassey	Miller's Pond	Aug 19, 2019	28.00	<u>22</u>	106.0	9.00	8.20	69		0.60	LTD	LTD	2.00	15	LTD	LTD	12	1
Trepassey	Broom Cove Pond	Aug 19, 2019	15.00	12	86.0	12.00	7.77	56		1.00	LTD	LTD	5.00	15	LTD	LTD	10	1
Trinity																		
Trinity, T.B.	Indian Pond	Aug 12, 2019	LTD	<u>18</u>	43.0	LTD	<u>6.42</u>	28		0.20	LTD	LTD	LTD	10	LTD	LTD	7	LTD
Trinity Bay North																		
Little Catalina	Whirl Pond	Aug 13, 2019	10.00	15	81.0	5.00	6.94	53		0.50	LTD	LTD	2.00	16	LTD	LTD	12	1
Melrose	Whirl Pond	Aug 13, 2019	16.00	14	97.0	5.00	7.22	63		0.40	LTD	LTD	2.00	17	LTD	LTD	17	1
Port Union, Catalina (+Little Catalina)	Whirl Pond	Aug 13, 2019	20.00	15	93.0	2.00	7.45	60		0.40	LTD	LTD	1.00	15	LTD	LTD	16	1
Trout River																		
Trout River	Feeder Brook	Sep 27, 2019	56.00	8	172.0	63.00	7.72	112		0.40	LTD	LTD	7.00	18	LTD	LTD	10	2
Twillingate																		
Twillingate	Wild Cove Pond	Aug 22, 2019	7.00	10	125.0	21.00	6.66	81		0.30	0.01	LTD	5.00	28	LTD	LTD	14	3
Upper Island Cove																		
Upper Island Cove	Kelly's Pond (Spider's Pond)	Aug 26, 2019	LTD	4	42.0	2.00	6.89	27		0.70	LTD	LTD	1.00	8	LTD	LTD	4	1
Victoria																		
Victoria (+Salmon Cove)	Rocky Pond	Aug 26, 2019	8.00	2	53.0	2.00	7.40	34		0.50	LTD	LTD	1.00	10	LTD	LTD	6	1
Wabush																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	A						
Wabush																		
Wabush	Wahnahnish Lake	Jul 17, 2019	35.00	11	64.0	30.00	7.98	42		0.40	LTD	LTD	7.00	3	LTD	LTD	LTD	2
West Bay																		
West Bay	Victor's Brook	Sep 26, 2019	96.00	10	341.0	136.00	7.64	222		0.90	0.03	LTD	43.00	40	LTD	LTD	13	8
West Bay	Unnamed Brook	Sep 26, 2019	118.00	<u>42</u>	313.0	141.00	8.01	203		2.20	0.02	LTD	45.00	21	LTD	LTD	10	8
West St. Modeste																		
West St. Modeste	Well Field	Aug 07, 2019	92.00	4	249.0	LTD	8.18	162		2.50	0.08	LTD	LTD	18	0.720	LTD	50	6
Whitbourne																		
Whitbourne	Hodges River	Sep 16, 2019	LTD	12	97.0	12.00	7.02	63		0.40	LTD	LTD	3.00	22	LTD	LTD	10	2
Whiteway																		
Whiteway (+Cavendish)	Long Pond	Sep 12, 2019	5.00	3	70.0	9.00	6.98	46		0.60	LTD	LTD	2.00	16	LTD	LTD	9	2
Whiteway - PWDU	Long Pond	Sep 12, 2019	LTD	LTD	37.0	LTD	<u>6.24</u>	24		0.40	LTD	LTD	LTD	8	LTD	LTD	5	3
Winterton																		
Winterton	Western Pond	Sep 17, 2019	5.00	7	52.0	5.00	7.25	34		0.40	LTD	LTD	2.00	10	LTD	LTD	5	2
Woodstock																		
Woodstock	Mill Pond	Sep 27, 2019	LTD	<u>141</u>	29.0	2.00	<u>5.55</u>	19		0.60	LTD	LTD	1.00	5	LTD	LTD	3	LTD
Woody Point																		
Woody Point	Winterhouse Brook	Sep 27, 2019	40.00	<u>30</u>	109.0	38.00	7.83	71		0.50	LTD	LTD	2.00	9	LTD	LTD	5	1

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
		Guidelines for Canadian Drinking Water Quality		15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
		Aesthetic (A) or Contaminant (C) Parameter		A			A	A		C	C			A	C		A	A

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

Quality Assurance / Quality Control (QA/QC) - The department is striving to improve the quality of the data using standard QA/QC protocols. This is an evolving process which may result in minor changes to the reported data.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

The exceedance report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ.

Aesthetic (A) Parameters - Aesthetic parameters reflect substances or characteristics of drinking water that can affect its acceptance by consumers but which usually do not pose any health effects. Aesthetic exceedances are highlighted in **blue text** and underlined.

Contaminants (C) - Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant and Aesthetic Exceedances

Turbidity - The maximum acceptable concentration for turbidity is 1 NTU. Turbidity refers to the water's ability to transmit light or the cloudiness of the water. Turbidity in tap water can be the result of turbid raw water and influences within the distribution system. Turbidity is usually the result of fine organic and inorganic particles which do not settle out. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process.

Boron - The interim maximum acceptable concentration for boron in drinking water is 5.0 mg/L. Boron is widespread in the environment, occurring naturally in over 80 minerals and in the earth's crust. Levels in well water have been reported to be more variable and often higher than those in surface waters, most likely due to erosion from natural resources. High levels of this contaminant can cause adverse health effects for some people

Fluoride - The maximum acceptable concentration for fluoride in drinking water is 1.5mg/L. The fluoride concentration in natural water varies widely as it depends on such factors as the source of the water and the geological formations present. Trace amounts of fluoride may be essential for human nutrition and the presence of small quantities leads to a reduction of dental caries. High levels of this contaminant can cause adverse health effects for some people.

Colour - An aesthetic objective of 15 true colour units (TCU) has been established for colour in drinking water. Colour in drinking water may be due to the presence of coloured organic substances or metals such as iron, manganese and copper. Highly coloured industrial wastes also contribute to colour. The presence of colour is not directly linked to health but it can be aesthetically displeasing.

pH - The acceptable range for drinking water pH is 6.5 - 8.5. The control of pH is primarily based on minimizing corrosion and encrustation in the distribution system. Tap water with low pH may accelerate the corrosion process in the distribution system, and contribute to increased levels of copper, lead and possibly other metals. Incrustation and scaling problems may become more frequent above pH 8.5

TDS - The aesthetic objective for TDS in drinking water is 500 mg/L. The term "total dissolved solids"(TDS) refers mainly to the inorganic substances that are dissolved in water. At low levels TDS contributes to the palatability of water. At high levels it may cause excessive hardness, taste, mineral deposition and corrosion.

Chloride - The aesthetic objective for chloride in drinking water is 250 mg/L. Chloride can be in water from a variety of sources, including the dissolution of salt deposits and salting of roads for ice control. No evidence has been found suggesting that ingestion of chloride is harmful to humans. However, high levels of chloride in water can impart undesirable tastes to water and beverages prepared from water.

Sodium - The aesthetic objective for sodium in drinking water is 200 mg/L. Since the body has very effective means to control levels of sodium, sodium is not an acutely toxic element in the normal range of environmental or dietary concentrations. At extremely high dosages it has adverse health effects. Sodium levels may be of interest to authorities who wish to prescribe sodium restricted diets for their patients..

Sulphate - The aesthetic objective for sulphate in drinking water is 500 mg/L. Sulphates, which occur naturally in numerous minerals, are used in the mining and pulping industries and in wood preservation. Large quantities of sulphate can result in catharsis and gastrointestinal irritation. The presence of sulphate above the aesthetic limit can result in noticeable taste. Some sensitive individuals may find the taste objectionable at lower sulphate concentrations

mg/L = milligrams per litre or parts per million µS/cm = micro Siemens per centimeter NTU = nephelometric turbidity units TDS = total dissolved solids TSS = total suspended solids TCU = true colour units Nitrate(ite) = Nitrate + Nitrite DOC = dissolved organic carbon

Notes:

Guidelines for Canadian Drinking Water Quality have not been developed for all the parameters listed in this report.

pH has no units