



Permits to Operate: Inspections and Risk Rating

Drinking Water Safety Workshop, Gander

Paula Dawe, P.Eng

pauladawe@gov.nl.ca

March 25-27, 2014

Class of
System

Owner

Expiry
Date

Type of
System

Date
Issued

Newfoundland
Labrador

Government of Newfoundland and Labrador
Department of Environment and Conservation
Water Resources Management Division

Permit Reference #: 844.097.16-CP-WT
January 24, 2012

Permit to Operate
Permit No. OP-WT-12-0011

Pursuant to Section 35 of the Water Resources Act, SNL 2002 s/W-4.01, a permit to Operate is hereby issued to:

City of St. John's

for the operation of a: **Class IV Water Treatment Plant, Bay Bulls Big Pond**

Name of Owner: **City of St. John's**

Address of Owner: **PO Box 908
St. John's NL A1C 5M2
(709) 745-3841 (Tel.)
(709) 745-0935 (Fax.)**

Attention: **Mr. Terry Kne, Manager**

Conditions of Permit: **As per Appendix "A"**

Valid From: **January 24, 2012**


This permit is subject to the terms and conditions indicated in Appendix A (attached). This permit is valid until January 24, 2012, unless there is a change in the classification of the water treatment plant or as may be determined by this Department.

Failure to comply with the terms and conditions will render this permit null and void, place the owner and their agent(s) in violation of the Water Resources Act, SNL 2002 s/W-4.01 and make the owner responsible for taking any remedial measures as may be prescribed by this Department.


MINISTER

Permits to Operate 101

- Issued under Section 38 of the Water Resources Act
 - “All waterworks in the province shall at all times be maintained, kept in repair and operated in a manner and with those facilities that the minister may direct.”
- Permits to Operate are issued to the **Owner** of the system
 - Community
 - Regional Service Board
- First issued by ENVCA in 2002
 - Permits to Operate a recommendation of the Walkerton Enquiry



Why are Permits to Operate Important?

- Provide guidance on how Owners should properly operate and maintain their drinking water systems
- Terms and conditions contained in the permit can be viewed as the minimum requirements necessary for the proper operation and maintenance of the drinking water system
- Having a Permit to Operate is a factor in the approval of capital works funding by the Department of Municipal and Intergovernmental Affairs
- Key component in the province's Multi-Barrier Strategic Action Plan for Drinking Water Safety

Multi-Barrier Strategic Action Plan




Water Resources
Management
Division

Department of
Environment &
Conservation

Multi-Barrier Strategic Action Plan



Classification: Distribution Systems




Classification: Water Treatment


A	B	C	D	E	F
Water Treatment Plant Facility Classification Calculator (updated 2013)					
<i>note: water supplies with only c12 are considered a distribution system only</i>					
Class I --- 30 pts or less Class II --- 31 - 55 pts Class III --- 56 - 75 pts Class IV --- 76 pts or more					
Input of T, t, F, or f is accepted.					
Enter Plant Name Below:					
32 Points					
Plant->	Class II				
Item	Description	Input	Points	Comment	
1 Size in m3/day (1 pt min to 20 pt max)					
(i)	In m3/day, the larger of: Design Flow Avg Day or Peak Month Avg Day (min 1 pt, max 20 pt)	0	1		
2 Water Supply Sources- Rating Based on public health significance					
(i)	Seawater/saltwater (T) rue/(F)alse (0 pts)	f	0		
(ii)	Groundwater source (T) rue/(F)alse (0 pts)	t	0		
(iii)	Groundwater under the influence of surface water (GWDI) (T/F) (8 pts)	f	0		
(iv)	Surface water (T/F) (10 pts)	f	0		
3 Average raw water quality variation					
(i)	Little or no variation (T/F) -0 pts	f	0		
(ii)	Minor variation -eg. "high quality" source appropriate for ss filtration (T/F) (1 pt)	t	1		
(iii)	Moderate variation in chemical feed, dosage changes made (M)onthly, (W)eekly or (D)aily (2,3,4 pts) If N/A, leave blank				
(iv)	Variation requiring pronounced/very frequent dosage changes (T/F) (5 pts)	f	0		
(v)	Severe variation - source subject to non-point discharges, agricultural/urban storm runoff, flooding (T/F) (7 pts)	f	0		
(vi)	Raw water quality subject to agricultural or municipal waste point source discharges (T/F) (8 pts)	f	0		
(vii)	Raw water quality subject to industrial waste pollution (T/F) (10 pts)	f	0		
4 Raw water is subject to: (see note 1 at end)					
(i)	Taste and/or odour for which treatment process adjustments are routinely made (T/F) (2 pts)	f	0		
(ii)	Source Water Colour levels >15 TCU (T/F) (3 pts)	t	3		
(iii)	Iron and/or manganese levels > AOs: Fe 2 pts, Mn 3Pts. Maximum of 3 pts				

- Size
- Source type
- Chemical addition
- Types of treatment processes
- Residual disposal
- Process control

Classification: Water Treatment



History of Permits to Operate



Water Resources
Management
Division

Department of
Environment &
Conservation

Development
of Permits to Operate
post Walkerton

WTPs and stragglers

Reissuing of
expired permits

What's New with Permits to Operate?

- 319 Owners with Permits to Operate
- ENVCC used to issue separate Permits for:
 - Water Treatment (expired after 5 years)
 - Water Distribution (valid until change in classification)
- ENVCC now issuing a single Permit to Operate for the Drinking Water System
- Before reissuing expired Permits ENVCC is conducting:
 - an inspection of system
 - a quantified risk rating of the system

Purpose of Inspection & Risk Rating

- Determine compliance with terms and conditions in Owner's Permit to Operate
- Highlight areas of non-compliance that require attention
- Determine the risk posed to the system
- Provide guidance on corrective actions
- Give Owners an idea of how they are doing and how they are doing in comparison to other Owners
- To encourage Owners and Operators to work towards the continuous improvement of the O&M of their drinking water systems
- To establish a way to measure progress

Inspection Process

- ENVC will arrange a date/time
- ENVC will discuss with operator ahead of time
 - Records, plans, manuals made available
- Inspection can take 2 hrs to all day
- ENVC will inspect facilities with operator
- ENVC will fill out an Inspection Field Sheet
- ENVC will complete a Drinking Water System Inspection Report and Inspection Rating
- Inspection Report and Rating sent to:
 - Owner and Operator
 - Other communities on a shared system
 - MIGA
- Permit to Operate reissued

Water Resources
Management
Division

Department of
Environment &
Conservation



Inspection Field Sheet



- 12 Inspection Modules that consist of 85 questions:
 - Source
 - Source protection signage in place?
 - Treatment Process
 - Has max flow rate of WTP been exceeded?
 - Water Quantity and Quality Monitoring
 - Daily chlorine residual monitoring?
 - Waste and Process Wastewater
 - Does discharge meet Water & Sewer Regs?
 - Distribution System
 - Are up to date plans of distribution system available?
- Operations Manuals
 - Operators have access to manuals?
- Logbooks
 - Are logs kept for 5 years?
- Contingency, Emergency and Long-Term Planning
 - Emergency Response Plan has been developed?
- Security and Safety
 - Chemicals stored properly?
- Consumer Relations
 - Log of consumer complaints kept?
- Certification and Training
 - Operators certified to the level of their system?
- Reporting, Notification and Corrective Actions
 - Permit to Operate posted?

Inspection Rating

- Risk management approach
- Based on ON risk rating methodology applied to drinking water system inspection results
- Systematic approach to identifying potential hazards
 - understanding the likelihood and consequences of the hazards
 - taking steps to reduce the risk to the delivery of safe drinking water

Risk Methodology

- Risk = Consequence x Likelihood

Consequence	Consequence Value
Medium Administrative Consequence	1
Major Administrative Consequence	2
Minor Environmental Consequence	3
Minor Health Consequence	4
Medium Environmental Consequence	5
Major Environmental Consequence	6
Medium Health Consequence	7
Major Health Consequence	8

Likelihood of Consequence Occurring	Likelihood Value
0-0.99% (Possible but Highly Unlikely)	0
1-10% (Unlikely)	1
11-49% (Possible)	2
50-89% (Likely)	3
90-100% (Almost Certain)	4

- Each question has its own Risk Rating (of not complying) from a possible 0-32

Risk Methodology

- Individual question risk rating derived from an evaluation of every identified consequence and its corresponding likelihood of occurrence:
 - All levels of consequence are evaluated for their potential to occur
 - Greatest of all the combinations is selected

Source protection signage in place?							
Risk = Consequence x Likelihood							
1	2	3	4	5	6	7	8
Medium Administrative Consequence	Major Administrative Consequence	Minor Environmental Consequence	Minor Health Consequence	Medium Environmental Consequence	Major Environmental Consequence	Medium Health Consequence	Major Health Consequence
2 (Possible)	1 (Unlikely)	1 (Unlikely)	2 (Possible)	1 (Unlikely)	1 (Unlikely)	1 (Unlikely)	1 (Unlikely)
R=2	R=2	R=3	R=8	R=5	R=6	R=7	R=8

Risk Methodology

- Has max flow rate of WTP been exceeded?

- Consequence = 7
 - Medium Health Consequence
- Likelihood = 3
 - Likely a Medium Health Consequence will Occur

- Risk = $7 \times 3 = 21$

- Permit to Operate posted?

- Consequence = 4
 - Minor Health Consequence
- Likelihood = 1
 - Unlikely a Minor Health Consequence will Occur

- Risk = $4 \times 1 = 4$

Final Inspection Rating

Community:	
LGP #:	
Population:	
Region:	
Water Distribution Class:	
Water Treatment Class:	
Type of Inspection:	Detailed
Inspection Date:	26-Nov-12

Inspection Module	Non-Compliance Rating	Maximum Question Rating
Source	1	55
Treatment Process	0	104
Water Quantity and Quality Monitoring	45	110
Waste and Process Wastewater	10	22
Distribution System	27	89
Operations Manuals	0	22
Logbooks	0	30
Contingency, Emergency and Long-Term Planning	0	50
Security and Safety	0	37
Consumer Relations	0	15
Certification and Training	21	71
Reporting, Notification and Corrective Actions	16	73
Total	120	678


Inspection Risk Rating	17.7 %
------------------------	--------

Final Inspection Rating	82.3 %
-------------------------	--------


Rating Category	Rating Bands (%)
Poor	0-49
Marginal	50-64
Fair	65-74
Good	75-84
Very Good	85-94
Excellent	95-100

- Total score out of 100 %

Permit to Operate Drinking Water System Inspection Ratings



Permit to Operate Drinking Water System Inspection Ratings



Inspection Report

- Inspection Module questions and field notes
- Drinking Water System Description
- Summary of Non-Compliance Issues
- Recommended Corrective Actions
- Final Inspection Rating

Most Common Non-Compliance Issues

- Source
 - Potential pollution sources identified in source area
 - No source inspection program in place
 - No Water Use Licenses
- Treatment Process
 - Proof that chemicals used in the treatment process meet AWWA/NSF standards
 - Capacity of WTP has been exceeded or near to being exceeded
- Water Quantity and Quality Monitoring
 - Flow monitoring devices not calibrated
 - Chlorine residual monitoring is not undertaken for total chlorine or not done daily
 - Drinking water quality exceedences
- Waste & Process Wastewater
 - Process wastewater from the WTP is not being tested
- Manuals and Logbooks
 - Incomplete or missing operations and maintenance manuals
 - Logs of scheduled O & M activities were not kept

Most Common Non-Compliance Issues


- Distribution System
 - No regular maintenance program in place for backflow prevention devices
 - No cross connection control program in place
 - No program in place for inspecting/exercising valves
 - No leak detection/repair program in place
 - No monitoring of pressure in the distribution system
 - No program in place for inspection and cleaning of water storage tanks
- Contingency, Emergency and Long-Term Planning
 - No emergency response plan
- Consumer Relations
 - No water conservation program
- Certification & Training
 - Operators not certified to the level of the drinking water system
- Reporting, Notification and Corrective Actions
 - Permit to Operate not posted
 - Annual water system audit/report not completed

Future Implications

- Non-compliance issues will be reevaluated when your Permit to Operate is up for renewal again
- Where risk is deemed to be high and/or compliance is an ongoing concern, further action may be taken by this Department

Want to Schedule an Inspection of Your Drinking Water System?

- Western & Labrador contact
Corner Brook Office



- Eastern & Central contact St.
John's Office

Path Forward

- ENVC to complete inspections of all systems with WTPs
- ENVC to move forward with inspections and permit reissue for systems with:
 - PWDUs
 - pH adjustment
 - Filtration systems (Fe/Mn, arsenic, lead)
 - UV
 - Systems that have had significant changes that may affect their classification
 - Special requests from Owners
- ENVC looking at classification of systems with water treatment facilities other than WTPs
- Review risk rating methodology periodically to account for changes in regulatory requirements, Permit to Operate terms and conditions, etc.
- 5 year cycle of Permit to Operate Inspections and Renewals
- Work toward the goal of 100 per cent compliance

Questions?



Water Resources
Management
Division

Department of
Environment &
Conservation