

Drinking Water Safety Initiative

Clean and Safe Drinking Water
Workshop 2010

Gander, NL

March 23, 2010



Drinking Water Safety Initiative

Part 1: Program Background & Status

Presented by: Bob Picco
Dept. of Municipal Affairs

Part 2: Potable Water Dispensing Units

Presented by: Mike Chaulk
CBCL Limited

Background

- April 2008 joint announcement by the Ministers of MA & ENVC
- Joint Program to make safe drinking water available to smaller communities (Pop <500)

Application Process

- 114 communities rated as top priority for water quality improvement
- Invitation to all communities with:
 - Population < 500
 - Existing water supply

227 letters requesting applications sent

Response

- Initial response: 41
- Total to date: 51
 - 34 from top priority communities

Application Review

| | | |
|-------------------|----|-----------------------|
| • Yes: | 22 | |
| • No: | 15 | ➔ 5 for other options |
| • Maybe: | 11 | |
| • To be reviewed: | 3 | |
| Total | 51 | |

Design Considerations

- Based on concurrent study by CBCL on seven existing units:
 - Minimize O & M costs
 - Simplify maintenance requirements
 - Standardize process and equipment
 - Stand alone structure
 - Accessibility
 - Health concerns

Construction Process

- Proposal for equipment, 'standing offer' agreement
- Pilot system to be installed
- Tenders for construction by region

Proposed Construction Schedule

- Call for proposals for treatment equipment in March, award in April/May
- Construction tenders in the summer/fall 2010

Cost Estimates

PWDU:

Constructions cost

- \$250,000 to \$270,000 - province/community
- Includes equipment, engineering and HST

Cost shared 90/10 province/community

O & M Costs:

- \$2,500 - \$3,000/year
- Includes heat, light parts and supplies

Cost Estimates (cont'd)

Full Scale Treatment Plant:

Constructions costs:

- \$1.5 M – \$2 M
- Includes equipment, engineering and HST

Cost shared 90/10 province/community
(Pop<3000)

O & M Costs:

- \$50K - \$100 K /year
- Includes labour heat, light parts and supplies


Community Considerations

- PWDU supplies clean, safe easily accessible drinking water at reasonable cost
- Focus on O & M costs
- O & M requirements
 - Low Cost
 - Standardized system
 - Regional service possibilities

PART 2

Potable Water Dispensing Units

Per Capita Water Use in Newfoundland and Labrador



Water Supply, Treatment and Distribution




Water Treatment Perspectives

- Common design approach is to use a centralized WTP to provide all services
- Several provinces have mandated minimum water treatment standards (i.e. ON, NS)
- NL has historically had several hundred boil water advisories in place at any time
- Community infrastructure maintenance has historically been challenging

Challenges - Water Distribution System




Water Quality Requirements



Bottled Water

- **Environmental Impacts:**
 - Energy associated with the treatment of bottled water as well as the production and eventual disposal of plastic bottles
- **Cost Impacts:**
 - Bottled water is significantly more expensive than municipal tap water or PWDU water



Private Wells

- **Private wells can provide clean, safe water if properly managed**



Spring Water

- **Roadside springs and other untreated sources of water are also popular throughout the province**
- **Untreated sources of water are:**
 - Untested
 - Unmonitored
 - Potentially unsafe



What is a potable water dispensing unit?

- A potable water dispensing unit is a small-scale water treatment system located in a convenient, central location
- It treats enough water to fulfill the consumptive needs of a community
- Residents gather water from the dispensing unit using their own containers

Why use a potable water dispensing unit?

- **High quality drinking water that is:**
 - Cost-effective for the community
 - Cost-effective for the user
- **Safer than spring water and cheaper than bottled water**

Two Interconnected Projects

- **Study of Existing PWDUs**
 - Treatment and dispensing area design
 - Water quality
 - Operation and maintenance costs
 - Socioeconomic impacts
- **PWDU Design and Construction**
 - Evaluation of communities
 - Community visits
 - Development of a standardized PWDU design
 - Request for proposals
 - Evaluation of proposals*
 - Construction*

PWDU Study

- **Seven communities in NL currently employ PWDUs**
- **The Department of Environment and Conservation commissioned a study to compare, contrast and evaluate these systems**
- **Deliverables include:**
 - Six technical memos
 - Public education component
 - Final report



Treatment Equipment


- **Three communities use ozone to remove:**
 - Colour (TOC/DOC)
 - Iron
 - Manganese
 - Pathogens*
- **Four communities use reverse osmosis to remove:**
 - Colour (TOC/DOC)
 - Iron
 - Manganese
 - Turbidity
 - Dissolved solids (salts etc)
 - Pathogens*



Dispensing Areas

- **The dispensing area is the only part of the PWDU that most users interact with**
- **Adoption of the PWDU may be influenced by the quality of the ‘dispensing experience’:**
 - Location
 - Access hours
 - Cleanliness
 - Overall design






O&M

- **Operating and maintaining complex water treatment technology can be challenging in small, remote communities**
 - Lack of operator training
 - Volunteer labour
 - Shipping distance/time
 - Energy costs (generators)

O&M - Monitoring



O&M Costs

- **O&M costs include:**
 - Power (equipment, lights, heat)
 - Labour (operator)
 - Equipment (replacement, consumables)


$$C_{\text{Total}} = C_{\text{Power}} + C_{\text{Labour}} + C_{\text{Equipment}}$$

Socioeconomic Factors

- **Who uses the PWDUs?**
 - Small communities
 - Possible reasons:
 - Lack of resources to afford more complex options
 - More 'buy-in'
 - Remote communities
 - Possible reasons:
 - Ingrained self-sufficiency
 - Lack of access to/experience of high quality, distributed drinking water


**High Per
Capita Use**

**Low Per
Capita Use**



Water Quality

- **The PWDUs exist to provide safe, aesthetically pleasing water for users**
- **People are unlikely to use the systems if the water quality is suspect**
- **We sampled the feed and treated water streams at all of the locations to evaluate whether the systems were accomplishing their goals**
 - Some systems were not available at some points for different reasons



| | Health Related Parameters | Aesthetic Parameters | Perceived Water Quality Assessment | Per Capita Daily Flow |
|----------------------------|---------------------------|----------------------|------------------------------------|-----------------------|
| Black Tickle-Domino | None | pH | Acceptable | 4.5 L |
| Buchans | None | Colour | Unacceptable | 0.2 L |
| Burnt Islands | None | pH | Acceptable | 3.5 L |
| Gaultois | None | None | Excellent | Unknown |
| Howley | Turbidity* | pH | Unacceptable | 1.1 L |
| Ramea | None | pH | Acceptable | 1.8 L |
| St. Lawrence | None | pH, Mn | Unacceptable | 0.5 L |


Standardized PWDU Design

- Project offers opportunity to approach municipal infrastructure differently
- Can a single robust treatment system be designed that fulfills the needs of all participating communities?
- Design, Installation, Operation, Maintenance

Community Evaluations

- **Each community was evaluated for inclusion in the project based on:**
 - Water quality
 - Existing infrastructure
 - Socioeconomic factors
 - Community visits

Water Quality



Existing Infrastructure

- **The majority of the communities have:**
 - A surface water source
 - Challenging water quality
 - No water treatment equipment
 - A history of boil order advisories

Socioeconomic Factors

- **Most of the communities:**
 - Have small populations (50 to 500 people)
 - Are located in remote parts of the province
 - Face challenges relating to unemployment and a shrinking population
- **Many of the communities:**
 - Have seasonal industries
- **Based on the findings of the PWDU study, these communities should benefit from the installation of a PWDU**

Community Visits

- **Three CBCL employees traveled around the province in the summer of 2009**
- **They met with community government officials and maintenance people**
 - Briefly assessed the water supply and distribution system
 - Determined an ideal location for a PWDU
 - Established whether the community was interested in the PWDU and whether they were able to afford it






PROTECTED WATERS
SUPPLY AREA

Design

- **The standardized PWDU design includes:**
 - Optional pressure boost
 - Prefiltration
 - Oxidation with ozone
 - Filtration (multimedia filter, carbon filter)
 - Reverse osmosis (nanofiltration)
 - Storage
 - Carbon filter for taste and odour control
 - UV disinfection
 - Dispensing



Pressure and Pretreatment

- **Optional Pressure Boost**

- Many of the existing water supply systems are gravity fed
 - There is sometimes insufficient pressure available to feed water through the proposed treatment process
- Other communities experience periodic high demands that can affect the pressure available:
 - Fish plant operation
 - Running water to keep pipes from freezing

- **Prefiltration**

- Solids in the water are removed before the other treatment processes using a prefilter

Ozone and Filtration

- **Ozone will be used to oxidize:**
 - Colour-causing compounds
 - Metals
 - Iron
 - Manganese
- **Ozone is created on-site using an ozone generator fed by clean, purified oxygen drawn from the surrounding atmosphere**
- **The ozone is injected into the water and allowed to react for a set period of time**
- **The water is then filtered to remove the particulate products of the reaction**

Nanofiltration

- **Nanofiltration is similar to reverse osmosis but occurs at a lower pressure**
 - Minimizing the energy demands of the system
- **Nanofiltration will be used to remove any remaining:**
 - Colour
 - Iron
 - Manganese
 - TDS
 - Other contaminants

Storage

- **Storage is provided as a buffer so that there is always enough water available for users**
 - Process runs at 8 LPM
 - Taps provide water at 20 LPM
- **When the level in the storage tank drops below a certain level, the treatment system starts to operate to fill it back up again**

Post-Storage

- **Carbon Filter**

- An activated carbon filter is provided after the storage tank to remove taste and odour compounds that may accumulate in the treated water

- **UV Disinfection**


- UV light is used to inactivate any pathogens remaining after ozonation, reverse osmosis filtration and storage

Building

- **Standard Design**

- A single type of detached structure used for all systems
- Will include separate treatment and dispensing areas
- Dispensing area to be same in all locations
- PWDUs across the province will have consistent look
- User access is by magnetic lock – programmable by owner
- Dispensing area includes bottle washing/rinsing

Building







Why use standard building & treatment design?

- **Long term O&M - regionalization**
- **Access to parts, supplies, and experience**
- **Consistent appearance makes a recognizable product across the province**
- **Validated process helps ensure optimal value for each community**

Current Status

- **Government will issue a request for proposals (RFP) for the treatment system**
 - It will contain our design (specifications, drawings)
- **Proposals will be solicited from a variety of equipment suppliers**
 - Their submissions will need to conform to our design
 - Proposals will be solicited from a variety of equipment suppliers
- **Equipment supplier submissions will be evaluated by CBCL, Municipal Affairs, and DOEC**
 - Weighted evaluation of suppliers (cost, parts, service etc)
- **Site designs for each location will be completed and tender packages prepared.**
 - Multiple sites will be included in a single tender

Critical Factors for Success

- **Excluding socioeconomic factors there are several key factors to overall success:**
 - Treated water quality (short term)
 - Perceived benefit (short term)
 - Reliability (short and long term)
 - Trained operator (long term)
 - Adequate O&M financing (long term)

Questions
