

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality				
Admirals Beach	Admiral's Beach	2 Well Fields	Nov 21, 2025	0.22	LTD	LTD	1.60
Appleton	Appleton (+Glenwood)	Gander Lake (The Outflow)	Nov 26, 2025	0.01	0.11	LTD	6.90
Badger	Badger	Well Field, 2 wells on standby	Nov 25, 2025	0.19	LTD	LTD	LTD
Baine Harbour	Baine Harbour	Dug	Nov 19, 2025	0.03	0.12	LTD	1.00
Barachois Brook	Barachois Brook	Drilled	Nov 10, 2025	0.12	0.08	0.01	0.66
Bauline	Bauline	#1 Brook Path Well	Nov 13, 2025	0.05	LTD	LTD	5.10
Bay Roberts	Bay Roberts	Rocky Pond	Dec 18, 2025	0.01	0.07	LTD	2.10
Bay St. George South	Jeffrey's	#1 Well Jeffery's (Joe Curnew)	Nov 20, 2025	1.00	LTD	LTD	LTD
Bay St. George South	Robinson's	#1 Well Robinson's (Louie MacDonald)	Nov 20, 2025	0.18	2.00	LTD	LTD
Bay St. George South	St. Fintan's, St. David's	#1 Well St. Fintan's (The Y)	Nov 20, 2025	0.38	0.05	LTD	LTD
Bay St. George South	Jeffrey's	#2 Well Jeffery's (Calvin Madore)	Nov 20, 2025	1.30	0.05	LTD	0.61
Bay St. George South	St. Fintan's	#2 Well St. Fintan's (Louis King)	Nov 20, 2025	0.28	1.20	LTD	0.55
Bay St. George South	McKay's	#2B Lions Club Well	Nov 20, 2025	0.84	LTD	LTD	LTD
Bay St. George South	Highlands	#3 Brian Pumphrey Well Highlands	Nov 20, 2025	2.80	LTD	LTD	LTD
Bay St. George South	Jeffrey's	#3 Well Jeffery's (Sid Shears)	Nov 20, 2025	2.90	LTD	LTD	1.40
Bay St. George South	Robinson's	#3 Well Robinson's (Gales)	Nov 20, 2025	0.37	LTD	LTD	LTD
Bay St. George South	McKay's	#3 Woodworth Well McKay's	Nov 20, 2025	0.22	LTD	LTD	0.78
Bay St. George South	Jeffrey's	#4 Well Jeffery's - Jack Harris	Nov 20, 2025	0.53	LTD	LTD	0.93
Bay St. George South	Lock Leven	#6 Well Loch Leven (Jerry Quilty)	Dec 02, 2025	0.16	0.35	LTD	LTD
Bay St. George South	McKay's	#7 Well McKay's (Gordon Hulan)	Nov 20, 2025	0.47	LTD	LTD	1.80
Beaches	Beaches	Grassey Pond Brook	Nov 18, 2025	0.02	LTD	LTD	9.50
Bear Cove	Bear Cove	Lower Bear Cove	Nov 05, 2025	0.05	LTD	LTD	5.70
Bear Cove	Bear Cove	Upper Bear Cove	Nov 05, 2025	0.16	LTD	LTD	5.50
Benoit's Siding	Doyles	# 2 Well Doyles	Nov 25, 2025	1.70	LTD	LTD	LTD
Benoit's Siding	Benoit's Siding (aka Bennett's Siding)	Drilled	Nov 25, 2025	0.77	0.90	LTD	LTD
Birchy Bay	Birchy Bay	Jumper's Pond	Nov 18, 2025	0.02	0.08	LTD	11.00
Bishop's Falls	Bishop's Falls	Northern Arm Lake	Nov 03, 2025	0.01	LTD	LTD	2.00
Black Duck	Black Duck (Siding)	#1 Well	Dec 12, 2025	0.11	0.15	LTD	LTD
Blaketown	Blaketown South	#1 Selby Mercer Well	Nov 06, 2025	0.06	1.20	LTD	LTD
Blaketown	Blaketown	#2 Daphne Pincen Well	Nov 06, 2025	0.09	0.55	LTD	0.97
Blaketown	Blaketown Centre	#3 Fred Osborne Well	Nov 06, 2025	0.06	0.06	LTD	2.10

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units Guidelines for Canadian Drinking Water Quality	mg/L 7	mg/L 10	mg/L 1	mg/L
Blaketown	Blaketown Centre	#3 Fred Osborne Well	Nov 26, 2025	0.06	LTD	LTD	1.70
Blaketown	Blaketown North	#4 Hilda Barrett Well	Nov 06, 2025	0.12	LTD	LTD	0.54
Branch	Branch	Drilled Wells	Dec 08, 2025	0.24	0.53	LTD	LTD
Branch	Branch	Drilled Wells	Dec 19, 2025	0.27	0.67	LTD	LTD
Brent's Cove	Brent's Cove	Paddy's Pond	Nov 13, 2025	0.02	0.35	LTD	LTD
Brigus South	Forge Hill area	#1 Well Forge Hill	Nov 19, 2025	0.37	LTD	LTD	2.50
Brigus South	Near highway	#3 Well Main Road	Nov 19, 2025	LTD	0.09	LTD	LTD
Bryant's Cove	Bryant's Cove South Side	#1 Well - Bert James Well #2 Well - Baxter Bowering Well	Nov 10, 2025	0.04	0.19	0.02	1.20
Bunyan's Cove	Bunyan's Cove	#1 Wellfield	Dec 10, 2025	0.06	0.34	LTD	3.10
Burlington	Burlington	Eastern Island Pond	Nov 12, 2025	0.01	0.12	LTD	13.00
Burlington	Burlington	Eastern Island Pond	Nov 12, 2025	0.01	0.09	LTD	13.00
Burlington	Burlington	Eastern Island Pond	Nov 12, 2025	0.01	LTD	LTD	13.00
Canning's Cove	Lower Canning's Cove	#1 Well - Pleman Pitts	Dec 10, 2025	0.23	0.11	LTD	0.54
Canning's Cove	Upper Canning's Cove	#2 Well - Eugene Ellis	Dec 10, 2025	0.11	0.11	LTD	1.30
Canning's Cove	Centre Canning's Cove	#3 Well - Glenda Penney	Dec 10, 2025	0.03	0.45	LTD	LTD
Cartwright	Cartwright	Burdett's Pond	Nov 26, 2025	0.01	LTD	LTD	13.00
Cartwright	Cartwright - PWDU	Burdett's Pond	Nov 26, 2025	LTD	LTD	LTD	LTD
Castor River South	Castor River South	Unnamed	Nov 06, 2025	0.04	0.18	LTD	4.60
Cavendish	North Side Cavendish	#1 Well - Max Bishop	Dec 02, 2025	0.13	2.10	LTD	0.82
Cavendish	North Side Cavendish	#2 Well - Tom Critch	Dec 02, 2025	0.17	LTD	LTD	2.70
Chance Cove	Lower Cove	#5B Albert Rowe Well	Nov 06, 2025	0.39	0.08	LTD	1.90
Chance Cove	Upper Cove	Hollett's Well	Nov 06, 2025	0.02	0.12	LTD	1.40
Chance Cove	New Housing Area	New Housing Area Well	Nov 06, 2025	0.52	0.26	LTD	1.40
Chance Cove	Back Cove Area	Olive Smith Well	Nov 06, 2025	0.12	0.47	LTD	0.77
Change Islands	Change Islands - PWDU	#1 Fox Cove Well	Dec 08, 2025	0.00	LTD	LTD	LTD
Channel-Port aux Basques	Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Dec 01, 2025	0.01	LTD	LTD	2.20
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Nov 26, 2025	0.01	LTD	LTD	12.00
Charlottetown (Labrador)	Charlottetown (Labrador) - PWDU	Middle Pond	Nov 26, 2025	LTD	LTD	LTD	LTD
Churchill Falls	Churchill Falls	Smallwood Reservoir	Oct 21, 2025	0.01	LTD	LTD	2.90
Clareville	Clareville, Shoal Harbour	Shoal Harbour River	Dec 12, 2025	0.01	0.05	LTD	2.10
Clarke's Beach	Otterbury	#1 Well - Quinlon Well	Dec 19, 2025	0.23	LTD	LTD	LTD
Clarke's Beach	Otterbury	#2 Well - Delaney Well	Dec 19, 2025	0.10	0.07	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality 7	mg/L 10	mg/L 1	mg/L
Colliers	Merrigan's Lane + Main Rd	#2 Well - Merrigan's Well	Nov 27, 2025	0.24	0.14	LTD	LTD
Colliers	Harbour Drive & Main Road	#3 Well - Griffin's Well	Nov 27, 2025	0.18	0.32	LTD	0.74
Colliers	Harbour Drive	#4 Well - Flynn's Well	Nov 27, 2025	0.06	0.69	LTD	LTD
Colliers	Harbour Drive	#5 Well - Whalen's Well	Nov 27, 2025	0.12	1.10	LTD	LTD
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	Nov 26, 2025	0.01	0.06	LTD	1.50
Conception Harbour	Cemetery Road & Main Road	Cemetery Road Well	Nov 27, 2025	0.08	0.22	LTD	0.63
Conception Harbour	Lower Bacon Cove	Lower Bacon Cove Well	Nov 13, 2025	0.68	0.25	0.01	0.83
Conception Harbour	Upper Bacon Cove, Kitchuses	Upper Bacon Cove Well	Nov 27, 2025	0.34	0.14	LTD	LTD
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Nov 10, 2025	0.02	0.06	0.01	1.80
Cox's Cove	Upper Area	Upper Area Wellfield	Dec 02, 2025	0.47	LTD	LTD	0.50
Deadman's Bay	Deadman's Bay	Deadman's Pond	Nov 26, 2025	0.00	LTD	LTD	8.60
Eastport	Eastport (+Sandy Cove)	Dug	Dec 10, 2025	0.03	0.36	LTD	LTD
Fermeuse	Fermeuse	Port Kirwan Road Well	Nov 20, 2025	0.13	0.87	LTD	LTD
Flat Bay	Flat Bay (East)	#1 Well	Nov 10, 2025	0.07	LTD	LTD	0.69
Flat Bay	Flat Bay (East)	#3 Well	Nov 10, 2025	0.43	1.10	LTD	0.98
Flat Bay West	Flat Bay West	#3 Well	Nov 10, 2025	0.07	0.93	LTD	0.59
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Nov 12, 2025	0.01	0.09	LTD	9.70
Forteau	Forteau	Trout Brook	Nov 27, 2025	0.03	0.09	LTD	3.40
Fox Roost-Margaree	Fox Roost-Margaree	Drilled Well and Margaree Pond	Dec 01, 2025	0.01	0.06	LTD	17.00
Fox Roost-Margaree	Fox Roost-Margaree - PWDU	Drilled Well and Margaree Pond	Dec 01, 2025	LTD	LTD	LTD	LTD
Frenchman's Cove	Frenchman's Cove	Dug Well	Nov 18, 2025	0.02	LTD	LTD	4.30
Freshwater	Freshwater (Carbonear)	#2 Well - Covage's Lane Well	Dec 16, 2025	0.06	0.18	LTD	LTD
Freshwater	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	Dec 16, 2025	0.57	1.20	LTD	LTD
Gander	Gander	Gander Lake	Nov 26, 2025	0.01	0.16	LTD	5.30
Gaskiers	Gaskiers-Point La Haye - PWDU	Well	Nov 21, 2025	0.06	LTD	LTD	LTD
Georgetown	Georgetown	Drilled	Nov 26, 2025	0.09	0.38	LTD	LTD
Glenburnie-Birchy Head-Shoal Brook	Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Nov 17, 2025	0.01	LTD	LTD	7.70
Grand Bank	Grand Bank (Backup Supply)	Grand Bank Brook (Backup Supply)	Oct 09, 2025	0.03	LTD	LTD	5.30
Grand Falls-Windsor	Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Nov 03, 2025	0.01	LTD	LTD	2.00
Grates Cove	Grates Cove Centre	#1C Well	Nov 27, 2025	0.09	0.06	LTD	0.54

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality 7	mg/L 10	mg/L 1	mg/L
Grates Cove	Grates Cove North End	#3 Frank Janes Well	Nov 27, 2025	0.06	LTD	LTD	1.50
Grates Cove	Grates Cove South End	#4 Stoyles Hill Well	Nov 27, 2025	0.05	0.24	LTD	0.60
Great Codroy	Great Codroy East	#1 Well	Nov 25, 2025	3.00	0.07	LTD	LTD
Great Codroy	Great Codroy West	#2 Well	Nov 25, 2025	0.43	0.07	LTD	LTD
Green Island Brook	Green Island Brook	Green Island Brook	Nov 05, 2025	0.02	LTD	LTD	8.60
Hampden	Hampden	Elliot Brook	Nov 18, 2025	0.05	LTD	0.01	7.00
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	Nov 03, 2025	0.02	0.06	0.02	1.20
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	Nov 03, 2025	0.04	LTD	0.01	1.40
Harbour Grace	Thickett	#1 Thickett Susie Galway Well	Dec 19, 2025	0.02	0.44	LTD	LTD
Harbour Grace	Thickett	#2 Thickett New Well	Dec 02, 2025	0.07	0.35	LTD	LTD
Harbour Grace	Riverhead	Mercer's Rd. Well	Dec 02, 2025	0.03	0.40	LTD	LTD
Harbour Grace	Harbour Grace South Lower	New Southside Well (Well#3)	Dec 19, 2025	0.11	LTD	LTD	LTD
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Dec 19, 2025	0.08	LTD	LTD	LTD
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Flynn's Hill Well	Nov 13, 2025	0.16	0.50	0.01	1.50
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Holden's Road Well	Nov 13, 2025	0.11	1.30	LTD	0.80
Harry's Harbour	Harry's Harbour	#1C Well - Northeast Well	Nov 20, 2025	0.05	0.07	LTD	0.88
Harry's Harbour	Harry's Harbour	#2 Well - Northwest Hill / Country Road	Nov 20, 2025	0.15	0.14	LTD	1.00
Harry's Harbour	Harry's Harbour	#3 Well - South Well	Nov 20, 2025	0.09	0.17	LTD	LTD
Heart's Content	Heart's Content	Southern Cove Pond	Dec 02, 2025	0.00	LTD	LTD	4.20
Heart's Desire	Heart's Desire	Terrence Pond	Oct 08, 2025	0.01	LTD	LTD	3.00
Heart's Desire	Heart's Desire	Terrence Pond	Oct 08, 2025	0.01	LTD	LTD	2.90
Heart's Desire	Heart's Desire	Terrence Pond	Oct 08, 2025	0.01	LTD	LTD	3.00
Holyrood	Holyrood	Main Line	Nov 13, 2025	0.12	0.22	LTD	1.60
Holyrood	Holyrood	O'Connell's Well	Nov 13, 2025	0.39	LTD	LTD	3.00
Holyrood	Holyrood	Woodford Station - Healey's Well and Quinlan's Well	Nov 13, 2025	0.39	0.08	LTD	3.00
Hopeall	Hopeall	Charles Cumby Well	Dec 02, 2025	0.07	0.36	LTD	LTD
Hopeall	Gilberts Hill	Gilberts Hill Well	Dec 02, 2025	0.07	0.96	LTD	LTD
Hopedale	Hopedale	American Pond	Oct 14, 2025	0.01	LTD	LTD	4.60
Humber Arm South	Frenchman's Cove Area	Gurges Pond	Nov 06, 2025	0.05	LTD	LTD	4.00
Isle aux Morts	Isle aux Morts	Burnt Ground Pond	Oct 08, 2025	0.01	0.06	LTD	14.00
Isle aux Morts	Isle aux Morts	Burnt Ground Pond	Oct 08, 2025	0.01	0.06	LTD	14.00
Isle aux Morts	Isle aux Morts	Burnt Ground Pond	Oct 08, 2025	0.01	0.06	LTD	15.00

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality 7	mg/L 10	mg/L 1	mg/L
Jackson's Arm	Jackson's Arm	Unnamed Brook	Nov 18, 2025	0.03	LTD	LTD	8.20
Jackson's Arm	Jackson's Arm - PWDU	Unnamed Brook	Nov 18, 2025	LTD	LTD	LTD	LTD
Jackson's Cove-Langdon's Cove-Silverdale	Langdon's Cove	#3 Well Langdon's Cove Well	Nov 20, 2025	0.11	LTD	LTD	0.77
Jean de Baie	Jean de Baie	#1 Well	Nov 19, 2025	0.08	0.22	LTD	0.72
Kippens	Kippens	Well Field	Dec 04, 2025	0.10	0.18	LTD	LTD
L'Anse au Clair	L'Anse au Clair	Park Pond	Nov 26, 2025	0.03	0.15	LTD	2.50
L'Anse au Loup	L'Anse au Loup	L'anse Au Loup River	Nov 27, 2025	0.01	0.09	LTD	2.90
Labrador City	Labrador City	Beverly Lake	Oct 22, 2025	0.01	LTD	LTD	1.70
Lance Cove	Lance Cove	Local Service District Well	Nov 21, 2025	1.30	0.43	LTD	0.65
Lewisporte	Lewisporte	Stanhope Pond	Nov 05, 2025	0.02	LTD	LTD	7.50
Mainland	Mainland	Caribou Brook	Nov 28, 2025	0.07	0.21	LTD	2.30
Makinsons	Turkswater & Hodgewater Line West	Country Path Wells	Nov 26, 2025	0.03	0.05	LTD	LTD
Makinsons	Hodgewater Line East & Juniper Stump	Taylor's Wells	Nov 26, 2025	0.60	LTD	LTD	1.10
Makkovik	Makkovik	Ranger Bight Pond	Oct 14, 2025	0.02	LTD	LTD	6.00
Makkovik	Makkovik - PWDU	Ranger Bight Pond	Oct 14, 2025	0.01	LTD	LTD	LTD
Mary's Harbour	Mary's Harbour - PWDU	St. Mary's River	Nov 27, 2025	LTD	0.05	LTD	LTD
Mary's Harbour	Mary's Harbour	St. Mary's River	Nov 27, 2025	0.01	LTD	LTD	10.00
Marystown	Marystown	Fox Hill Reservoir / Clam Pond	Nov 17, 2025	0.01	LTD	LTD	2.30
Marysvale	Marysvale, Long Pond	Drilled	Nov 26, 2025	0.03	0.07	LTD	LTD
Mattis Point	Mattis Point	Drilled	Nov 10, 2025	0.11	LTD	LTD	0.77
McCallum	McCallum	Drilled	Dec 04, 2025	0.04	LTD	LTD	23.00
Ming's Bight	Ming's Bight	Middle Brook Pond	Nov 13, 2025	0.01	LTD	LTD	6.00
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	Nov 26, 2025	0.01	0.06	LTD	1.60
Nain	Nain	Trouser Lake	Oct 14, 2025	0.01	LTD	LTD	2.20
Natuashish	Natuashish (Sango Bay)	Sango Brook and Wellfield	Nov 09, 2025	0.12	0.10	LTD	0.96
New Harbour	New Harbour	Williams Hill Well	Nov 26, 2025	0.14	0.08	LTD	LTD
Norris Arm	Norris Arm (south)	Mill Lake	Nov 05, 2025	0.01	LTD	LTD	5.20
North West River	North West River	Wellfield (Well # 1 & Well # 2)	Nov 03, 2025	0.19	LTD	LTD	0.81
O'Donnells	O'Donnell's	Well Field	Nov 21, 2025	0.08	0.18	LTD	LTD
O'Regans East	O'Regan's East	Drilled	Nov 25, 2025	0.29	0.83	LTD	0.73
Paradise	Paradise	Bay Bulls Big Pond	Nov 26, 2025	0.01	0.06	LTD	1.60
Petley	Petley	Drilled + Dug Reservoir	Dec 09, 2025	1.50	0.08	LTD	1.40

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L 7 Guidelines for Canadian Drinking Water Quality	mg/L 10	mg/L 1	mg/L
Petty Harbour-Maddox Cove	Petty Harbour-Maddox Cove	Western Barrens Pond	Nov 18, 2025	0.01	LTD	LTD	3.40
Piccadilly Head	Piccadilly Head (+West Bay)	Unnamed Brook	Nov 26, 2025	0.00	LTD	LTD	13.00
Piccadilly Slant-Abraham's Cove	Piccadilly Slant	#1 Well - Piccadilly Slant	Dec 11, 2025	0.26	0.28	LTD	1.20
Piccadilly Slant-Abraham's Cove	Abraham's Cove	#2 Well - Abraham's Cove	Dec 11, 2025	0.09	1.90	LTD	3.40
Point of Bay	Point of Bay	Indian Cove Pond	Nov 17, 2025	0.01	LTD	LTD	7.70
Port Blandford	Port Blandford	Noseworthy's Pond	Dec 10, 2025	0.02	0.09	LTD	5.90
Port Kirwan	Port Kirwan	Developed Spring	Nov 20, 2025	0.03	0.43	LTD	LTD
Port au Port East	Port au Port East	Drilled Well - 75-80% Berry Head Watershed - 20-25%	Dec 09, 2025	0.11	0.24	LTD	1.40
Port au Port West-Aguathuna-Felix Cove	Port au Port West, Aguathuna	#1 & #3 & #6 FatherJoy's Well	Dec 09, 2025	0.43	0.08	LTD	1.00
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#4-Goose Pond Road Well	Dec 12, 2025	0.19	0.20	LTD	0.95
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#5 Ocean View Drive Well	Dec 12, 2025	0.01	0.17	LTD	0.95
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	Nov 26, 2025	0.01	0.06	LTD	1.60
Postville	Postville - PWDU	Big Pond	Oct 14, 2025	LTD	LTD	LTD	LTD
Postville	Postville	Big Pond	Oct 14, 2025	0.01	LTD	LTD	6.70
Pouch Cove	Pouch Cove	North Three Island Pond	Nov 13, 2025	0.00	LTD	LTD	1.70
Raleigh	Raleigh	#4 Well	Nov 05, 2025	0.19	LTD	LTD	6.40
Ramea	Ramea	Northwest Pond	Dec 02, 2025	0.03	LTD	LTD	4.50
Ramea	Ramea - PWDU	Northwest Pond	Dec 02, 2025	0.02	LTD	LTD	2.50
Random Sound West	North West Brook, Ivany Cove	#2 Well	Dec 08, 2025	0.08	1.10	LTD	0.54
Random Sound West	North West Brook, Ivany Cove	#3 Well - Harbour Well	Dec 08, 2025	0.08	0.23	LTD	3.90
Red Bay	Red Bay	Northern Brook	Nov 27, 2025	0.01	LTD	LTD	5.30
Red Harbour	Red Harbour	1A Well Drilled + 1C Dug Well (back-up)	Nov 19, 2025	0.51	0.11	LTD	1.40
Reidville	Reidville	Humber Canal, Grand Lake	Nov 04, 2025	0.02	0.09	LTD	3.60
Renews-Cappahayden	Cappahayden	#1 Dinn's Well	Nov 19, 2025	0.28	LTD	LTD	LTD
Rigolet	Rigolet	Rigolet Pond	Oct 14, 2025	0.02	LTD	LTD	14.00
Rigolet	Rigolet - PWDU	Rigolet Pond	Oct 14, 2025	LTD	LTD	LTD	LTD
Sandringham	Sandringham	Drilled	Dec 10, 2025	0.04	0.89	LTD	0.63
Sandy Cove	Sandy Cove	Dug	Dec 10, 2025	0.03	0.37	LTD	LTD
Sheaves Cove	Sheaves Cove	Drilled	Dec 10, 2025	0.26	0.28	LTD	1.10
Sheppardville	Sheppardville	Drilled	Nov 26, 2025	0.05	LTD	LTD	2.00
Sheshatshiu	Sheshatshui - Indian Band Council	Wells 1, 2 & 3	Nov 03, 2025	0.17	0.16	LTD	1.20

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Served Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality 7	mg/L 10	mg/L 1	mg/L
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#1 Well - PJ's Variety Well	Dec 10, 2025	0.34	0.08	LTD	1.60
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#2 Well - Howard & Rodney Jesso Well	Dec 10, 2025	0.28	0.08	LTD	1.20
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#4B Well - Nancy Rowe Well	Dec 10, 2025	0.47	0.25	LTD	4.10
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#5 Well - Murdock Wheeler Well	Dec 10, 2025	0.13	0.30	LTD	0.70
Ship Cove-Lower Cove-Jerry's Nose	Lower Cove	#6 Well - Lower Cove Well	Dec 10, 2025	0.17	0.65	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Adam's Cove	#1 Well - Reg Bursey Well	Nov 28, 2025	0.37	0.22	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#10 Well - Cantwood Hill Well	Nov 28, 2025	0.79	0.14	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Blackhead + Adam's Cove	#4 Well - Leonard King Well	Nov 28, 2025	0.13	0.21	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#6 Well - Herb Trickett Well	Nov 28, 2025	0.54	0.31	LTD	0.58
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#8 Well - Effie Flight Wells	Nov 28, 2025	0.23	1.70	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#9 Well - Walter Reynolds Well	Nov 28, 2025	0.03	1.80	LTD	LTD
Smith's Sound	Harcourt-Monroe-Waterville	Developed Spring	Dec 05, 2025	0.05	0.13	LTD	LTD
South Dildo	South Dildo	#5 Well - Calvin Reid Well	Nov 26, 2025	0.09	LTD	LTD	LTD
Springdale	Springdale Industrial Park	Well	Nov 20, 2025	0.11	0.20	LTD	LTD
St. Alban's	St. Alban's	Well Field	Nov 12, 2025	0.01	0.10	LTD	22.00
St. Andrews	St. Andrew's	#1 Well	Nov 25, 2025	0.68	0.79	LTD	2.90
St. Andrews	St. Andrew's	#2 Well	Nov 25, 2025	0.31	LTD	LTD	0.94
St. Andrews	St. Andrew's East	#3 Well	Nov 25, 2025	0.14	0.51	LTD	3.10
St. Andrews	Air Strip Road	#4 Well Strip Road Well	Nov 25, 2025	0.67	LTD	LTD	LTD
St. Anthony	St. Anthony	St. Anthony Pond	Nov 05, 2025	0.01	0.07	LTD	6.40
St. George's	St. George's	Wellfield	Nov 10, 2025	0.11	0.15	LTD	0.89
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Nov 25, 2025	0.01	0.07	LTD	1.60
St. John's	St. John's	Petty Harbour Long Pond	Nov 25, 2025	0.01	LTD	LTD	1.50
St. John's	St. John's	Windsor Lake	Nov 25, 2025	0.01	LTD	LTD	1.90
St. Joseph's	St. Joseph's S.M.B.	Drilled	Nov 21, 2025	0.11	LTD	LTD	1.10
St. Lewis	St. Lewis	Tub Harbour Pond	Nov 27, 2025	0.01	LTD	LTD	13.00
St. Lunaire-Griquet	St. Lunaire-Griquet	Drilled	Nov 05, 2025	0.11	LTD	LTD	4.10
St. Mary's	St. Mary's	Wellfield	Nov 21, 2025	0.11	LTD	LTD	LTD
St. Patricks	St. Patricks	David Joy Well	Nov 20, 2025	0.07	0.09	LTD	LTD
St. Pauls	St. Pauls	Two Mile Pond	Nov 18, 2025	0.06	0.12	LTD	7.90
Stephenville	Stephenville	Well Field	Dec 04, 2025	0.15	0.19	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality 7	mg/L 10	mg/L 1	mg/L
Stephenville Crossing	Stephenville Crossing	Well Fields 1 & 2	Dec 04, 2025	0.09	0.36	LTD	LTD
Sunnyside (T.B.)	Sunnyside	Center Cove River	Nov 03, 2025	0.01	LTD	LTD	9.50
Swift Current	Swift Current (Hollett's Point)	Drilled	Nov 20, 2025	0.04	LTD	LTD	6.00
Terrenceville	Terrenceville	Big Brook	Nov 17, 2025	0.00	LTD	LTD	6.50
Tompkins	Tompkins	Greg Wall Well	Nov 25, 2025	0.22	0.28	LTD	LTD
Torbay	Torbay	North Pond	Nov 13, 2025	0.01	0.08	LTD	3.20
Trout River	Trout River	Feeder Brook	Nov 17, 2025	0.02	0.17	LTD	3.30
Upper Ferry	Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	Nov 25, 2025	0.08	1.50	LTD	LTD
Upper Ferry	Upper Ferry - Middle	#2 Well - Hughie MacIassac Well	Nov 25, 2025	0.17	0.18	LTD	LTD
Upper Ferry	Upper Ferry - Upper	#3 Well - Marshall Devoe Well	Nov 25, 2025	0.19	0.28	LTD	LTD
Upper Ferry	Upper Ferry	#4 Well - Angus MacNeil Well	Nov 25, 2025	0.38	LTD	LTD	LTD
Wabana	Wabana - PWDU	#3 Yard West Mines Road	Nov 21, 2025	LTD	LTD	LTD	LTD
Wabana	Wabana	#3 Yard West Mines Road	Nov 21, 2025	0.53	LTD	LTD	4.60
Wabana	Wabana	Mixed Supplies	Nov 21, 2025	0.41	LTD	LTD	1.70
Wabana	Wabana	Mixed Supplies	Nov 21, 2025	0.43	LTD	LTD	1.60
Wabana	Wabana	Mixed Supplies	Nov 21, 2025	0.44	LTD	LTD	1.50
Wabana	Wabana	Normore Crescent East #1	Nov 21, 2025	0.76	LTD	LTD	3.10
Wabana	Wabana	Quigley's Line	Nov 21, 2025	0.71	LTD	LTD	3.20
Wabana	Wabana	Scotia #1	Nov 21, 2025	0.31	LTD	LTD	3.80
Wabana	Wabana	St. Edward's Memorial St.	Nov 21, 2025	0.08	0.05	LTD	LTD
Wabush	Wabush	Wahnahnish Lake	Oct 22, 2025	0.02	LTD	LTD	3.20
West St. Modeste	West St. Modeste	Well Field	Nov 27, 2025	0.07	LTD	LTD	4.00
Westport	Westport	Western Brook Pond	Nov 12, 2025	0.01	0.08	LTD	13.00
Winterland	Winterland	Well Field	Nov 18, 2025	0.14	0.83	LTD	LTD
Woody Point	Woody Point	Winterhouse Brook	Nov 17, 2025	0.01	0.11	LTD	3.50

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
		Guidelines for Canadian Drinking Water Quality		7	10	1	

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

This report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ. Guidelines have not been developed for all the parameters listed in this report.

Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant Exceedances

Strontium: The maximum acceptable concentration for strontium is 7.0 mg/L. Strontium may enter drinking water from naturally occurring deposits or as a result of human activity, such as mining or other industries. High levels of this contaminant can cause adverse health effects for some people.

Nitrate: The maximum acceptable concentration for nitrate is 10 mg/L as nitrate-nitrogen. Nitrate is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

Nitrite: The maximum acceptable concentration for nitrite is 1 mg/L as nitrite-nitrogen. Nitrite is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

mg/L = milligrams per litre or parts per million TOC = total organic carbon