Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Anchor Point	Anchor Point	Well Cove Brook	Feb 04, 2026	0.03	0.05	LTD	9.70
Appleton	Appleton (+Glenwood)	Gander Lake (The Outflow)	Feb 25, 2026	0.01	0.10	LTD	7.10
Aquaforte	Aquaforte	Davies Pond	Jan 29, 2026	0.01	0.05	LTD	6.90
Arnold's Cove	Arnold's Cove	Steve's Pond (2 Intakes)	Jan 22, 2026	0.00	LTD	LTD	6.00
Avondale	Avondale	Lees Pond	Jan 26, 2026	0.01	LTD	LTD	3.90
Baie Verte	Baie Verte	Southern Arm Pond	Feb 10, 2026	0.01	LTD	LTD	7.00
Baine Harbour	Baine Harbour	Baine Harbour Pond	Mar 10, 2026	0.02	LTD	LTD	2.90
Bartletts Harbour	Bartletts Harbour	Long Pond (same as Castors River North)	Feb 05, 2026	0.03	LTD	LTD	7.30
Bay L'Argent	Bay L'Argent	Sugarloaf Hill Pond	Mar 10, 2026	0.01	LTD	LTD	6.30
Bay L'Argent	Bay L'Argent	Sugarloaf Hill Pond	Mar 19, 2026	0.01	LTD	LTD	5.10
Bay Roberts	Bay Roberts	Rocky Pond	Jan 30, 2026	0.01	0.08	LTD	2.30
Bay de Verde	Bay de Verde	Island Pond	Feb 11, 2026	0.01	LTD	LTD	4.30
Beaches	Beaches	Grassey Pond Brook	Mar 04, 2026	0.02	LTD	LTD	7.80
Beachside	Beachside	Long Pond	Feb 18, 2026	0.01	0.07	LTD	5.90
Bellburns	Bellburns	Bound Brook Tributary	Feb 11, 2026	0.04	0.28	LTD	4.60
Belleoram	Belleoram	Rabbits Pond	Feb 04, 2026	0.01	LTD	LTD	8.00
Bellevue	Bellevue	Big Pond	Feb 12, 2026	0.02	0.14	LTD	5.90
Bellevue Beach	Bellevue Beach	Unnamed Brook	Feb 12, 2026	0.01	LTD	LTD	6.10
Benton	Benton	Little Pond	Mar 02, 2026	0.02	LTD	LTD	15.00
Birchy Bay	Birchy Bay	Jumper's Pond	Jan 26, 2026	0.02	0.15	LTD	10.00
Bird Cove	Bird Cove (+Brig Bay)	Inner Gilmour Pond	Feb 04, 2026	0.02	0.09	LTD	8.70
Bishop's Falls	Bishop's Falls	Northern Arm Lake	Jan 20, 2026	0.01	0.09	LTD	1.90
Black Duck Cove	Black Duck Cove	Long Pond - Black Duck Cove Intake	Feb 04, 2026	0.03	LTD	LTD	13.00
Bonavista	Bonavista	Long Pond	Jan 20, 2026	0.01	LTD	LTD	5.90
Botwood	Botwood	Northern Arm Lake	Jan 20, 2026	0.01	LTD	LTD	1.90
Branch	Branch	Drilled Wells	Mar 10, 2026	0.24	0.50	LTD	LTD
Brent's Cove	Brent's Cove	Paddy's Pond	Feb 11, 2026	0.01	0.17	LTD	16.00
Brig Bay	Brig Bay	Inner Gilmour Pond	Feb 04, 2026	0.02	0.06	LTD	8.70
Brighton	Brighton	Hynes Cove Pond	Feb 26, 2026	0.01	LTD	LTD	7.00
Brigus	Brigus (+Cupids, +South River)	Brigus Long Pond (to Brigus)	Feb 05, 2026	0.01	LTD	LTD	4.70
Buchans	Buchans	Buchans Lake aka Sandy Lake	Feb 25, 2026	0.01	0.06	LTD	7.10
Buchans Junction	Buchans Junction	Lapland Pond	Feb 25, 2026	0.02	0.09	LTD	8.60

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Burgeo	Burgeo	Long Pond	Feb 19, 2026	0.01	0.11	LTD	11.00
Burgeo	Burgeo	Long Pond	Mar 26, 2026	0.00	LTD	LTD	6.80
Burgeo	Burgeo	Long Pond	Mar 26, 2026	0.00	LTD	0.02	6.80
Burgeo	Burgeo	Long Pond	Mar 26, 2026	0.00	LTD	LTD	6.40
Burgoyne's Cove	Burgoyne's Cove	Lower Rocky Pond	Jan 19, 2026	0.01	LTD	LTD	2.50
Burin	Burin (+Lewin's Cove)	Big Pond	Mar 10, 2026	0.01	LTD	LTD	4.60
Burin	Port au Bras	Gripe Cove Pond	Mar 10, 2026	0.02	0.06	LTD	4.00
Burin	Burin	Long Pond	Mar 10, 2026	0.01	0.07	LTD	4.10
Burlington	Burlington	Eastern Island Pond	Feb 10, 2026	0.01	LTD	LTD	12.00
Burnt Islands	Burnt Islands	Long Lake	Feb 04, 2026	0.01	0.08	LTD	7.50
Burnt Islands	Burnt Islands - PWDU	Long Lake	Feb 04, 2026	LTD	LTD	LTD	LTD
Campbellton	Campbellton	Indian Arm Brook	Jan 20, 2026	0.01	LTD	LTD	7.80
Cape Freels North	Cape Freels North	Long Pond	Mar 02, 2026	0.01	0.06	LTD	14.00
Cape St. George	Cape St. George, Red Brook, De-Grau, Marches Point	Rouzes Brook	Mar 10, 2026	0.05	0.28	LTD	2.20
Caplin Cove-Southport	Southport	Button's Pond	Mar 04, 2026	0.01	LTD	LTD	6.10
Carbonear	Carbonear	Little Island Pond	Feb 05, 2026	0.01	LTD	LTD	3.70
Carmanville	Carmanville	Grandfathers Pond	Feb 25, 2026	0.01	0.06	LTD	5.20
Castor River North	Castor River North	Long Pond (same as Bartletts Harbour)	Feb 05, 2026	0.03	LTD	LTD	7.70
Castor River South	Castor River South	Unnamed	Feb 05, 2026	0.04	0.35	LTD	2.50
Cavendish	Cavendish	Long Pond	Jan 29, 2026	0.01	0.06	LTD	4.90
Centreville-Wareham-Trinity	Centreville-Wareham	Northwest Pond	Mar 03, 2026	0.01	LTD	LTD	7.80
Centreville-Wareham-Trinity	Trinity	Southwest Feeder Pond	Mar 03, 2026	0.00	LTD	LTD	6.60
Chanceport	Chanceport	Bridger's Cove Pond	Feb 17, 2026	0.03	0.15	LTD	11.00
Channel-Port aux Basques	Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Feb 04, 2026	0.01	0.07	LTD	1.70
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Mar 02, 2026	0.01	LTD	LTD	14.00
Charlottetown (Labrador)	Charlottetown (Labrador) - PWDU	Middle Pond	Mar 02, 2026	LTD	0.09	LTD	LTD
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Mar 20, 2026	0.01	0.06	LTD	14.00
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Mar 20, 2026	0.01	LTD	LTD	14.00
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Mar 20, 2026	0.01	0.09	LTD	14.00
Clarenville	Clarenville, Shoal Harbour	Shoal Harbour River	Mar 05, 2026	0.01	0.11	LTD	2.10
Clarke's Beach	Clarkes Beach	Clarkes Pond	Jan 30, 2026	0.01	LTD	LTD	3.20
Come By Chance	Come By Chance	Butchers Brook	Jan 22, 2026	0.01	LTD	LTD	LTD

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Comfort Cove-Newstead	Comfort Cove-Newstead	Steady Cove Pond	Jan 26, 2026	0.02	0.05	LTD	8.50
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	Mar 05, 2026	0.01	LTD	LTD	1.80
Conche	Conche	Martin's Brook	Feb 03, 2026	0.03	LTD	LTD	13.00
Conne River	Conne River	Southwest Brook	Feb 16, 2026	0.00	0.11	LTD	LTD
Cook's Harbour	Cook's Harbour	Unnamed Pond	Feb 04, 2026	0.10	LTD	LTD	6.40
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Feb 20, 2026	0.02	0.12	LTD	1.60
Cottlesville	Cottlesville	Rushy Cove Pond	Jan 26, 2026	0.03	0.06	LTD	9.90
Cottrell's Cove	Cottrell's Cove	Cottrell's Pond	Feb 10, 2026	0.03	LTD	LTD	7.10
Cow Head	Cow Head	Short Cat Path Pond	Feb 11, 2026	0.02	0.07	LTD	13.00
Cow Head	Cow Head - PWDU	Short Cat Path Pond	Feb 11, 2026	LTD	LTD	LTD	LTD
Cox's Cove	Cox's Cove	Cox's Brook	Mar 10, 2026	0.02	0.15	LTD	5.30
Crow Head	Crow Head	Oars Pond	Feb 17, 2026	0.04	0.16	LTD	9.40
Cupids	Cupids	Brigus Long Pond (to Brigus)	Feb 05, 2026	0.01	LTD	LTD	4.70
Daniel's Harbour	Daniel's Harbour	Unnamed Spring & Brook	Feb 11, 2026	0.04	0.16	LTD	3.10
Deadman's Bay	Deadman's Bay	Deadman's Pond	Mar 02, 2026	0.01	LTD	LTD	9.40
Deep Bight	Deep Bight	Deep Bight River	Mar 05, 2026	0.01	0.09	LTD	6.00
Deer Lake	Deer Lake (+Reidville)	Humber Canal, Grand Lake	Mar 06, 2026	0.01	0.13	LTD	3.70
Dildo	Dildo, Broad Cove (+South Dildo)	Broad Cove Pond	Feb 09, 2026	0.01	0.06	LTD	7.60
Dover	Dover	Hare Bay Pond	Mar 03, 2026	0.01	0.05	LTD	10.00
Dover	Dover	Hare Bay Pond	Mar 18, 2026	0.00	0.06	LTD	9.40
Eddies Cove West	Eddies Cove West	Unnamed	Feb 05, 2026	0.03	0.15	LTD	5.50
Elliston	Elliston	Big Pond	Jan 20, 2026	0.02	0.06	LTD	2.20
Embree	Embree (+Little Burnt Bay)	Troke's Cove Pond	Jan 20, 2026	0.01	LTD	LTD	6.50
Englee	Englee	Island Cove Pond	Feb 03, 2026	0.01	LTD	LTD	13.00
Fairbanks-Hillgrade	Fairbanks-Hillgrade	Saltine's Pond	Feb 17, 2026	0.02	LTD	LTD	9.10
Fermeuse	Fermeuse, Kingman's	Merrymeeting Pond, Bear Cove Pond (2 intakes)	Jan 29, 2026	0.01	0.08	LTD	4.60
Ferryland	Ferryland	Deep Cove Pond	Jan 29, 2026	0.01	LTD	LTD	4.50
Flat Bay	Flat Bay (East)	#5 Well	Feb 12, 2026	0.16	0.17	LTD	0.57
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Feb 10, 2026	0.01	LTD	LTD	10.00
Flower's Cove	Flower's Cove (+Nameless Cove)	French Island Pond	Feb 04, 2026	0.03	0.10	LTD	7.40
Fogo Island	Seldom-Little Seldom	Bullock Cove Pond	Mar 04, 2026	0.01	LTD	LTD	13.00
Fogo Island	Fogo	Freeman's Pond	Mar 04, 2026	0.02	0.08	LTD	15.00

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Fogo Island	Fogo - PWDU	Freeman's Pond	Mar 04, 2026	LTD	LTD	LTD	LTD
Fogo Island	Joe Batt's Arm-Barr'd Islands-Shoal Bay	Long Pond	Mar 04, 2026	0.01	0.06	LTD	6.80
Fogo Island	Tilting	Sandy Cove Pond	Mar 04, 2026	0.02	0.06	LTD	12.00
Forresters Point	Forresters Point	Rudges Pond	Feb 04, 2026	0.06	LTD	LTD	8.90
Fortune	Fortune (+Grand Bank)	Horsebrook	Mar 05, 2026	0.01	0.08	LTD	2.00
Fox Cove-Mortier	Fox Cove-Mortier	Rock Pond	Mar 10, 2026	0.01	0.07	LTD	4.70
Francois	Francois	Our Pond	Feb 03, 2026	0.00	LTD	LTD	4.00
Gallants	Gallants	Gallant's Brook	Mar 11, 2026	0.04	0.15	LTD	0.96
Gambo	Gambo	Dark Cove Pond	Mar 03, 2026	0.02	LTD	0.01	5.80
Gander	Gander	Gander Lake	Feb 25, 2026	0.01	0.16	LTD	6.20
Gander Bay South	Gander Bay South - PWDU	Barry's Brook	Feb 25, 2026	LTD	0.07	LTD	LTD
Gander Bay South	George's Point, Harris Point	Barry's Brook	Feb 25, 2026	0.01	0.15	LTD	12.00
Garden Cove	Garden Cove	Arch Cove Pond	Mar 09, 2026	0.01	LTD	LTD	7.90
Garnish	Garnish	Witchazel Pond	Mar 05, 2026	0.01	LTD	LTD	7.90
Gaskiers	Gaskiers-Point La Haye - PWDU	Well	Feb 09, 2026	0.06	LTD	LTD	LTD
Gaultois	Gaultois	Piccaire Pond	Mar 10, 2026	0.01	0.06	LTD	15.00
Gaultois	Gaultois - PWDU	Piccaire Pond	Mar 10, 2026	0.02	0.43	LTD	LTD
George's Brook-Milton	George's Brook-Milton	George's Brook	Mar 05, 2026	0.01	0.09	LTD	6.30
Georgetown	Georgetown	Third Pond	Jan 26, 2026	0.01	0.14	LTD	4.00
Gillams	Gillams	Meaters Pond	Mar 10, 2026	0.02	0.16	LTD	4.40
Glenburnie-Birchy Head-Shoal Brook	Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Jan 27, 2026	0.02	0.16	LTD	3.40
Glenwood	Glenwood	Gander Lake (The Outflow)	Feb 25, 2026	0.01	0.14	LTD	6.50
Glovertown	Glovertown	Northwest Pond	Mar 05, 2026	0.01	LTD	LTD	7.70
Goobies	Goobies	Water Pond	Mar 09, 2026	0.01	LTD	LTD	4.40
Goose Cove East	Goose Cove East	Jack's Pond	Feb 03, 2026	0.03	0.26	LTD	8.70
Grand Bank	Grand Bank	Horsebrook	Mar 05, 2026	0.01	0.14	LTD	2.30
Grand Falls-Windsor	Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Jan 20, 2026	0.01	LTD	LTD	1.90
Grand Le Pierre	Grand Le Pierre	Nip Nose Pond	Mar 06, 2026	0.00	LTD	LTD	4.00
Great Brehat	Great Brehat	Little Steady Pond	Feb 04, 2026	0.05	0.09	LTD	9.50
Green Island Brook	Green Island Brook	Green Island Brook	Feb 04, 2026	0.02	LTD	LTD	6.30
Greenspond	Greenspond	Shambler's Cove Pond	Mar 03, 2026	0.01	LTD	LTD	9.40
Grey River	Grey River	Big Charlie's Pond	Mar 09, 2026	0.01	0.08	LTD	7.70

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Hampden	Hampden	Elliot Brook	Feb 11, 2026	0.05	0.07	LTD	4.40
Hant's Harbour	Hant's Harbour	Eastern Pond (Halfway Brook)	Feb 11, 2026	0.01	LTD	LTD	5.00
Happy Adventure	Happy Adventure	Goose Neck Pond	Mar 10, 2026	0.01	LTD	LTD	10.00
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	Mar 05, 2026	0.02	LTD	LTD	0.63
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	Mar 04, 2026	0.04	LTD	LTD	0.90
Harbour Breton	Harbour Breton	Connaigra Pond, Hutchings Pond	Feb 04, 2026	0.02	0.13	LTD	6.10
Harbour Grace	Harbour Grace, Harbour Grace South (+Riverhead)	Bannerman Lake	Jan 29, 2026	0.01	0.05	LTD	3.10
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Jan 08, 2026	0.08	LTD	LTD	LTD
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Jan 08, 2026	0.08	LTD	LTD	LTD
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Jan 29, 2026	0.08	LTD	LTD	LTD
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Maloney's River	Jan 26, 2026	0.02	0.06	LTD	3.60
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Mar 03, 2026	0.01	LTD	LTD	9.70
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Mar 18, 2026	0.00	0.05	LTD	9.80
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Mar 18, 2026	0.00	0.06	LTD	9.30
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Mar 18, 2026	0.00	0.08	LTD	9.40
Hawke's Bay	Hawke's Bay	Torrent River	Feb 05, 2026	0.02	LTD	0.01	7.80
Heart's Content	Heart's Content	Southern Cove Pond	Jan 29, 2026	0.00	LTD	LTD	4.50
Heart's Delight-Islington	Heart's Delight-Islington	Long Pond	Jan 29, 2026	0.01	0.07	LTD	2.00
Heart's Desire	Heart's Desire	Terrence Pond	Feb 09, 2026	0.01	LTD	LTD	3.50
Hermitage	Hermitage-Sandyville - PWDU	Granfer's Pond	Feb 04, 2026	LTD	LTD	LTD	LTD
Hermitage	Hermitage-Sandyville	Granfer's Pond	Feb 04, 2026	0.01	LTD	LTD	10.00
Herring Neck	Herring Neck, Hatchet Harbour, Salt Harbour, Shoal Cove, Sunnyside	Gut Pond	Feb 17, 2026	0.02	0.08	LTD	7.30
Hickman's Harbour-Robinson Bight	Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Mar 03, 2026	0.01	LTD	LTD	4.50
Howley	Howley	Sandy Lake	Feb 06, 2026	0.01	0.10	LTD	7.10
Howley	Howley - PWDU	Sandy Lake	Feb 06, 2026	LTD	LTD	LTD	LTD
Hughes Brook	Hughes Brook	Reservoir	Mar 10, 2026	0.03	0.31	LTD	2.10
Humber Arm South	Halfway Point, Benoit's Cove, John's Beach	Dormody's Brook	Feb 20, 2026	0.02	0.18	LTD	0.59
Humber Arm South	Frenchman's Cove Area	Gurges Pond	Feb 20, 2026	0.06	LTD	LTD	3.10
Indian Bay	Indian Bay	Indian Bay Brook	Mar 03, 2026	0.01	0.09	LTD	7.00
Irishtown-Summerside	Irishtown	Irishtown Brook	Mar 10, 2026	0.02	0.21	LTD	8.30
Irishtown-Summerside	Summerside	Pynn's Pond	Mar 10, 2026	0.02	0.16	LTD	6.60

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Isle aux Morts	Isle aux Morts	Burnt Ground Pond	Feb 04, 2026	0.01	LTD	LTD	5.80
Isle aux Morts	Isle aux Morts - PWDU	Burnt Ground Pond	Feb 04, 2026	LTD	LTD	LTD	LTD
Jackson's Arm	Jackson's Arm	Unnamed Brook	Feb 11, 2026	0.03	0.05	LTD	8.80
Jackson's Arm	Jackson's Arm - PWDU	Unnamed Brook	Feb 11, 2026	LTD	LTD	LTD	LTD
Jackson's Cove-Langdon's Cove-Silverdale	Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Feb 18, 2026	0.01	LTD	LTD	3.90
Keels	Keels	Boland's Pond	Jan 20, 2026	0.01	LTD	LTD	15.00
King's Point	King's Point	Bulley's Pond	Feb 18, 2026	0.01	LTD	LTD	6.10
La Poile	La Poile	Black Duck Pond	Feb 10, 2026	0.01	LTD	LTD	8.30
LaScie	La Scie	Stakes Pond	Feb 11, 2026	0.01	LTD	LTD	5.70
Labrador City	Labrador City	Beverly Lake	Feb 25, 2026	0.02	0.06	LTD	1.60
Lamaline	Lamaline - PWDU	Upper Hodges Pond	Mar 05, 2026	LTD	LTD	LTD	LTD
Lamaline	Lamaline	Upper Hodges Pond	Mar 05, 2026	0.02	LTD	LTD	2.00
Lark Harbour	Lark Harbour	Fairfax Brook	Feb 20, 2026	0.02	0.37	LTD	2.50
Lawn	Lawn	Brazil Pond	Mar 05, 2026	0.01	0.10	LTD	2.80
Lawn	Lawn - PWDU	Brazil Pond	Mar 05, 2026	0.00	0.06	LTD	LTD
Leading Tickles	Leading Tickles	Cook's Pond	Feb 10, 2026	0.02	0.10	LTD	8.80
Leading Tickles	Leading Tickles - PWDU	Cook's Pond	Feb 10, 2026	LTD	LTD	LTD	LTD
Lewin's Cove	Lewin's Cove	Big Pond	Mar 05, 2026	0.01	LTD	LTD	4.60
Lewisporte	Lewisporte	Stanhope Pond	Jan 20, 2026	0.02	0.07	LTD	8.20
Little Bay	Little Bay	First Pond	Feb 18, 2026	0.01	0.28	LTD	1.90
Little Bay	Little Bay	Mine Pond	Feb 18, 2026	0.02	0.07	LTD	5.10
Little Burnt Bay	Little Burnt Bay	Troke's Cove Pond	Jan 20, 2026	0.01	LTD	LTD	6.20
Little Harbour East	Little Harbour East (Placentia Bay)	Unnamed Pond	Mar 09, 2026	0.01	LTD	LTD	6.90
Little St. Lawrence	Little St. Lawrence	Butler's Brook (2 Intakes)	Mar 05, 2026	0.01	0.08	LTD	2.50
Long Harbour-Mount Arlington Heights	Long Harbour-Mount Arlington Heights	Shingle Pond and/or Trout Pond (2 Intakes)	Jan 23, 2026	0.02	LTD	LTD	1.20
Loon Bay	Loon Bay	Southeast Pond	Jan 20, 2026	0.02	0.08	LTD	7.70
Lourdes	Lourdes (+West Bay)	Victor's Brook	Mar 09, 2026	0.07	0.30	LTD	6.60
Lumsden	Lumsden	Gull Pond	Mar 02, 2026	0.01	LTD	LTD	2.80
Lushes Bight-Beaumont-Beaumont North	Lushes Bight, Beaumont	Milkboy's Pond/Gull Pond	Feb 26, 2026	0.01	0.09	LTD	8.90
Lushes Bight-Beaumont-Beaumont North	Lushes Bight, Beaumont - PWDU	Milkboy's Pond/Gull Pond	Feb 26, 2026	LTD	LTD	LTD	LTD
Main Brook	Main Brook	Joe Burt's Pond	Feb 03, 2026	0.02	LTD	LTD	7.80

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Marystown	Marystown	Fox Hill Reservoir / Clam Pond	Mar 10, 2026	0.01	LTD	LTD	1.60
Massey Drive	Massey Drive	Trout Pond, Third Pond (2 intakes)	Feb 20, 2026	0.02	0.07	LTD	1.70
McIvers	McIvers	McIvers Brook	Mar 10, 2026	0.03	0.26	LTD	6.80
Meadows	Meadows, Summerside West	Meaters Pond	Mar 10, 2026	0.02	0.09	LTD	4.50
Merritt's Harbour	Merritt's Harbour	Jimmy's Pond	Feb 17, 2026	0.02	LTD	LTD	11.00
Middle Arm	Middle Arm	Dam Pond Brook	Feb 10, 2026	0.01	0.06	LTD	6.80
Miles Cove	Miles Cove	Paddock's Pond	Feb 26, 2026	0.01	0.07	LTD	7.60
Millertown	Millertown	Water Pond	Feb 25, 2026	0.02	LTD	LTD	16.00
Millertown	Millertown	Water Pond	Mar 17, 2026	0.02	LTD	LTD	14.00
Millertown	Millertown	Water Pond	Mar 17, 2026	0.02	0.07	LTD	14.00
Millertown	Millertown	Water Pond	Mar 17, 2026	0.02	LTD	LTD	14.00
Milltown-Head of Bay D'Espoir	Milltown, Head of Bay D'Espoir	Jersey Pond	Feb 16, 2026	0.02	LTD	LTD	4.50
Ming's Bight	Ming's Bight	Middle Brook Pond	Feb 11, 2026	0.01	0.06	LTD	6.00
Morrisville	Morrisville	Morrisville Pond	Feb 16, 2026	0.02	0.08	LTD	5.80
Mount Moriah	Mount Moriah	Trout Pond, Third Pond (2 intakes)	Feb 20, 2026	0.02	0.07	LTD	1.50
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	Mar 05, 2026	0.01	0.05	LTD	1.80
Musgrave Harbour	Musgrave Harbour	Rocky Pond	Feb 25, 2026	0.01	0.07	LTD	2.70
Nameless Cove	Nameless Cove / Flower Cove	French Island Pond	Feb 04, 2026	0.03	0.11	LTD	7.50
Natuashish	Natuashish (Sango Bay)	Sango Brook and Wellfield	Feb 15, 2026	0.08	LTD	LTD	1.20
New Chelsea-New Melbourne-Brownsdale-Sibley's Cove-Lead Cove	Sibley's Cove, Lead Cove	Sibley's Cove Pond	Feb 11, 2026	0.01	0.06	LTD	3.60
New Perlican	New Perlican	New Perlican River	Feb 11, 2026	0.01	LTD	LTD	4.40
New-Wes-Valley	Wesleyville-Badger's Quay-Pool's Island, Brookfield-Poundcove-Newtown-Templeman	Little Northwest Pond	Mar 02, 2026	0.01	LTD	LTD	13.00
Newman's Cove	Newman's Cove	Heale Pond Brook	Jan 20, 2026	0.01	LTD	LTD	16.00
Nippers Harbour	Nippers Harbour	Blackhead Pond Brook	Feb 11, 2026	0.00	0.07	LTD	7.30
Norman's Cove-Long Cove	Norman's Cove-Long Cove	John Newhooks Pond	Jan 22, 2026	0.01	LTD	LTD	4.30
Norris Arm	Norris Arm (south)	Mill Lake	Jan 20, 2026	0.01	LTD	LTD	5.00
Norris Point	Norris Point	Neddy Harbour Pond	Feb 06, 2026	0.03	0.14	LTD	4.00
North Harbour	North Harbour	Grandfather's Pond	Mar 09, 2026	0.01	LTD	LTD	10.00
Northern Arm	Northern Arm	Northern Arm Lake	Jan 20, 2026	0.01	LTD	LTD	1.90
Old Perlican	Old Perlican	Bell Pond	Feb 11, 2026	0.01	LTD	LTD	4.30

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Pacquet	Pacquet	Big Brook	Feb 11, 2026	0.00	0.06	LTD	8.10
Pacquet	Pacquet - PWDU	Big Brook	Feb 11, 2026	LTD	LTD	LTD	LTD
Paradise	Paradise	Bay Bulls Big Pond	Mar 05, 2026	0.02	0.07	LTD	1.80
Parkers Cove	Parkers Cove	Unnamed brook	Mar 10, 2026	0.01	LTD	LTD	7.30
Parson's Pond	Parson's Pond	Cold Brook	Feb 11, 2026	0.14	1.20	LTD	1.40
Pasadena	Pasadena	Blue Gulch Pond	Mar 06, 2026	0.02	0.08	LTD	4.90
Peterview	Peterview	Northern Arm Lake	Jan 20, 2026	0.01	0.06	LTD	1.90
Petit Forte	Petit Forte	Reddy's Pond	Mar 06, 2026	0.01	0.07	LTD	7.00
Petty Harbour-Maddox Cove	Petty Harbour-Maddox Cove	Western Barrens Pond	Feb 16, 2026	0.01	LTD	LTD	3.80
Phillips Head	Phillips Head	Dogberry Brook	Feb 10, 2026	0.02	0.16	LTD	5.80
Piccadilly Head	Piccadilly Head (+West Bay)	Unnamed Brook	Mar 09, 2026	0.23	0.17	LTD	5.20
Pidgeon Cove-St. Barbe	Pigeon Cove - St. Barbe	Long Pond	Feb 04, 2026	0.02	0.07	LTD	12.00
Pilley's Island	Pilley's Island	Loadabats Pond	Feb 26, 2026	0.04	0.12	LTD	5.80
Placentia	Freshwater, Argentia site, Dunville	Clarkes Pond	Jan 23, 2026	0.02	0.09	LTD	5.90
Placentia	Placentia, Jerseyside, SE Placentia	Larkins Pond	Jan 23, 2026	0.02	LTD	LTD	5.80
Pleasantview	Pleasantview	Little Arm Pond	Feb 10, 2026	0.02	0.07	LTD	10.00
Plum Point	Plum Point	Grand Pond	Feb 04, 2026	0.02	0.07	LTD	9.00
Point Lance	Point Lance	Unnamed Pond	Mar 10, 2026	0.02	0.05	LTD	5.00
Point Leamington	Point Leamington	Little Pond	Feb 10, 2026	0.01	0.09	LTD	7.20
Point May	Point May - PWDU	Short's Pond	Mar 05, 2026	0.01	LTD	0.02	LTD
Point May	Point May	Short's Pond	Mar 05, 2026	0.02	0.06	LTD	2.40
Point of Bay	Point of Bay	Indian Cove Pond	Feb 10, 2026	0.01	LTD	LTD	8.50
Pollards Point	Pollards Point, Country Cove	Country Cove Pond	Feb 11, 2026	0.03	LTD	LTD	4.50
Pollards Point	Pollards Point East	George Ricks Pond	Mar 04, 2026	0.02	LTD	LTD	8.60
Pollards Point	Pollards Point East	George Ricks Pond	Mar 04, 2026	0.02	LTD	LTD	8.90
Pool's Cove	Pool's Cove	Widgeon Pond	Feb 04, 2026	0.01	0.08	LTD	5.80
Port Albert	Port Albert	Beaverton Pond	Mar 04, 2026	0.03	LTD	LTD	7.70
Port Anson	Port Anson	Anchor Pond	Feb 26, 2026	0.01	LTD	LTD	11.00
Port Anson	Port Anson	Anchor Pond	Mar 18, 2026	0.01	LTD	LTD	10.00
Port Blandford	Port Blandford	Noseworthy's Pond	Mar 10, 2026	0.02	0.15	LTD	5.10
Port Rexton	Port Rexton	#1 Well - Lois Long Well	Mar 11, 2026	0.07	0.63	LTD	0.69
Port Rexton	Port Rexton (Seasonal Use)	#2 Well - Edmund Brown's Well	Mar 11, 2026	0.07	0.44	LTD	1.10

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Port Rexton	Hunchback Hill	#3 Well - Harold Vivian's Well	Mar 11, 2026	0.15	0.16	LTD	LTD
Port Rexton	Ship Cove	#5 Well - Mabel Clarke's Well	Mar 11, 2026	0.05	0.86	LTD	3.50
Port Rexton	Ship Cove	#6 Well - Banister's Well	Mar 11, 2026	0.10	LTD	LTD	1.20
Port Rexton	Champneys Arm	Champney's Arm Well	Mar 11, 2026	0.17	LTD	LTD	2.00
Port Saunders	Port Saunders - PWDU	Tom Taylor's Pond	Feb 05, 2026	0.01	0.06	LTD	LTD
Port Saunders	Port Saunders	Tom Taylor's Pond	Feb 05, 2026	0.02	LTD	LTD	8.10
Port au Choix	Port au Choix	Winterhouse Pond	Feb 05, 2026	0.05	0.08	LTD	5.50
Port au Choix	Port au Choix - PWDU	Winterhouse Pond	Feb 05, 2026	LTD	LTD	LTD	LTD
Port au Port West-Aguathuna-Felix Cove	Port au Port West	Jim Rowe's Brook	Mar 05, 2026	0.47	LTD	LTD	0.56
Portland Creek	Portland Creek	Unnamed Streams	Feb 11, 2026	0.08	0.82	LTD	1.80
Portugal Cove South	Portugal Cove South	Wrights Brook	Feb 09, 2026	0.01	0.08	LTD	1.40
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	Mar 03, 2026	0.01	0.11	LTD	1.90
Pouch Cove	Pouch Cove	North Three Island Pond	Feb 16, 2026	0.01	LTD	LTD	1.70
Purcell's Harbour	Purcell's Harbour	Purcell's Harbour Pond	Feb 17, 2026	0.02	LTD	LTD	18.00
Pynn's Brook	Pynn's Brook	Pynn's Brook	Mar 06, 2026	0.08	0.12	LTD	3.20
Ramea	Ramea	Northwest Pond	Mar 10, 2026	0.04	0.07	LTD	5.30
Ramea	Ramea - PWDU	Northwest Pond	Mar 10, 2026	0.04	0.07	LTD	4.10
Random Sound West	Queen's Cove	Reservoir	Mar 10, 2026	0.01	0.07	LTD	7.80
Rattling Brook	Rattling Brook	Mark's Pond Brook	Feb 18, 2026	0.00	0.10	LTD	7.30
Reidville	Reidville	Humber Canal, Grand Lake	Feb 06, 2026	0.01	0.12	LTD	3.60
River of Ponds	River of Ponds	Burnt Head Ponds	Feb 05, 2026	0.02	LTD	LTD	7.70
Robert's Arm	Robert's Arm	Young's Pond / Dam Pond	Feb 26, 2026	0.03	LTD	LTD	4.70
Rocky Harbour	Rocky Harbour	Gull Pond	Feb 06, 2026	0.03	0.15	LTD	5.60
Roddickton-Bide Arm	Roddickton	East Brook Pond	Feb 03, 2026	0.03	0.08	LTD	5.40
Roddickton-Bide Arm	Bide Arm	First Clay Cove Pond	Feb 03, 2026	0.03	LTD	LTD	5.40
Rose Blanche-Harbour Le Cou	Rose Blanche-Harbour Le Cou	Rose Blanche Brook	Feb 04, 2026	0.01	0.07	LTD	3.80
Rushoon	Rushoon	Big Pond Brook	Mar 10, 2026	0.01	0.10	LTD	4.30
Salmon Cove	Salmon Cove	Rocky Pond	Jan 30, 2026	0.01	LTD	LTD	2.80
Salvage	Salvage	Wild Cove Pond	Mar 05, 2026	0.02	LTD	LTD	13.00
Seal Cove (FB)	Seal Cove, F.B.	Big Black Duck Pond	Feb 04, 2026	0.01	LTD	LTD	8.70
Seal Cove (FB)	Seal Cove, F.B. - PWDU	Big Black Duck Pond	Feb 04, 2026	LTD	LTD	LTD	0.50
Seal Cove (WB)	Seal Cove, W.B.	Seal Cove Brook & Long Pond	Feb 10, 2026	0.01	LTD	LTD	12.00

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Sheaves Cove	Sheaves Cove	Unnamed Brook	Mar 10, 2026	0.06	0.31	LTD	3.50
Shoe Cove	Shoe Cove	Second Pond	Feb 11, 2026	0.01	0.06	LTD	14.00
Smith's Harbour	Smith's Harbour	Fleshetts Brook	Feb 10, 2026	0.01	0.10	LTD	12.00
Sop's Arm	Sop's Arm	Little Tickle Pond	Feb 11, 2026	0.03	0.12	LTD	9.60
South Brook	South Brook	Next to Brook	Feb 25, 2026	0.04	0.35	LTD	LTD
South Dildo	South Dildo	Broad Cove Pond	Feb 09, 2026	0.01	LTD	LTD	6.10
South River	South River	Brigus Long Pond (to Brigus)	Feb 05, 2026	0.01	LTD	LTD	4.60
Southern Harbour	Southern Harbour	Brigades Pond	Jan 22, 2026	0.01	LTD	LTD	4.70
Spaniard's Bay	Spaniard's Bay (+Upper Island Cove, + Bryant's Cove)	Kelly's Pond (Spider's Pond)	Jan 30, 2026	0.01	0.11	LTD	4.40
Springdale	Springdale	Sullivan's Pond (2 Intakes)	Feb 18, 2026	0.01	0.07	LTD	4.70
St. Anthony	St. Anthony	St. Anthony Pond	Feb 04, 2026	0.02	0.06	LTD	6.70
St. Anthony Bight	St. Anthony Bight	Cabbox Pond	Feb 04, 2026	0.03	LTD	LTD	18.00
St. Bernard's-Jacques Fontaine	St. Bernard's-Jacques Fontaine	Rattle Brook	Mar 10, 2026	0.01	0.09	LTD	4.90
St. Bride's	St. Bride's	North Side Brook	Mar 10, 2026	0.02	0.07	LTD	2.70
St. Bride's	St. Bride's	South Side Brook	Mar 10, 2026	0.01	0.07	LTD	5.20
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Mar 05, 2026	0.01	0.06	LTD	1.80
St. John's	St. John's	Petty Harbour Long Pond	Mar 03, 2026	0.01	0.05	LTD	1.90
St. John's	St. John's	Windsor Lake	Mar 03, 2026	0.01	LTD	LTD	2.20
St. Judes	St. Judes	Chute Brook	Mar 06, 2026	0.13	0.08	LTD	3.10
St. Judes	St. Judes	Uncle Arthur Brook	Mar 06, 2026	0.12	0.16	LTD	4.50
St. Judes	St. Judes	Uncle Arthur Brook	Mar 20, 2026	0.03	LTD	LTD	7.70
St. Lawrence	St. Lawrence - PWDU	St. Lawrence River	Mar 05, 2026	0.01	LTD	LTD	1.70
St. Lawrence	St. Lawrence	St. Lawrence River	Mar 05, 2026	0.01	0.07	LTD	2.30
St. Lunaire-Griquet	St. Lunaire-Griquet	Joe's Pond	Feb 04, 2026	0.03	LTD	LTD	16.00
St. Lunaire-Griquet	St. Lunaire-Griquet - PWDU	Joe's Pond	Feb 04, 2026	LTD	0.34	LTD	LTD
St. Lunaire-Griquet	Gunners Cove	Lookout Brook	Feb 04, 2026	0.08	0.09	LTD	6.50
St. Pauls	St. Pauls	Two Mile Pond	Feb 06, 2026	0.04	0.08	LTD	9.30
St. Shott's	St. Shott's	Unnamed Pond	Feb 09, 2026	0.01	0.13	LTD	1.30
Steady Brook	Steady Brook	Wellfield + Steady Brook	Mar 06, 2026	0.30	0.13	LTD	4.50
Stephenville	Stephenville	Well Field	Mar 05, 2026	0.14	0.23	LTD	0.73
Stoneville	Stoneville	Dog Bay Pond Brook	Mar 04, 2026	0.01	0.15	LTD	8.10
Straitsview	Straitsview	Saddle Hill Pond	Feb 04, 2026	0.06	LTD	LTD	14.00

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Summerford	Summerford (+Cottlesville)	Rushy Cove Pond	Feb 17, 2026	0.03	0.05	LTD	9.80
Sunnyside (T.B.)	Sunnyside	Center Cove River	Jan 22, 2026	0.01	LTD	LTD	5.40
Terrenceville	Terrenceville	Big Brook	Mar 06, 2026	0.01	0.08	LTD	4.10
Thornlea	Thornlea	Big Bakeapple Pond	Feb 12, 2026	0.03	LTD	LTD	8.20
Tizzard's Harbour	Tizzard's Harbour	Rocky Pond	Feb 17, 2026	0.01	LTD	LTD	13.00
Torbay	Torbay	North Pond	Feb 16, 2026	0.01	LTD	LTD	3.00
Trepassey	Trepassey	Miller's Pond	Feb 09, 2026	0.01	LTD	LTD	2.80
Trinity	Trinity, T.B.	Indian Pond	Jan 21, 2026	0.00	LTD	LTD	6.80
Trinity Bay North	Little Catalina	Whirl Pond	Jan 21, 2026	0.00	LTD	LTD	8.00
Trinity Bay North	Port Union, Catalina (+Little Catalina)	Whirl Pond	Jan 21, 2026	0.00	LTD	LTD	8.00
Trinity Bay North	Melrose	Whirl Pond	Jan 21, 2026	0.01	LTD	LTD	7.80
Triton	Triton, Jim's Cove, Card's Harbour	Triton Pond	Feb 26, 2026	0.03	LTD	LTD	10.00
Trout River	Trout River	Feeder Brook	Jan 27, 2026	0.01	0.21	LTD	1.20
Twillingate	Twillingate	Wild Cove Pond	Feb 17, 2026	0.01	0.06	LTD	11.00
Upper Amherst Cove	Upper Amherst Cove	Drilled	Jan 20, 2026	0.11	LTD	LTD	2.10
Upper Island Cove	Upper Island Cove	Kelly's Pond (Spider's Pond)	Jan 29, 2026	0.00	LTD	LTD	4.10
Victoria	Victoria (+Salmon Cove)	Rocky Pond	Jan 30, 2026	0.01	0.16	LTD	2.90
Victoria	Victoria (+Salmon Cove)	Rocky Pond	Feb 27, 2026	0.01	LTD	LTD	2.80
Victoria	Victoria (+Salmon Cove)	Rocky Pond	Feb 27, 2026	0.01	0.08	LTD	2.90
Victoria	Victoria (+Salmon Cove)	Rocky Pond	Feb 27, 2026	0.01	LTD	LTD	2.80
West Bay	West Bay	Victor's Brook	Mar 09, 2026	0.07	0.24	LTD	6.10
Westport	Westport	Western Brook Pond	Feb 10, 2026	0.01	LTD	LTD	13.00
Whitbourne	Whitbourne	Hodges River	Jan 23, 2026	0.01	LTD	LTD	5.30
Whiteway	Whiteway (+Cavendish)	Long Pond	Jan 29, 2026	0.01	LTD	LTD	5.20
Whiteway	Whiteway - PWDU	Long Pond	Jan 29, 2026	0.01	LTD	LTD	LTD
Wild Cove	Wild Cove	Hedderson's Pond Brook	Feb 10, 2026	0.02	0.06	LTD	8.90
Winterton	Winterton	Western Pond	Feb 11, 2026	0.01	0.07	LTD	5.00
Wooddale	Wooddale	Northern Arm Lake	Jan 20, 2026	0.01	LTD	LTD	1.70
Woodstock	Woodstock	Mill Pond	Feb 11, 2026	0.01	LTD	LTD	12.00
Woody Point	Woody Point	Winterhouse Brook	Jan 27, 2026	0.02	0.16	LTD	1.00

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

This report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ. Guidelines have not been developed for all the parameters listed in this report.

Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant Exceedances

Strontium: The maximum acceptable concentration for strontium is 7.0 mg/L. Strontium may enter drinking water from naturally occurring deposits or as a result of human activity, such as mining or other industries. High levels of this contaminant can cause adverse health effects for some people.

Nitrate: The maximum acceptable concentration for nitrate is 10 mg/L as nitrate-nitrogen. Nitrate is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

Nitrite: The maximum acceptable concentration for nitrite is 1 mg/L as nitrite-nitrogen. Nitrite is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

mg/L = milligrams per litre or parts per million TOC = total organic carbon