

AMENDMENT TO PERMIT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 49

Date: **JULY 31, 2026**

File No: **844.197.001**

Permit No: **WS14836-2026**

Amendment No: **1**

Permit Holder: **Town of Bay Roberts
321 Water Street
P.O. Box 114
Bay Roberts NL A0A 1G0**


Attention: **Sean Elms**

Re: **Bay Roberts - Water Street Upgrades Phase 2**

The original Permit dated MARCH 27, 2026 is amended as follows:

to allow the installation of approximately 80 m of 200 mm PVC sanitary sewer and all related appurtenances as described in the information provided on July 30, 2026.

All other terms and conditions of the original Permit will apply and failure to comply with the terms and conditions of this amendment and the original Permit will render this Permit null and void, place the Permit Holder and their agent(s) in violation of the *Water Resources Act* and make the Permit Holder responsible for taking any remedial measures as may be prescribed by this Department.



(for) MINISTER

GOVERNMENT OF NEWFOUNDLAND AND LABRADOR
Department of Environment, Conservation and Climate Change

File No: 844.197.001
Permit No: WS14836-2026
Amendment No: 1

APPENDIX A
Terms and Conditions for Permit

Sewer Systems

1. Storm water drainage, including roof drains, weeping tile drains, and street drainage, shall not be connected to the sanitary sewer system.
2. In the event that private or existing sewer lines are disturbed during construction, the lines are to be restored to their original working condition. Care shall be taken to ensure that soil or other material does not enter the lines to cause blockage.
3. The flow channel through manholes should be made to conform in shape and slope to that of the sanitary sewer.
4. The direct connection of sanitary sewer service lines to manholes is prohibited unless the service enters at the flow line of the manhole. In this instance, filleting must be provided to prevent solids deposition.
5. All sanitary sewers shall be laid or covered with sufficient depth of suitable material to prevent frost penetration and damage from traffic loading.
6. Where storm sewer and sanitary sewer service laterals are extended to property boundaries for future connections, the stub ends must be clearly marked to identify storm and sanitary lines to prevent possible cross-connections.
7. For sanitary sewers with low percentage grade or slope, council accepts the slopes and any additional maintenance required if cleansing velocities are insufficient.

cc: Ms. Deneen Spracklin, P.Eng.
Manager, Drinking Water and Wastewater Section
Water Resources Management Division
Department of Environment, Conservation and Climate Change
P.O. Box 8700
4th Floor, West Block, Confederation Building
St. John's, NL A1B 4J6
dspracklin@gov.nl.ca

cc: Mr. Dean Shute (Harbour Grace - Eastern)
Manager of Operations, GSC-Harbour Grace
Digital Government and Service NL
7-9 Roddick Crescent
PO Box 512
Harbour Grace NL A0A 2M0
deanshute@gov.nl.ca

cc: Mr. Inayat Rehman, P.Eng.
Regional Engineer
Department of Transportation and Infrastructure
P.O. Box 8700
St. John's, NL A1B 4J6
inayatrehman@gov.nl.ca