

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Admirals Beach																		
Admiral's Beach	2 Well Fields	Nov 21, 2025	110.00	10	290.0	100.00	8.02	160		LTD	LTD	LTD	24.00	16	0.200	1.200	19	11
Appleton																		
Appleton (+Glenwood)	Gander Lake (The Outflow)	Nov 26, 2025	2.10	<u>32</u>	31.0	5.90	<u>5.88</u>	17		0.41	LTD	LTD	1.30	6	LTD	0.180	2	LTD
Badger																		
Badger	Well Field, 2 wells on standby	Nov 25, 2025	30.00	LTD	210.0	47.00	7.26	120		0.19	LTD	LTD	17.00	44	0.130	0.300	21	5
Baine Harbour																		
Baine Harbour	Dug	Nov 19, 2025	21.00	7	130.0	25.00	7.20	72		LTD	LTD	LTD	7.80	20	LTD	0.510	14	9
Barachois Brook																		
Barachois Brook	Drilled	Nov 10, 2025	57.00	LTD	190.0	58.00	7.89	110		0.40	LTD	LTD	18.00	16	LTD	1.400	12	12
Bauline																		
Bauline	#1 Brook Path Well	Nov 13, 2025	56.00	15	320.0	80.00	7.58	180		0.14	LTD	LTD	24.00	59	LTD	0.720	30	12
Bay Roberts																		
Bay Roberts	Rocky Pond	Dec 18, 2025	LTD	LTD	79.0	9.80	<u>6.15</u>	44		0.21	LTD	LTD	2.50	18	LTD	0.230	10	3
Bay St. George South																		
St. Fintan's, St. David's	#1 Well St. Fintan's (The Y)	Nov 20, 2025	150.00	LTD	360.0	150.00	8.21	200		0.12	0.06	LTD	35.00	23	LTD	3.400	15	7
St. Fintan's	#2 Well St. Fintan's (Louis King)	Nov 20, 2025	200.00	LTD	870.0	270.00	8.09	480		0.18	LTD	LTD	79.00	120	LTD	2.400	73	68
Jeffrey's	#2 Well Jeffery's (Calvin Madore)	Nov 20, 2025	140.00	LTD	460.0	140.00	8.11	260		2.00	0.21	LTD	41.00	49	LTD	10.000	28	21
Jeffrey's	#1 Well Jeffery's (Joe Curnew)	Nov 20, 2025	95.00	LTD	1,100.0	260.00	8.00	<u>590</u>		0.21	0.40	LTD	72.00	93	0.190	9.800	120	280
Lock Leven	#6 Well Loch Leven (Jerry Quilty)	Dec 02, 2025	190.00	LTD	750.0	250.00	8.01	420		0.29	LTD	LTD	74.00	100	LTD	2.600	45	32
McKay's	#7 Well McKay's (Gordon Hulan)	Nov 20, 2025	180.00	LTD	670.0	240.00	8.02	370		0.95	0.12	LTD	67.00	38	LTD	5.000	39	110
Robinson's	#1 Well Robinson's (Louie MacDonald)	Nov 20, 2025	250.00	LTD	730.0	270.00	7.96	410		0.17	LTD	LTD	87.00	79	LTD	3.500	40	12
McKay's	#2B Lions Club Well	Nov 20, 2025	130.00	LTD	760.0	280.00	8.01	420		1.30	0.10	LTD	82.00	56	0.110	5.100	34	170

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality			15		6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter			A		A	A		C	C			A	C		A	A
Bay St. George South																			
Jeffrey's	#3 Well Jeffrey's (Sid Shears)	Nov 20, 2025	100.00	LTD	530.0	130.00	7.98	300		0.29	0.58	LTD	39.00	38	0.120	10.000	46	96	
McKay's	#3 Woodworth Well McKay's	Nov 20, 2025	120.00	LTD	1,300.0	55.00	8.44	<u>730</u>		0.66	0.28	LTD	18.00	170	0.190	4.400	<u>240</u>	230	
Highlands	#3 Brian Pumphrey Well Highlands	Nov 20, 2025	170.00	LTD	950.0	45.00	8.20	<u>530</u>		0.12	0.28	LTD	11.00	180	0.260	1.400	180	31	
Robinson's	#3 Well Robinson's (Gales)	Nov 20, 2025	150.00	LTD	430.0	150.00	8.17	240		0.12	0.11	LTD	34.00	41	0.110	7.700	20	13	
Jeffrey's	#4 Well Jeffery's - Jack Harris	Nov 20, 2025	130.00	LTD	530.0	170.00	8.07	290		0.24	0.11	LTD	50.00	44	LTD	9.200	32	64	
Beaches																			
Beaches	Grassey Pond Brook	Nov 18, 2025	11.00	<u>60</u>	44.0	14.00	7.09	24		0.65	LTD	LTD	4.60	5	LTD	0.920	3	LTD	
Bear Cove																			
Bear Cove	Lower Bear Cove	Nov 05, 2025	180.00	<u>22</u>	390.0	190.00	8.01	220		0.19	LTD	LTD	37.00	17	LTD	2.600	11	6	
Bear Cove	Upper Bear Cove	Nov 05, 2025	270.00	5	570.0	190.00	7.92	320		0.70	0.32	LTD	36.00	24	0.190	15.000	43	11	
Benoit's Siding																			
Benoit's Siding (aka Bennett's Siding)	Drilled	Nov 25, 2025	140.00	LTD	610.0	170.00	7.89	340		LTD	LTD	LTD	55.00	98	LTD	4.000	46	10	
Doyles	# 2 Well Doyles	Nov 25, 2025	140.00	LTD	450.0	150.00	7.98	250		0.18	0.05	LTD	38.00	53	LTD	12.000	14	7	
Birchy Bay																			
Birchy Bay	Jumper's Pond	Nov 18, 2025	16.00	<u>22</u>	110.0	19.00	7.47	62		0.45	LTD	LTD	6.10	21	LTD	0.290	16	1	
Bishop's Falls																			
Bishop's Falls	Northern Arm Lake	Nov 03, 2025	6.40	LTD	87.0	32.00	6.92	48		0.17	LTD	LTD	12.00	4	LTD	0.130	2	25	
Black Duck																			
Black Duck (Siding)	#1 Well	Dec 12, 2025	110.00	LTD	240.0	96.00	8.07	130		LTD	LTD	LTD	29.00	12	LTD	0.720	14	3	
Blaketown																			
Blaketown South	#1 Selby Mercer Well	Nov 06, 2025	54.00	LTD	240.0	44.00	7.07	130		0.43	0.06	LTD	12.00	37	0.100	1.500	28	9	
Blaketown	#2 Daphne Pincent Well	Nov 06, 2025	110.00	LTD	320.0	51.00	7.94	180		0.63	0.12	LTD	13.00	31	0.230	1.900	46	9	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Blaketown																		
Blaketown North	#4 Hilda Barrett Well	Nov 06, 2025	92.00	LTD	260.0	65.00	8.05	140		0.28	0.10	LTD	17.00	22	0.210	1.500	25	11
Blaketown Centre	#3 Fred Osborne Well	Nov 06, 2025	110.00	LTD	260.0	25.00	<u>8.67</u>	140		0.15	0.10	LTD	6.70	15	0.160	1.900	46	3
Blaketown Centre	#3 Fred Osborne Well	Nov 26, 2025	110.00	8	260.0	25.00	<u>8.65</u>	150		0.55	0.10	LTD	7.20	14	0.160	2.100	49	LTD
Branch																		
Branch	Drilled Wells	Dec 08, 2025	110.00	LTD	280.0	87.00	8.14	160		5.70	0.06	LTD	29.00	17	LTD	2.600	21	7
Branch	Drilled Wells	Dec 19, 2025	110.00	LTD	280.0	100.00	8.03	160		0.38	LTD	LTD	34.00	17	LTD	2.700	21	7
Brent's Cove																		
Brent's Cove	Paddy's Pond	Nov 13, 2025	13.00	LTD	49.0	13.00	6.79	27		LTD	LTD	LTD	3.80	4	LTD	0.750	3	4
Brigus South																		
Forge Hill area	#1 Well Forge Hill	Nov 19, 2025	130.00	9	340.0	130.00	7.84	190		0.12	LTD	LTD	49.00	29	LTD	0.820	19	9
Near highway	#3 Well Main Road	Nov 19, 2025	45.00	LTD	120.0	LTD	7.57	65		LTD	LTD	LTD	LTD	9	LTD	LTD	26	2
Bryant's Cove																		
Bryant's Cove South Side	#1 Well - Bert James Well #2 Well - Baxter Bowering Well	Nov 10, 2025	68.00	LTD	230.0	52.00	7.81	130		0.15	LTD	LTD	17.00	13	LTD	0.360	7	15
Bunyan's Cove																		
Bunyan's Cove	#1 Wellfield	Dec 10, 2025	41.00	<u>28</u>	250.0	49.00	7.21	140		2.30	LTD	LTD	13.00	42	LTD	1.800	27	10
Burlington																		
Burlington	Eastern Island Pond	Nov 12, 2025	9.70	<u>56</u>	75.0	10.00	6.78	42		0.73	LTD	LTD	3.00	13	LTD	0.200	11	LTD
Burlington	Eastern Island Pond	Nov 12, 2025	9.70	<u>48</u>	74.0	9.90	6.81	41		0.84	LTD	LTD	2.80	13	LTD	0.190	11	LTD
Burlington	Eastern Island Pond	Nov 12, 2025	9.90	<u>56</u>	75.0	10.00	6.78	42		0.76	LTD	LTD	2.90	13	LTD	0.190	11	LTD
Canning's Cove																		
Lower Canning's Cove	#1 Well - Pleman Pitts	Dec 10, 2025	61.00	LTD	150.0	45.00	7.67	85		LTD	LTD	LTD	17.00	9	LTD	0.610	13	3
Upper Canning's Cove	#2 Well - Eugene Ellis	Dec 10, 2025	89.00	LTD	190.0	85.00	7.83	110		0.15	LTD	LTD	32.00	7	LTD	0.370	6	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Canning's Cove																		
Centre Canning's Cove	#3 Well - Glenda Penney	Dec 10, 2025	18.00	LTD	83.0	21.00	7.17	46		LTD	LTD	LTD	6.80	11	LTD	0.520	7	3
Cartwright																		
Cartwright	Burdett's Pond	Nov 26, 2025	6.80	<u>150</u>	55.0	4.00	6.64	31		0.68	LTD	LTD	0.68	10	LTD	0.140	9	LTD
Cartwright - PWDU	Burdett's Pond	Nov 26, 2025	LTD	LTD	3.6	LTD	<u>6.22</u>	2		LTD	LTD	LTD	LTD	LTD	LTD	LTD	0	LTD
Castor River South																		
Castor River South	Unnamed	Nov 06, 2025	210.00	12	420.0	200.00	7.68	240		0.11	LTD	LTD	52.00	14	LTD	0.950	8	3
Cavendish																		
North Side Cavendish	#1 Well - Max Bishop	Dec 02, 2025	81.00	LTD	290.0	89.00	7.47	160		0.14	LTD	LTD	27.00	28	LTD	1.500	19	14
North Side Cavendish	#2 Well - Tom Critch	Dec 02, 2025	100.00	7	280.0	86.00	7.83	160		2.20	LTD	LTD	25.00	21	LTD	1.200	20	10
Chance Cove																		
Back Cove Area	Olive Smith Well	Nov 06, 2025	22.00	LTD	140.0	23.00	7.23	76		0.15	LTD	LTD	6.90	24	LTD	0.620	15	6
New Housing Area	New Housing Area Well	Nov 06, 2025	110.00	LTD	250.0	78.00	8.03	140		0.12	LTD	LTD	26.00	17	LTD	0.510	18	6
Lower Cove	#5B Albert Rowe Well	Nov 06, 2025	120.00	LTD	270.0	100.00	7.89	150		0.15	LTD	LTD	36.00	13	LTD	0.540	11	5
Upper Cove	Hollett's Well	Nov 06, 2025	110.00	LTD	610.0	2.70	8.00	340		0.81	LTD	LTD	1.10	110	0.140	0.340	120	27
Change Islands																		
Change Islands - PWDU	#1 Fox Cove Well	Dec 08, 2025	11.00	LTD	52.0	1.90	6.98	29		LTD	0.10	LTD	0.46	9	LTD	0.810	10	LTD
Channel-Port aux Basques																		
Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Dec 01, 2025	4.30	LTD	110.0	32.00	6.85	61		0.62	LTD	LTD	12.00	12	LTD	0.360	5	23
Charlottetown (Labrador)																		
Charlottetown (Labrador)	Middle Pond	Nov 26, 2025	LTD	<u>62</u>	42.0	6.40	<u>5.19</u>	23		0.62	LTD	LTD	1.50	7	LTD	0.210	2	LTD
Charlottetown (Labrador) - PWDU	Middle Pond	Nov 26, 2025	LTD	13	13.0	LTD	<u>4.78</u>	7		LTD	LTD	LTD	LTD	1	LTD	LTD	LTD	LTD
Churchill Falls																		
Churchill Falls	Smallwood Reservoir	Oct 21, 2025	4.50	8	29.0	11.00	6.85	16		0.40	LTD	LTD	2.70	3	LTD	0.260	1	1

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Clareville																		
Clareville, Shoal Harbour	Shoal Harbour River	Dec 12, 2025	6.40	LTD	110.0	27.00	7.09	61		1.10	LTD	LTD	9.80	8	LTD	0.180	10	24
Clarke's Beach																		
Otterbury	#1 Well - Quinlon Well	Dec 19, 2025	88.00	LTD	220.0	83.00	8.10	120		LTD	LTD	LTD	20.00	9	LTD	0.580	11	13
Otterbury	#2 Well - Delaney Well	Dec 19, 2025	88.00	LTD	220.0	97.00	8.02	120		LTD	LTD	LTD	25.00	11	LTD	0.490	9	12
Colliers																		
Merrigan's Lane + Main Rd	#2 Well - Merrigan's Well	Nov 27, 2025	110.00	LTD	320.0	59.00	8.04	180		1.70	LTD	LTD	22.00	24	LTD	1.400	43	16
Harbour Drive & Main Road	#3 Well - Griffin's Well	Nov 27, 2025	96.00	LTD	480.0	86.00	7.81	260		0.11	LTD	LTD	29.00	82	LTD	0.820	60	7
Harbour Drive	#4 Well - Flynn's Well	Nov 27, 2025	99.00	LTD	290.0	110.00	7.80	160		LTD	LTD	LTD	39.00	27	LTD	0.670	14	6
Harbour Drive	#5 Well - Whalen's Well	Nov 27, 2025	43.00	LTD	230.0	52.00	7.50	130		0.19	LTD	LTD	17.00	37	LTD	1.800	22	5
Conception Bay South																		
Conception Bay South	Bay Bulls Big Pond	Nov 26, 2025	21.00	LTD	94.0	25.00	7.40	53		0.47	LTD	LTD	9.00	16	LTD	0.240	8	2
Conception Harbour																		
Cemetery Road & Main Road	Cemetery Road Well	Nov 27, 2025	84.00	LTD	220.0	67.00	7.89	120		LTD	LTD	LTD	25.00	12	0.120	0.880	15	5
Upper Bacon Cove, Kitchuses	Upper Bacon Cove Well	Nov 27, 2025	130.00	LTD	300.0	100.00	8.07	170		0.19	LTD	LTD	36.00	13	LTD	2.200	20	6
Lower Bacon Cove	Lower Bacon Cove Well	Nov 13, 2025	120.00	LTD	320.0	92.00	8.01	180		0.15	LTD	LTD	33.00	23	LTD	2.200	26	8
Corner Brook																		
Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Nov 10, 2025	30.00	LTD	100.0	23.00	7.57	58		LTD	LTD	LTD	7.10	12	LTD	0.350	12	3
Cox's Cove																		
Upper Area	Upper Area Wellfield	Dec 02, 2025	170.00	LTD	350.0	130.00	8.09	200		0.61	0.06	LTD	33.00	12	0.250	3.600	17	11
Deadman's Bay																		
Deadman's Bay	Deadman's Pond	Nov 26, 2025	LTD	45	57.0	4.40	5.96	32		1.70	LTD	LTD	0.74	13	LTD	0.210	9	1
Eastport																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Eastport																		
Eastport (+Sandy Cove)	Dug	Dec 10, 2025	22.00	LTD	130.0	22.00	6.85	71		LTD	LTD	LTD	6.60	22	LTD	0.850	13	4
Fermeuse																		
Fermeuse	Port Kirwan Road Well	Nov 20, 2025	130.00	LTD	410.0	140.00	7.88	230		LTD	LTD	LTD	41.00	51	LTD	1.000	22	10
Flat Bay																		
Flat Bay (East)	#3 Well	Nov 10, 2025	64.00	LTD	540.0	130.00	7.49	300		0.48	LTD	LTD	48.00	62	LTD	1.400	50	100
Flat Bay (East)	#1 Well	Nov 10, 2025	150.00	LTD	1,600.0	18.00	8.95	880		0.19	0.47	LTD	4.10	370	0.490	2.600	280	47
Flat Bay West																		
Flat Bay West	#3 Well	Nov 10, 2025	77.00	LTD	290.0	47.00	8.01	160		0.96	LTD	LTD	15.00	31	LTD	1.200	40	16
Fleur de Lys																		
Fleur De Lys	First Pond, Narrow Pond	Nov 12, 2025	6.60	35	95.0	12.00	6.82	53		0.56	LTD	LTD	2.80	20	LTD	0.620	13	2
Forteau																		
Forteau	Trout Brook	Nov 27, 2025	130.00	14	270.0	130.00	7.96	150		0.33	LTD	LTD	37.00	9	LTD	0.380	6	2
Fox Roost-Margaree																		
Fox Roost-Margaree	Drilled Well and Margaree Pond	Dec 01, 2025	LTD	130	70.0	6.40	5.10	39		0.64	LTD	LTD	1.00	13	LTD	0.550	7	2
Fox Roost-Margaree - PWDU	Drilled Well and Margaree Pond	Dec 01, 2025	LTD	LTD	7.4	LTD	6.01	4		0.88	LTD	LTD	LTD	LTD	LTD	LTD	0	LTD
Frenchman's Cove																		
Frenchman's Cove	Dug Well	Nov 18, 2025	5.50	15	150.0	16.00	6.63	82		0.25	LTD	LTD	2.40	34	LTD	1.200	19	5
Freshwater																		
Freshwater (Carbonear)	#2 Well - Covage's Lane Well	Dec 16, 2025	51.00	LTD	160.0	54.00	7.60	88		LTD	LTD	LTD	20.00	12	LTD	0.280	9	9
Freshwater (Carbonear)	#3 Well - Wallace Snow Well	Dec 16, 2025	94.00	LTD	1,100.0	260.00	7.78	630		LTD	LTD	LTD	73.00	270	LTD	1.100	100	46
Gander																		
Gander	Gander Lake	Nov 26, 2025	23.00	14	72.0	5.70	7.36	40		1.10	LTD	LTD	1.30	6	LTD	0.170	12	LTD
Gaskiers																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality			15		6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter			A		A	A		C	C			A	C		A	A
Gaskiers																			
Gaskiers-Point La Haye - PWDU	Well	Nov 21, 2025	68.00	LTD	210.0	57.00	8.08	120		0.22	LTD	LTD	13.00	17	0.160	1.100	19	<u>3300</u>	
Georgetown																			
Georgetown	Drilled	Nov 26, 2025	56.00	LTD	180.0	58.00	7.61	98		0.11	LTD	LTD	19.00	18	LTD	0.380	12	11	
Glenburnie-Birchy Head-Shoal Brook																			
Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Nov 17, 2025	9.70	<u>68</u>	50.0	16.00	6.99	28		0.30	LTD	LTD	3.40	8	LTD	0.320	4	LTD	
Grand Bank																			
Grand Bank (Backup Supply)	Grand Bank Brook (Backup Supply)	Oct 09, 2025	6.60	<u>21</u>	71.0	16.00	6.54	40		1.10	LTD	LTD	4.70	15	LTD	0.260	7	2	
Grand Falls-Windsor																			
Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Nov 03, 2025	7.80	LTD	87.0	30.00	7.11	49		0.15	LTD	LTD	11.00	4	LTD	0.100	2	25	
Grates Cove																			
Grates Cove South End	#4 Stoyles Hill Well	Nov 27, 2025	86.00	LTD	440.0	100.00	7.88	240		0.10	LTD	LTD	30.00	72	LTD	0.970	37	7	
Grates Cove North End	#3 Frank Janes Well	Nov 27, 2025	120.00	LTD	300.0	100.00	7.82	170		LTD	LTD	LTD	28.00	23	LTD	0.950	19	5	
Grates Cove Centre	#1C Well	Nov 27, 2025	96.00	LTD	240.0	88.00	8.00	130		LTD	LTD	LTD	24.00	17	LTD	0.480	15	4	
Great Codroy																			
Great Codroy East	#1 Well	Nov 25, 2025	130.00	LTD	360.0	150.00	8.02	200		LTD	LTD	LTD	46.00	16	LTD	1.900	12	30	
Great Codroy West	#2 Well	Nov 25, 2025	240.00	LTD	510.0	230.00	7.95	280		LTD	LTD	LTD	64.00	17	LTD	2.400	12	9	
Green Island Brook																			
Green Island Brook	Green Island Brook	Nov 05, 2025	89.00	<u>40</u>	190.0	95.00	7.75	110		1.20	LTD	LTD	20.00	8	LTD	0.370	5	1	
Hampden																			
Hampden	Elliot Brook	Nov 18, 2025	23.00	<u>25</u>	75.0	30.00	7.08	42		0.15	LTD	LTD	10.00	8	LTD	0.330	3	1	
Happy Valley-Goose Bay																			
Happy Valley-Goose Bay	Spring Gulch	Nov 03, 2025	15.00	LTD	37.0	13.00	7.06	21		0.69	LTD	LTD	2.80	2	LTD	1.200	1	LTD	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Happy Valley-Goose Bay																		
Happy Valley-Goose Bay	Well Field (connect summer 2002)	Nov 03, 2025	38.00	LTD	120.0	37.00	7.22	68		0.88	LTD	LTD	8.60	14	LTD	2.400	7	2
Harbour Grace																		
Riverhead	Mercer's Rd. Well	Dec 02, 2025	75.00	LTD	450.0	97.00	7.92	250		LTD	LTD	LTD	27.00	84	LTD	0.550	47	11
Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Dec 19, 2025	94.00	LTD	230.0	87.00	8.05	130		LTD	LTD	LTD	27.00	11	LTD	0.280	9	7
Thickett	#1 Thicket Susie Galway Well	Dec 19, 2025	32.00	LTD	110.0	34.00	7.53	59		LTD	LTD	LTD	9.20	11	LTD	0.360	7	3
Thickett	#2 Thicket New Well	Dec 02, 2025	73.00	LTD	340.0	110.00	7.86	190		0.46	LTD	LTD	30.00	58	LTD	0.460	21	8
Harbour Grace South Lower	New Southside Well (Well#3)	Dec 19, 2025	83.00	LTD	200.0	63.00	8.00	110		0.30	LTD	LTD	18.00	12	LTD	0.520	17	7
Harbour Main-Chapel's Cove-Lakeview																		
Harbour Main, Chapel's Cove, Lakeview	Flynn's Hill Well	Nov 13, 2025	110.00	LTD	340.0	100.00	7.76	190		0.13	LTD	LTD	37.00	35	LTD	1.100	29	14
Harbour Main, Chapel's Cove, Lakeview	Holden's Road Well	Nov 13, 2025	84.00	LTD	240.0	85.00	7.49	130		0.15	LTD	LTD	31.00	17	LTD	1.100	12	8
Harry's Harbour																		
Harry's Harbour	#1C Well - Northeast Well	Nov 20, 2025	72.00	LTD	230.0	71.00	7.96	130		0.10	LTD	LTD	24.00	20	LTD	0.730	17	15
Harry's Harbour	#2 Well - Northwest Hill / Country Road	Nov 20, 2025	110.00	LTD	390.0	120.00	8.12	220		0.64	LTD	LTD	29.00	52	LTD	1.600	33	18
Harry's Harbour	#3 Well - South Well	Nov 20, 2025	99.00	LTD	280.0	110.00	8.00	160		0.10	LTD	LTD	38.00	20	LTD	1.000	12	14
Heart's Content																		
Heart's Content	Southern Cove Pond	Dec 02, 2025	3.50	10	49.0	4.10	<u>6.40</u>	27		0.35	LTD	LTD	0.88	10	LTD	0.170	7	LTD
Heart's Desire																		
Heart's Desire	Terrence Pond	Oct 08, 2025	3.50	LTD	63.0	7.90	<u>6.26</u>	35		0.13	LTD	LTD	1.90	15	LTD	0.290	7	2
Heart's Desire	Terrence Pond	Oct 08, 2025	4.10	LTD	62.0	7.60	<u>6.38</u>	34		0.30	LTD	LTD	1.80	15	LTD	0.280	7	2
Heart's Desire	Terrence Pond	Oct 08, 2025	2.90	LTD	63.0	8.30	<u>6.19</u>	35		0.26	LTD	LTD	2.10	16	LTD	0.280	7	2
Holyrood																		
Holyrood	Main Line	Nov 13, 2025	62.00	LTD	280.0	75.00	7.63	150		0.30	LTD	LTD	27.00	40	LTD	0.620	22	14

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Holyrood																		
Holyrood	O'Connell's Well	Nov 13, 2025	150.00	LTD	490.0	140.00	7.98	270		LTD	LTD	LTD	52.00	56	LTD	1.200	40	17
Holyrood	Woodford Station - Healey's Well and Quinlan's Well	Nov 13, 2025	150.00	LTD	490.0	150.00	8.04	270		0.11	LTD	LTD	53.00	54	LTD	1.300	41	17
Hopeall																		
Hopeall	Charles Cumby Well	Dec 02, 2025	79.00	LTD	220.0	67.00	7.72	120		LTD	LTD	LTD	19.00	20	LTD	0.860	17	4
Gilberts Hill	Gilberts Hill Well	Dec 02, 2025	37.00	6	120.0	31.00	7.16	69		1.00	LTD	LTD	9.00	12	LTD	1.200	11	3
Hopedale																		
Hopedale	American Pond	Oct 14, 2025	4.00	<u>18</u>	37.0	7.80	6.57	20		0.77	LTD	LTD	2.30	7	LTD	0.230	4	LTD
Humber Arm South																		
Frenchman's Cove Area	Gurges Pond	Nov 06, 2025	21.00	7	86.0	21.00	7.31	48		0.54	LTD	LTD	5.00	10	LTD	0.350	7	4
Isle aux Morts																		
Isle aux Morts	Burnt Ground Pond	Oct 08, 2025	14.00	<u>98</u>	100.0	39.00	7.72	56		1.10	LTD	LTD	15.00	18	LTD	0.280	3	1
Isle aux Morts	Burnt Ground Pond	Oct 08, 2025	14.00	<u>120</u>	100.0	39.00	7.68	56		1.20	LTD	LTD	15.00	18	LTD	0.260	3	1
Isle aux Morts	Burnt Ground Pond	Oct 08, 2025	13.00	<u>120</u>	96.0	35.00	7.49	54		1.10	LTD	LTD	13.00	17	LTD	0.270	3	1
Jackson's Arm																		
Jackson's Arm	Unnamed Brook	Nov 18, 2025	LTD	<u>23</u>	40.0	9.30	<u>5.50</u>	22		0.54	LTD	LTD	2.70	8	LTD	0.370	3	LTD
Jackson's Arm - PWDU	Unnamed Brook	Nov 18, 2025	LTD	LTD	22.0	LTD	<u>6.12</u>	12		LTD	LTD	LTD	0.11	LTD	LTD	LTD	0	LTD
Jackson's Cove-Langdon's Cove-Silverdale																		
Langdon's Cove	#3 Well Langdon's Cove Well	Nov 20, 2025	130.00	LTD	310.0	71.00	8.38	170		LTD	LTD	LTD	19.00	13	0.150	2.300	41	13
Jean de Baie																		
Jean de Baie	#1 Well	Nov 19, 2025	60.00	LTD	180.0	57.00	7.81	98		0.10	LTD	LTD	18.00	17	0.120	0.400	12	3
Kippens																		
Kippens	Well Field	Dec 04, 2025	160.00	LTD	350.0	150.00	8.06	190		0.28	LTD	LTD	40.00	12	LTD	0.790	11	5
L'Anse au Clair																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality			15		6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter			A		A	A		C	C			A	C		A	A
L'Anse au Clair																			
L'Anse au Clair	Park Pond	Nov 26, 2025	130.00	6	270.0	130.00	7.98	150		0.22	LTD	LTD	39.00	8	LTD	0.540	5	3	
L'Anse au Loup																			
L'Anse au Loup	L'anse Au Loup River	Nov 27, 2025	21.00	<u>18</u>	47.0	13.00	7.15	26		1.10	LTD	LTD	3.50	6	LTD	0.180	4	LTD	
Labrador City																			
Labrador City	Beverly Lake	Oct 22, 2025	52.00	LTD	110.0	48.00	7.70	63		0.54	LTD	LTD	11.00	4	LTD	1.600	1	3	
Lance Cove																			
Lance Cove	Local Service District Well	Nov 21, 2025	110.00	LTD	380.0	92.00	8.02	210		LTD	LTD	LTD	30.00	45	0.110	1.900	32	13	
Lewisporte																			
Lewisporte	Stanhope Pond	Nov 05, 2025	10.00	<u>20</u>	62.0	15.00	6.74	34		0.22	LTD	LTD	4.30	10	LTD	0.230	6	1	
Mainland																			
Mainland	Caribou Brook	Nov 28, 2025	180.00	LTD	420.0	180.00	8.27	230		0.13	LTD	LTD	55.00	25	LTD	0.590	14	7	
Makinsons																			
Turkswater & Hodgewater Line West	Country Path Wells	Nov 26, 2025	120.00	LTD	390.0	8.40	<u>9.20</u>	220		LTD	LTD	LTD	2.40	45	LTD	0.590	79	15	
Hodgewater Line East & Juniper Stump	Taylor's Wells	Nov 26, 2025	91.00	LTD	460.0	150.00	7.92	260		0.11	LTD	LTD	42.00	84	LTD	0.540	37	14	
Makkovik																			
Makkovik	Ranger Bight Pond	Oct 14, 2025	6.80	<u>37</u>	40.0	11.00	6.79	22		0.67	LTD	LTD	3.30	6	0.160	0.220	4	LTD	
Makkovik - PWDU	Ranger Bight Pond	Oct 14, 2025	4.30	LTD	29.0	5.80	6.70	16		LTD	LTD	LTD	1.80	6	LTD	0.170	3	LTD	
Mary's Harbour																			
Mary's Harbour	St. Mary's River	Nov 27, 2025	LTD	<u>77</u>	34.0	2.80	<u>6.00</u>	19		0.66	LTD	LTD	0.66	7	LTD	LTD	6	LTD	
Mary's Harbour - PWDU	St. Mary's River	Nov 27, 2025	LTD	6	2.9	LTD	<u>5.79</u>	2		LTD	LTD	LTD	LTD	LTD	LTD	LTD	0	LTD	
Marystown																			
Marystown	Fox Hill Reservoir / Clam Pond	Nov 17, 2025	7.00	LTD	110.0	9.90	6.92	62		0.21	LTD	LTD	2.90	25	LTD	0.270	17	2	
Marysvale																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality		15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter		A			A	A		C	C			A	C		A	A
Marysvale																			
Marysvale, Long Pond	Drilled	Nov 26, 2025	21.00	LTD	120.0	26.00	6.90	66		1.20	LTD	LTD	6.60	22	LTD	0.560	12	5	
Mattis Point																			
Mattis Point	Drilled	Nov 10, 2025	84.00	LTD	260.0	43.00	8.08	140		0.72	LTD	LTD	14.00	21	0.170	0.280	36	13	
McCallum																			
McCallum	Drilled	Dec 04, 2025	17.00	220	130.0	25.00	6.78	73		1.80	LTD	LTD	7.80	24	LTD	0.440	18	3	
Ming's Bight																			
Ming's Bight	Middle Brook Pond	Nov 13, 2025	15.00	35	60.0	19.00	7.24	34		0.24	LTD	LTD	5.60	7	LTD	0.120	4	2	
Mount Pearl																			
Mount Pearl	Bay Bulls Big Pond	Nov 26, 2025	21.00	LTD	94.0	25.00	7.40	52		0.11	LTD	LTD	8.90	16	LTD	0.250	8	2	
Nain																			
Nain	Trouser Lake	Oct 14, 2025	6.00	5	26.0	6.90	6.88	15		0.35	LTD	LTD	1.90	3	LTD	0.170	2	LTD	
Natuashish																			
Natuashish (Sango Bay)	Sango Brook and Wellfield	Nov 09, 2025	67.00	LTD	1,100.0	97.00	7.90	590		0.14	0.17	LTD	13.00	260	2.100	8.700	160	41	
New Harbour																			
New Harbour	Williams Hill Well	Nov 26, 2025	110.00	LTD	270.0	85.00	7.97	150		0.75	LTD	LTD	26.00	15	LTD	1.900	25	5	
Norris Arm																			
Norris Arm (south)	Mill Lake	Nov 05, 2025	3.40	9	44.0	11.00	6.05	25		0.40	LTD	LTD	3.00	9	LTD	0.340	3	1	
North West River																			
North West River	Wellfield (Well # 1 & Well # 2)	Nov 03, 2025	76.00	LTD	200.0	83.00	7.98	110		0.34	LTD	LTD	26.00	1	0.440	3.400	3	25	
O'Donnells																			
O'Donnell's	Well Field	Nov 21, 2025	120.00	LTD	390.0	55.00	8.03	220		0.13	LTD	LTD	15.00	46	0.590	1.500	57	16	
O'Regans East																			
O'Regan's East	Drilled	Nov 25, 2025	130.00	LTD	430.0	140.00	7.68	240		LTD	LTD	LTD	46.00	41	LTD	3.500	27	15	
Paradise																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality		15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter		A			A	A		C	C			A	C		A	A
Paradise																			
Paradise	Bay Bulls Big Pond	Nov 26, 2025	23.00	LTD	95.0	24.00	7.66	53		LTD	LTD	LTD	8.60	16	LTD	0.220	7	1	
Petley																			
Petley	Drilled + Dug Reservoir	Dec 09, 2025	63.00	5	220.0	65.00	7.87	120		LTD	LTD	LTD	23.00	21	LTD	0.900	15	11	
Petty Harbour-Maddox Cove																			
Petty Harbour-Maddox Cove	Western Barrens Pond	Nov 18, 2025	8.80	8	58.0	5.30	7.21	32		0.37	LTD	LTD	1.40	11	LTD	0.210	9	2	
Piccadilly Head																			
Piccadilly Head (+West Bay)	Unnamed Brook	Nov 26, 2025	5.00	<u>75</u>	62.0	3.50	6.55	34		1.00	LTD	LTD	0.83	13	LTD	0.180	11	LTD	
Piccadilly Slant-Abraham's Cove																			
Abraham's Cove	#2 Well - Abraham's Cove	Dec 11, 2025	190.00	10	470.0	210.00	7.94	260		0.28	LTD	LTD	74.00	29	LTD	1.500	19	8	
Piccadilly Slant	#1 Well - Piccadilly Slant	Dec 11, 2025	220.00	LTD	490.0	240.00	7.97	270		LTD	LTD	LTD	68.00	30	LTD	1.200	17	15	
Point of Bay																			
Point of Bay	Indian Cove Pond	Nov 17, 2025	24.00	<u>24</u>	76.0	15.00	7.15	42		0.33	LTD	LTD	4.50	13	LTD	0.220	10	1	
Port Blandford																			
Port Blandford	Noseworthy's Pond	Dec 10, 2025	9.70	13	150.0	10.00	7.15	81		0.15	LTD	LTD	3.40	32	LTD	0.200	24	5	
Port Kirwan																			
Port Kirwan	Developed Spring	Nov 20, 2025	13.00	LTD	89.0	18.00	6.75	49		LTD	LTD	LTD	5.10	15	LTD	0.580	8	4	
Port au Port East																			
Port au Port East	Drilled Well - 75-80% Berry Head Watershed - 20-25%	Dec 09, 2025	180.00	LTD	400.0	190.00	8.00	220		LTD	LTD	LTD	49.00	18	LTD	0.640	10	5	
Port au Port West-Aguathuna-Felix Cove																			
Port au Port West, Aguathuna	#1 & #3 & #6 FatherJoy's Well	Dec 09, 2025	200.00	LTD	510.0	210.00	8.00	280		LTD	0.05	LTD	54.00	39	0.320	2.100	23	11	
Felix Cove	#4-Goose Pond Road Well	Dec 12, 2025	260.00	LTD	550.0	260.00	7.99	300		LTD	LTD	LTD	67.00	27	0.130	1.100	17	7	
Felix Cove	#5 Ocean View Drive Well	Dec 12, 2025	260.00	LTD	600.0	10.00	8.05	340		LTD	0.05	LTD	2.50	39	0.180	0.290	140	8	
Portugal Cove-St. Phillips																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality		15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter		A			A	A		C	C			A	C		A	A
Portugal Cove-St. Phillips																			
Portugal Cove-St. Phillips	Bay Bulls Big Pond	Nov 26, 2025	23.00	LTD	99.0	26.00	7.60	55		LTD	LTD	LTD	9.20	16	LTD	0.250	8	1	
Postville																			
Postville	Big Pond	Oct 14, 2025	6.60	<u>24</u>	62.0	5.40	6.84	34		0.21	LTD	LTD	1.40	12	LTD	0.290	10	LTD	
Postville - PWDU	Big Pond	Oct 14, 2025	LTD	LTD	4.0	LTD	<u>6.08</u>	2		LTD	LTD	LTD	LTD	LTD	LTD	LTD	0	LTD	
Pouch Cove																			
Pouch Cove	North Three Island Pond	Nov 13, 2025	5.70	LTD	59.0	5.90	6.96	33		LTD	LTD	LTD	1.40	13	LTD	0.290	9	1	
Raleigh																			
Raleigh	#4 Well	Nov 05, 2025	180.00	LTD	440.0	95.00	8.23	240		0.29	0.10	LTD	24.00	29	LTD	4.200	53	12	
Ramea																			
Ramea	Northwest Pond	Dec 02, 2025	9.60	<u>22</u>	310.0	47.00	7.33	170		1.10	LTD	LTD	13.00	58	LTD	1.400	39	37	
Ramea - PWDU	Northwest Pond	Dec 02, 2025	6.70	LTD	250.0	31.00	7.23	140		0.16	LTD	LTD	8.10	48	LTD	1.200	33	27	
Random Sound West																			
North West Brook, Ivany Cove	#2 Well	Dec 08, 2025	73.00	LTD	180.0	61.00	7.84	100		0.10	LTD	LTD	22.00	16	LTD	0.230	15	10	
North West Brook, Ivany Cove	#3 Well - Harbour Well	Dec 08, 2025	71.00	12	330.0	75.00	7.82	180		LTD	LTD	LTD	27.00	52	LTD	0.390	36	10	
Red Bay																			
Red Bay	Northern Brook	Nov 27, 2025	3.10	<u>28</u>	37.0	3.20	<u>6.39</u>	20		0.40	LTD	LTD	0.62	8	LTD	0.110	6	LTD	
Red Harbour																			
Red Harbour	1A Well Drilled + 1C Dug Well (back-up)	Nov 19, 2025	100.00	8	270.0	92.00	8.06	150		LTD	LTD	LTD	33.00	21	0.140	0.530	17	4	
Reidville																			
Reidville	Humber Canal, Grand Lake	Nov 04, 2025	9.30	15	47.0	12.00	6.79	26		0.49	LTD	LTD	3.80	8	LTD	0.240	3	LTD	
Renews-Cappahayden																			
Cappahayden	#1 Dinn's Well	Nov 19, 2025	110.00	LTD	330.0	110.00	8.01	180		0.55	LTD	LTD	27.00	35	0.130	2.200	28	10	
Rigolet																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality			15		6.5 - 8.5	500		1.0	5.0		250	1.5		200	500	
			Aesthetic (A) or Contaminant (C) Parameter			A		A	A		C	C		A	C		A	A	
Rigolet																			
Rigolet	Rigolet Pond	Oct 14, 2025	8.80	81	77.0	8.80	6.86	43		0.76	LTD	LTD	2.60	15	LTD	0.110	13	LTD	
Rigolet - PWDU	Rigolet Pond	Oct 14, 2025	2.10	LTD	28.0	LTD	6.21	16		LTD	LTD	LTD	0.12	LTD	LTD	LTD	1	LTD	
Sandringham																			
Sandringham	Drilled	Dec 10, 2025	14.00	LTD	290.0	23.00	6.73	160		0.10	LTD	LTD	7.20	68	LTD	1.400	42	9	
Sandy Cove																			
Sandy Cove	Dug	Dec 10, 2025	27.00	LTD	140.0	24.00	7.19	76		LTD	LTD	LTD	7.40	22	LTD	0.920	16	4	
Sheaves Cove																			
Sheaves Cove	Drilled	Dec 10, 2025	200.00	LTD	640.0	240.00	7.94	350		LTD	LTD	LTD	75.00	55	LTD	0.940	35	44	
Sheppardville																			
Sheppardville	Drilled	Nov 26, 2025	65.00	LTD	150.0	52.00	7.82	85		LTD	LTD	LTD	18.00	6	0.300	0.250	11	4	
Sheshatshiu																			
Sheshatshui - Indian Band Council	Wells 1, 2 & 3	Nov 03, 2025	120.00	LTD	460.0	94.00	7.65	250		0.84	0.07	LTD	23.00	64	0.320	4.400	47	22	
Ship Cove-Lower Cove-Jerry's Nose																			
Ship Cove, Jerry's Nose	#5 Well - Murdock Wheeler Well	Dec 10, 2025	240.00	LTD	540.0	260.00	7.94	300		LTD	LTD	LTD	62.00	29	LTD	1.200	20	6	
Lower Cove	#6 Well - Lower Cove Well	Dec 10, 2025	220.00	15	700.0	270.00	7.90	390		LTD	LTD	LTD	74.00	85	LTD	1.200	44	10	
Ship Cove, Jerry's Nose	#2 Well - Howard & Rodney Jesso Well	Dec 10, 2025	250.00	LTD	610.0	250.00	7.94	340		0.65	LTD	LTD	74.00	43	LTD	1.400	30	11	
Ship Cove, Jerry's Nose	#1 Well - P.J's Variety Well	Dec 10, 2025	260.00	LTD	770.0	260.00	7.88	430		LTD	LTD	LTD	79.00	87	LTD	1.700	56	13	
Ship Cove, Jerry's Nose	#4B Well - Nancy Rowe Well	Dec 10, 2025	150.00	12	500.0	200.00	7.97	280		0.40	LTD	LTD	62.00	45	0.110	1.400	24	31	
Small Point-Adam's Cove-Blackhead-Broad Cove																			
Adam's Cove	#1 Well - Reg Bursey Well	Nov 28, 2025	92.00	LTD	270.0	82.00	8.00	150		LTD	LTD	LTD	21.00	18	0.140	0.460	25	17	
Blackhead + Adam's Cove	#4 Well - Leonard King Well	Nov 28, 2025	88.00	LTD	320.0	120.00	7.99	180		LTD	LTD	LTD	30.00	28	0.140	0.540	15	22	
Broad Cove	#6 Well - Herb Trickett Well	Nov 28, 2025	110.00	LTD	310.0	110.00	7.99	170		0.14	LTD	LTD	31.00	24	LTD	1.200	21	9	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Small Point-Adam's Cove-Blackhead-Broad Cove																		
Small Point	#8 Well - Effie Flight Wells	Nov 28, 2025	97.00	LTD	310.0	110.00	7.80	170		LTD	LTD	LTD	25.00	34	LTD	0.640	19	8
Small Point	#9 Well - Walter Reynolds Well	Nov 28, 2025	21.00	LTD	140.0	29.00	6.99	80		LTD	LTD	LTD	7.80	22	LTD	0.890	15	5
Broad Cove	#10 Well - Cantwood Hill Well	Nov 28, 2025	97.00	LTD	300.0	110.00	8.01	170		0.10	LTD	LTD	30.00	25	LTD	1.900	14	15
Smith's Sound																		
Harcourt-Monroe-Waterville	Developed Spring	Dec 05, 2025	16.00	LTD	56.0	15.00	7.09	31		0.19	LTD	LTD	3.90	6	LTD	0.410	4	2
South Dildo																		
South Dildo	#5 Well - Calvin Reid Well	Nov 26, 2025	86.00	LTD	290.0	62.00	7.92	160		0.11	0.07	LTD	18.00	30	0.160	2.000	33	11
Springdale																		
Springdale Industrial Park	Well	Nov 20, 2025	84.00	LTD	240.0	86.00	8.08	130		0.12	LTD	LTD	27.00	21	0.110	0.920	14	7
St. Alban's																		
St. Alban's	Well Field	Nov 12, 2025	2.10	<u>210</u>	50.0	8.20	<u>5.76</u>	28		0.97	LTD	LTD	1.80	10	LTD	0.370	6	2
St. Andrews																		
St. Andrew's	#1 Well	Nov 25, 2025	120.00	8	550.0	160.00	7.67	310		0.44	LTD	LTD	50.00	87	LTD	3.800	30	9
St. Andrew's	#2 Well	Nov 25, 2025	150.00	LTD	660.0	54.00	8.01	360		0.34	LTD	LTD	17.00	100	0.250	2.700	97	9
St. Andrew's East	#3 Well	Nov 25, 2025	120.00	6	440.0	66.00	7.85	240		0.35	LTD	LTD	21.00	54	LTD	3.800	55	11
Air Strip Road	#4 Well Strip Road Well	Nov 25, 2025	170.00	LTD	500.0	120.00	8.08	280		0.27	0.06	LTD	37.00	47	0.230	4.000	52	9
St. Anthony																		
St. Anthony	St. Anthony Pond	Nov 05, 2025	16.00	<u>36</u>	70.0	26.00	7.02	39		0.36	LTD	LTD	2.30	9	LTD	0.360	3	1
St. George's																		
St. George's	Wellfield	Nov 10, 2025	56.00	LTD	270.0	51.00	7.57	150		0.22	LTD	LTD	13.00	44	LTD	0.970	32	8
St. John's																		
St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Nov 25, 2025	22.00	6	96.0	25.00	7.47	53		0.45	LTD	LTD	9.10	16	LTD	0.240	7	1

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
St. John's																		
St. John's	Windsor Lake	Nov 25, 2025	34.00	LTD	140.0	39.00	7.54	77		0.33	LTD	LTD	14.00	22	LTD	0.320	12	3
St. John's	Petty Harbour Long Pond	Nov 25, 2025	45.00	LTD	120.0	48.00	7.70	69		LTD	LTD	LTD	18.00	12	LTD	0.290	5	1
St. Joseph's																		
St. Joseph's S.M.B.	Drilled	Nov 21, 2025	100.00	LTD	240.0	59.00	8.30	130		0.16	LTD	LTD	17.00	13	0.380	1.200	25	8
St. Lewis																		
St. Lewis	Tub Harbour Pond	Nov 27, 2025	4.00	<u>91</u>	61.0	13.00	<u>6.36</u>	34		0.55	LTD	LTD	3.60	13	LTD	0.350	7	2
St. Lunaire-Griquet																		
St. Lunaire-Griquet	Drilled	Nov 05, 2025	250.00	10	810.0	43.00	8.17	450		0.19	0.15	LTD	10.00	110	LTD	5.900	150	7
St. Mary's																		
St. Mary's	Wellfield	Nov 21, 2025	100.00	LTD	290.0	44.00	8.28	160		LTD	LTD	LTD	10.00	19	0.500	1.000	42	21
St. Patricks																		
St. Patricks	David Joy Well	Nov 20, 2025	110.00	LTD	330.0	100.00	8.08	180		LTD	LTD	LTD	33.00	30	LTD	1.200	23	16
St. Pauls																		
St. Pauls	Two Mile Pond	Nov 18, 2025	68.00	<u>18</u>	240.0	88.00	7.61	140		1.10	LTD	LTD	28.00	30	LTD	0.950	15	7
Stephenville																		
Stephenville	Well Field	Dec 04, 2025	170.00	LTD	380.0	160.00	8.06	210		0.13	LTD	LTD	47.00	17	LTD	0.990	18	7
Stephenville Crossing																		
Stephenville Crossing	Well Fields 1 & 2	Dec 04, 2025	170.00	LTD	470.0	170.00	7.99	260		LTD	LTD	LTD	50.00	48	LTD	1.200	25	6
Sunnyside (T.B.)																		
Sunnyside	Center Cove River	Nov 03, 2025	5.10	<u>36</u>	55.0	6.20	6.77	31		0.73	LTD	LTD	1.70	10	LTD	0.200	8	LTD
Swift Current																		
Swift Current (Hollett's Point)	Drilled	Nov 20, 2025	23.00	<u>40</u>	120.0	24.00	7.11	68		0.50	LTD	LTD	5.90	21	LTD	0.630	14	2
Terrenceville																		
Terrenceville	Big Brook	Nov 17, 2025	LTD	<u>67</u>	21.0	3.60	<u>6.04</u>	12		0.65	LTD	LTD	0.89	4	LTD	0.230	3	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality			15		6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter			A		A	A		C	C			A	C		A	A
Tompkins																			
Tompkins	Greg Wall Well	Nov 25, 2025	130.00	LTD	480.0	110.00	7.97	270		LTD	0.06	LTD	32.00	57	0.150	3.200	49	23	
Torbay																			
Torbay	North Pond	Nov 13, 2025	11.00	<u>22</u>	97.0	8.40	7.30	54		1.50	LTD	LTD	1.90	18	LTD	0.420	15	4	
Trout River																			
Trout River	Feeder Brook	Nov 17, 2025	53.00	<u>16</u>	170.0	63.00	7.69	92		0.33	LTD	LTD	6.50	17	LTD	0.220	11	4	
Upper Ferry																			
Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	Nov 25, 2025	160.00	LTD	370.0	160.00	7.96	210		LTD	LTD	LTD	45.00	14	LTD	1.500	8	2	
Upper Ferry - Middle	#2 Well - Hughie MacIssac Well	Nov 25, 2025	100.00	LTD	260.0	100.00	7.89	140		LTD	LTD	LTD	31.00	16	LTD	1.800	10	6	
Upper Ferry - Upper	#3 Well - Marshall Devoe Well	Nov 25, 2025	140.00	7	340.0	140.00	7.98	190		LTD	LTD	LTD	42.00	17	LTD	2.100	10	7	
Upper Ferry	#4 Well - Angus MacNeil Well	Nov 25, 2025	190.00	LTD	570.0	82.00	8.14	320		LTD	0.16	LTD	21.00	47	0.300	6.100	79	32	
Wabana																			
Wabana	#3 Yard West Mines Road	Nov 21, 2025	120.00	12	320.0	110.00	7.96	180		0.24	LTD	LTD	30.00	30	LTD	0.780	22	6	
Wabana	Normore Crescent East #1	Nov 21, 2025	130.00	14	400.0	120.00	8.06	220		LTD	LTD	LTD	36.00	43	LTD	1.600	34	14	
Wabana	Quigley's Line	Nov 21, 2025	150.00	11	410.0	130.00	8.08	230		LTD	LTD	LTD	41.00	41	LTD	1.700	28	13	
Wabana	Scotia #1	Nov 21, 2025	120.00	11	290.0	77.00	8.11	160		LTD	LTD	LTD	21.00	21	LTD	0.770	29	4	
Wabana	St. Edward's Memorial St.	Nov 21, 2025	170.00	LTD	480.0	11.00	<u>9.15</u>	270		0.71	0.05	LTD	3.50	42	0.310	1.100	110	12	
Wabana	Mixed Supplies	Nov 21, 2025	140.00	LTD	420.0	130.00	7.99	230		0.16	LTD	LTD	43.00	43	0.100	1.700	34	19	
Wabana	Mixed Supplies	Nov 21, 2025	140.00	LTD	440.0	120.00	8.05	250		0.44	LTD	LTD	40.00	46	0.110	1.700	35	20	
Wabana	Mixed Supplies	Nov 21, 2025	140.00	LTD	410.0	130.00	7.97	230		0.59	LTD	LTD	43.00	40	0.100	1.500	30	19	
Wabana - PWDU	#3 Yard West Mines Road	Nov 21, 2025	3.70	LTD	10.0	LTD	6.66	6		LTD	LTD	LTD	LTD	1	LTD	LTD	2	LTD	
Wabush																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality			15		6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
			Aesthetic (A) or Contaminant (C) Parameter			A		A	A		C	C			A	C		A	A
Wabush																			
Wabush	Wahnahnish Lake	Oct 22, 2025	41.00	LTD	88.0	38.00	7.58	49		0.29	LTD	LTD	9.10	2	LTD	0.930	0	3	
West St. Modeste																			
West St. Modeste	Well Field	Nov 27, 2025	83.00	<u>37</u>	230.0	41.00	7.71	130		0.28	0.08	LTD	10.00	19	0.380	2.400	33	5	
Westport																			
Westport	Western Brook Pond	Nov 12, 2025	6.20	<u>110</u>	35.0	9.00	6.62	19		0.42	LTD	LTD	2.60	5	LTD	0.400	3	LTD	
Winterland																			
Winterland	Well Field	Nov 18, 2025	100.00	8	320.0	110.00	7.96	180		LTD	LTD	LTD	36.00	33	1.200	0.520	20	5	
Woody Point																			
Woody Point	Winterhouse Brook	Nov 17, 2025	36.00	<u>30</u>	100.0	40.00	7.61	57		0.52	LTD	LTD	2.50	10	LTD	0.180	7	LTD	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
		Guidelines for Canadian Drinking Water Quality		15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
		Aesthetic (A) or Contaminant (C) Parameter		A			A	A		C	C			A	C		A	A

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

Quality Assurance / Quality Control (QA/QC) - The department is striving to improve the quality of the data using standard QA/QC protocols. This is an evolving process which may result in minor changes to the reported data.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

The exceedance report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ.

Aesthetic (A) Parameters - Aesthetic parameters reflect substances or characteristics of drinking water that can affect its acceptance by consumers but which usually do not pose any health effects. Aesthetic exceedances are highlighted in blue text and underlined.

Contaminants (C) - Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in red text and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant and Aesthetic Exceedances

Turbidity - The maximum acceptable concentration for turbidity is 1 NTU. Turbidity refers to the water's ability to transmit light or the cloudiness of the water. Turbidity in tap water can be the result of turbid raw water and influences within the distribution system. Turbidity is usually the result of fine organic and inorganic particles which do not settle out. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process.

Boron - The interim maximum acceptable concentration for boron in drinking water is 5.0 mg/L. Boron is widespread in the environment, occurring naturally in over 80 minerals and in the earth's crust. Levels in well water have been reported to be more variable and often higher than those in surface waters, most likely due to erosion from natural resources. High levels of this contaminant can cause adverse health effects for some people

Fluoride - The maximum acceptable concentration for fluoride in drinking water is 1.5mg/L.The fluoride concentration in natural water varies widely as it depends on such factors as the source of the water and the geological formations present. Trace amounts of fluoride may be essential for human nutrition and the presence of small quantities leads to a reduction of dental caries. High levels of this contaminant can cause adverse health effects for some people.

Colour - An aesthetic objective of 15 true colour units (TCU) has been established for colour in drinking water. Colour in drinking water may be due to the presence of coloured organic substances or metals such as iron, manganese and copper. Highly coloured industrial wastes also contribute to colour. The presence of colour is not directly linked to health but it can be aesthetically displeasing.

pH -The acceptable range for drinking water pH is 6.5 - 8.5. The control of pH is primarily based on minimizing corrosion and encrustation in the distribution system. Tap water with low pH may accelerate the corrosion process in the distribution system, and contribute to increased levels of copper, lead and possibly other metals. Incrustation and scaling problems may become more frequent above pH 8.5

TDS - The aesthetic objective for TDS in drinking water is 500 mg/L. The term "total dissolved solids"(TDS) refers mainly to the inorganic substances that are dissolved in water. At low levels TDS contributes to the palatability of water. At high levels it may cause excessive hardness, taste, mineral deposition and corrosion.

Chloride - The aesthetic objective for chloride in drinking water is 250 mg/L. Chloride can be in water from a variety of sources, including the dissolution of salt deposits and salting of roads for ice control. No evidence has been found suggesting that ingestion of chloride is harmful to humans. However, high levels of chloride in water can impart undesirable tastes to water and beverages prepared from water.

Sodium - The aesthetic objective for sodium in drinking water is 200 mg/L. Since the body has very effective means to control levels of sodium, sodium is not an acutely toxic element in the normal range of environmental or dietary concentrations. At extremely high dosages it has adverse health effects. Sodium levels may be of interest to authorities who wish to prescribe sodium restricted diets for their patients..

Sulphate - The aesthetic objective for sulphate in drinking water is 500 mg/L. Sulphates, which occur naturally in numerous minerals, are used in the mining and pulping industries and in wood preservation. Large quantities of sulphate can result in catharsis and gastrointestinal irritation. The presence of sulphate above the aesthetic limit can result in noticeable taste. Some sensitive individuals may find the taste objectionable at lower sulphate concentrations

mg/L = milligrams per litre or parts per million µS/cm = micro Siemens per centimeter NTU = nephelometric turbidity units TDS = total dissolved solids TSS = total suspended solids TCU = true colour units Nitrate(ite) = Nitrate + Nitrite DOC = dissolved organic carbon

Notes:
Guidelines for Canadian Drinking Water Quality have not been developed for all the parameters listed in this report.
pH has no units