



Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	C	C	A	C	A	A	A						
Aesthetic (A) or Contaminant (C) Parameter																		
Anchor Point																		
Anchor Point	Well Cove Brook	Aug 12, 2025	100.00	<u>22</u>	230.0	110.00	7.82	130		0.89	LTD	LTD	22.00	14	LTD	0.310	6	1
Appleton																		
Appleton (+Glenwood)	Gander Lake (The Outflow)	Aug 27, 2025	LTD	<u>37</u>	26.0	6.40	<u>5.43</u>	14		0.41	LTD	LTD	1.50	6	LTD	0.170	2	LTD
Aquaforte																		
Aquaforte	Davies Pond	Aug 12, 2025	3.30	7	69.0	4.10	6.55	39		0.52	LTD	LTD	0.82	18	LTD	0.290	11	2
Arnold's Cove																		
Arnold's Cove	Steve's Pond (2 Intakes)	Aug 19, 2025	13.00	<u>16</u>	61.0	6.00	7.32	34		0.28	LTD	LTD	1.60	9	LTD	0.180	9	1
Avondale																		
Avondale	Lees Pond	Aug 25, 2025	6.50	LTD	76.0	11.00	7.52	42		0.26	LTD	LTD	3.80	15	LTD	0.250	10	2
Baie Verte																		
Baie Verte	Southern Arm Pond	Sep 29, 2025	LTD	14	36.0	7.30	<u>5.34</u>	20		0.16	LTD	LTD	2.00	8	LTD	0.290	2	LTD
Baine Harbour																		
Baine Harbour	Baine Harbour Pond	Sep 10, 2025	4.60	<u>37</u>	41.0	8.60	6.60	23		1.00	LTD	LTD	2.40	6	LTD	0.170	5	5
Bartletts Harbour																		
Bartletts Harbour	Long Pond (same as Castors River North)	Aug 13, 2025	96.00	<u>26</u>	260.0	110.00	7.93	140		0.66	LTD	LTD	23.00	21	LTD	0.510	12	3
Bay L'Argent																		
Bay L'Argent	Sugarloaf Hill Pond	Sep 11, 2025	5.60	<u>28</u>	66.0	7.20	6.86	37		0.43	LTD	LTD	1.70	12	LTD	0.410	9	2
Bay Roberts																		
Bay Roberts	Rocky Pond	Aug 28, 2025	3.40	LTD	72.0	8.70	6.61	40		0.23	LTD	LTD	2.30	18	LTD	0.230	10	2
Bay de Verde																		
Bay de Verde	Island Pond	Sep 23, 2025	LTD	15	65.0	4.30	<u>5.64</u>	36		0.70	LTD	LTD	0.36	15	LTD	0.460	9	3
Beaches																		
Beaches	Grassey Pond Brook	Sep 17, 2025	17.00	<u>21</u>	59.0	21.00	7.53	33		0.77	LTD	LTD	6.90	5	LTD	1.200	3	2
Beachside																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500				1.0	5.0			250	1.5		200	500
Aesthetic (A) or Contaminant (C) Parameter				A	A	A				C	C			A	C		A	A
Beachside																		
Beachside	Long Pond	Sep 04, 2025	16.00	13	110.0	19.00	7.40	59		LTD	LTD	LTD	6.30	18	LTD	0.110	12	2
Bellburns																		
Bellburns	Bound Brook Tributary	Sep 11, 2025	180.00	14	410.0	190.00	8.21	230		0.33	LTD	LTD	48.00	15	LTD	0.720	10	6
Belleoram																		
Belleoram	Rabbits Pond	Aug 26, 2025	7.70	<u>54</u>	62.0	3.20	6.79	35		1.30	LTD	LTD	0.51	12	LTD	0.280	12	1
Bellevue																		
Bellevue	Big Pond	Aug 20, 2025	7.80	9	88.0	11.00	7.07	49		0.22	LTD	LTD	3.00	19	LTD	0.300	13	2
Bellevue Beach																		
Bellevue Beach	Unnamed Brook	Sep 08, 2025	4.00	<u>91</u>	61.0	9.70	<u>6.16</u>	34		0.96	LTD	LTD	2.40	11	LTD	0.180	7	4
Benton																		
Benton	Little Pond	Aug 19, 2025	2.10	<u>17</u>	140.0	6.70	<u>6.40</u>	79		0.29	LTD	LTD	1.80	36	LTD	0.310	25	3
Benton	Little Pond	Sep 15, 2025	2.80	11	150.0	6.50	6.67	86		1.60	LTD	LTD	1.70	41	LTD	0.290	27	3
Benton	Little Pond	Sep 15, 2025	2.60	10	150.0	7.10	6.54	86		0.84	LTD	LTD	1.90	40	LTD	0.330	30	3
Benton	Little Pond	Sep 15, 2025	3.30	12	150.0	6.00	6.52	86		0.90	LTD	LTD	1.60	40	LTD	0.280	25	3
Birchy Bay																		
Birchy Bay	Jumper's Pond	Aug 12, 2025	20.00	<u>17</u>	100.0	20.00	7.74	57		0.34	LTD	LTD	6.40	17	LTD	0.180	13	1
Bird Cove																		
Bird Cove (+Brig Bay)	Inner Gilmour Pond	Aug 13, 2025	97.00	<u>54</u>	220.0	98.00	7.99	120		0.78	LTD	LTD	21.00	9	LTD	0.390	7	2
Biscay Bay																		
Biscay Bay	Unnamed Pond	Aug 11, 2025	LTD	<u>28</u>	46.0	3.80	<u>5.64</u>	25		0.71	LTD	LTD	0.32	11	LTD	0.340	6	2
Bishop's Falls																		
Bishop's Falls	Northern Arm Lake	Aug 04, 2025	4.50	LTD	87.0	31.00	6.89	48		LTD	LTD	LTD	12.00	5	LTD	0.130	2	23
Black Duck Cove																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				Units															
				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500							
				Aesthetic (A) or Contaminant (C) Parameter	A	A	C	C	A	C	A	C	A	C	A	C	A	C	A
Black Duck Cove																			
Black Duck Cove	Long Pond - Black Duck Cove Intake	Aug 12, 2025	82.00	<u>32</u>	200.0	89.00	8.08	110		0.63	LTD	LTD	17.00	11	LTD	0.220	7	2	
Black Tickle-Domino																			
Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	Sep 05, 2025	5.10	<u>74</u>	90.0	8.50	6.60	50		3.60	LTD	LTD	1.00	18	LTD	0.750	14	2	
Black Tickle-Domino - PWDU	Martin's Pond - Tap at Pumphouse	Sep 05, 2025	5.10	LTD	16.0	LTD	6.86	9		1.70	LTD	LTD	LTD	2	LTD	0.210	3	LTD	
Bonavista																			
Bonavista	Long Pond	Sep 17, 2025	14.00	5	130.0	9.30	7.81	71		0.45	LTD	LTD	2.00	26	LTD	0.300	22	3	
Botwood																			
Botwood	Northern Arm Lake	Aug 04, 2025	6.20	LTD	87.0	32.00	7.22	48		LTD	LTD	LTD	12.00	4	LTD	0.120	2	24	
Branch																			
Branch	Drilled Wells	Sep 23, 2025	100.00	LTD	290.0	87.00	8.10	160		0.20	LTD	LTD	29.00	17	LTD	2.600	22	8	
Brent's Cove																			
Brent's Cove	Paddy's Pond	Aug 06, 2025	3.30	<u>88</u>	45.0	6.50	<u>6.43</u>	25		5.30	LTD	LTD	1.70	10	LTD	0.230	5	1	
Brig Bay																			
Brig Bay	Inner Gilmour Pond	Aug 13, 2025	97.00	<u>57</u>	220.0	97.00	8.02	120		0.98	LTD	LTD	20.00	9	LTD	0.370	6	2	
Brighton																			
Brighton	Hynes Cove Pond	Aug 26, 2025	16.00	7	100.0	19.00	7.37	58		0.45	LTD	LTD	5.50	18	LTD	0.190	13	2	
Brigus																			
Brigus (+Cupids, +South River)	Brigus Long Pond (to Brigus)	Sep 18, 2025	4.10	7	51.0	7.40	6.57	28		0.35	LTD	LTD	1.80	10	LTD	0.280	6	2	
Buchans																			
Buchans	Buchans Lake aka Sandy Lake	Aug 25, 2025	LTD	<u>20</u>	23.0	6.50	<u>6.03</u>	13		0.91	LTD	LTD	2.10	5	LTD	0.110	1	LTD	
Buchans Junction																			
Buchans Junction	Lapland Pond	Aug 25, 2025	6.20	LTD	67.0	5.60	6.78	37		0.88	LTD	LTD	1.70	15	LTD	LTD	11	LTD	
Burgeo																			
Burgeo	Long Pond	Sep 18, 2025	5.40	<u>130</u>	57.0	3.50	<u>6.29</u>	32		0.35	LTD	LTD	0.71	12	LTD	0.240	10	LTD	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	C	A	C	A	C	A	C	A	C	
Burin																		
Burin (+Lewin's Cove)	Big Pond	Sep 10, 2025	3.10	14	54.0	10.00	<u>6.32</u>	30		0.31	LTD	LTD	2.80	11	LTD	0.240	5	2
Burin	Long Pond	Sep 10, 2025	LTD	12	51.0	9.10	<u>6.04</u>	28		0.26	LTD	LTD	2.40	12	LTD	0.180	5	2
Port au Bras	Gripe Cove Pond	Sep 10, 2025	9.80	6	92.0	21.00	6.91	51		0.34	LTD	LTD	6.10	17	LTD	0.340	9	4
Burlington																		
Burlington	Eastern Island Pond	Sep 29, 2025	8.80	<u>23</u>	63.0	5.90	6.71	35		0.29	LTD	LTD	1.50	12	LTD	0.100	10	LTD
Burnt Islands																		
Burnt Islands	Long Lake	Sep 09, 2025	5.20	<u>46</u>	86.0	6.90	6.64	48		0.30	LTD	LTD	2.00	18	LTD	0.290	13	2
Burnt Islands - PWDU	Long Lake	Sep 09, 2025	2.20	LTD	25.0	LTD	<u>6.27</u>	14		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Campbellton																		
Campbellton	Indian Arm Brook	Aug 12, 2025	9.50	<u>22</u>	41.0	11.00	7.05	23		0.54	LTD	LTD	3.00	6	LTD	0.240	4	LTD
Cape Freels North																		
Cape Freels North	Long Pond	Aug 27, 2025	36.00	<u>440</u>	160.0	13.00	7.16	89		3.00	LTD	LTD	1.80	24	LTD	0.840	15	3
Cape Freels North	Long Pond	Sep 29, 2025	LTD	<u>200</u>	100.0	8.20	<u>5.79</u>	56		1.70	LTD	LTD	0.89	25	LTD	0.690	15	3
Cape Freels North	Long Pond	Sep 29, 2025	8.30	<u>250</u>	110.0	8.20	<u>6.36</u>	63		1.70	LTD	LTD	0.98	25	LTD	0.670	14	3
Cape St. George																		
Cape St. George, Red Brook, De-Grau, Marches Point	Rouzes Brook	Sep 19, 2025	210.00	LTD	470.0	220.00	8.25	260		LTD	LTD	LTD	54.00	21	LTD	0.880	12	6
Caplin Cove-Southport																		
Southport	Button's Pond	Sep 18, 2025	6.70	9	88.0	9.20	7.09	49		0.27	LTD	LTD	1.90	19	LTD	0.230	12	2
Carbonear																		
Carbonear	Little Island Pond	Aug 28, 2025	6.10	6	43.0	9.20	6.79	24		0.36	LTD	LTD	2.50	8	LTD	0.190	4	1
Carmanville																		
Carmanville	Grandfathers Pond	Aug 27, 2025	4.70	7	58.0	7.40	6.84	32		0.45	LTD	LTD	1.40	12	LTD	0.180	8	2
Cartwright																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	5.0	1.0	5.0	5.0	250	1.5	200	500		
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C					A	C	A	A		
Cartwright																		
Cartwright	Burdett's Pond	Aug 18, 2025	6.60	<u>74</u>	65.0	3.40	7.09	36		0.74	LTD	LTD	0.57	13	LTD	0.160	12	LTD
Cartwright - PWDU	Burdett's Pond	Aug 18, 2025	LTD	LTD	5.1	LTD	<u>6.27</u>	3		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Castor River North																		
Castor River North	Long Pond (same as Bartletts Harbour)	Aug 13, 2025	99.00	<u>27</u>	260.0	110.00	8.19	150		0.63	LTD	LTD	24.00	20	LTD	0.480	12	3
Castor River South																		
Castor River South	Unnamed	Aug 13, 2025	210.00	7	450.0	220.00	8.09	250		0.27	LTD	LTD	57.00	13	LTD	0.980	8	3
Cavendish																		
Cavendish	Long Pond	Sep 25, 2025	5.60	LTD	64.0	7.50	6.96	36		0.38	LTD	LTD	1.50	13	LTD	0.290	9	2
Centreville-Wareham-Trinity																		
Centreville-Wareham	Northwest Pond	Aug 19, 2025	4.40	13	48.0	5.80	6.52	27		0.30	LTD	LTD	1.40	10	LTD	0.170	8	LTD
Trinity	Southwest Feeder Pond	Aug 19, 2025	4.50	9	82.0	5.10	6.72	46		0.19	LTD	LTD	1.50	18	LTD	0.150	12	LTD
Chanceport																		
Chanceport	Bridger's Cove Pond	Aug 13, 2025	20.00	<u>76</u>	170.0	26.00	7.08	92		2.70	LTD	LTD	6.90	32	LTD	0.460	22	5
Channel-Port aux Basques																		
Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Sep 09, 2025	5.80	8	100.0	33.00	7.04	58		0.39	LTD	LTD	12.00	10	LTD	0.230	4	22
Charlottetown (Labrador)																		
Charlottetown (Labrador)	Middle Pond	Aug 18, 2025	LTD	<u>42</u>	31.0	5.40	<u>5.11</u>	17		0.88	LTD	LTD	1.20	7	LTD	0.210	2	LTD
Charlottetown (Labrador) - PWDU	Middle Pond	Aug 18, 2025	LTD	LTD	16.0	LTD	<u>5.58</u>	9		LTD	LTD	LTD	LTD	2	LTD	LTD	0	LTD
Churchill Falls																		
Churchill Falls	Smallwood Reservoir	Aug 01, 2025	6.90	10	29.0	11.00	6.80	16		0.64	LTD	LTD	3.00	3	LTD	0.310	1	LTD
Clareville																		
Clareville, Shoal Harbour	Shoal Harbour River	Aug 20, 2025	14.00	LTD	110.0	22.00	7.45	64		0.74	LTD	LTD	7.90	14	LTD	0.270	12	16
Clarke's Beach																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				Units															
				mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500							
				Aesthetic (A) or Contaminant (C) Parameter	A	A	C	C	A	C	A	C	A	C	A	C	A	C	
Clarke's Beach																			
Clarke's Beach	Clarke's Pond	Aug 28, 2025	LTD	LTD	37.0	6.70	<u>6.39</u>	21		0.15	LTD	LTD	1.60	8	LTD	0.210	4	2	
Colliers																			
Colliers	Bedlam Pond	Aug 25, 2025	4.10	LTD	49.0	4.30	6.88	27		0.88	LTD	LTD	0.85	11	LTD	0.310	8	1	
Come By Chance																			
Come By Chance	Butchers Brook	Aug 19, 2025	35.00	LTD	110.0	30.00	7.82	60		0.21	LTD	LTD	10.00	11	LTD	0.130	9	LTD	
Comfort Cove-Newstead																			
Comfort Cove-Newstead	Steady Cove Pond	Sep 16, 2025	9.20	<u>22</u>	91.0	19.00	6.72	50		0.46	LTD	LTD	4.70	18	LTD	0.840	8	2	
Conception Bay South																			
Conception Bay South	Bay Bulls Big Pond	Sep 16, 2025	21.00	LTD	97.0	24.00	7.55	54		LTD	LTD	LTD	8.70	15	LTD	0.210	7	1	
Conche																			
Conche	Martin's Brook	Aug 11, 2025	7.00	<u>63</u>	59.0	11.00	6.90	33		0.57	LTD	LTD	3.40	12	LTD	0.200	7	5	
Conne River																			
Conne River	Southwest Brook	Aug 20, 2025	8.90	LTD	29.0	2.40	7.24	16		LTD	LTD	LTD	0.66	3	LTD	0.150	6	LTD	
Cook's Harbour																			
Cook's Harbour	Unnamed Pond	Aug 12, 2025	87.00	14	330.0	100.00	7.95	180		0.69	LTD	LTD	36.00	46	LTD	0.780	20	5	
Corner Brook																			
Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Sep 17, 2025	23.00	LTD	96.0	20.00	7.55	54		0.28	LTD	LTD	6.10	12	LTD	0.370	11	3	
Cottlesville																			
Cottlesville	Rushy Cove Pond	Aug 12, 2025	39.00	<u>34</u>	180.0	56.00	7.54	100		0.44	LTD	LTD	20.00	26	LTD	0.420	12	4	
Cottrell's Cove																			
Cottrell's Cove	Cottrell's Pond	Aug 11, 2025	46.00	13	140.0	48.00	7.91	79		0.32	LTD	LTD	15.00	14	LTD	0.270	9	2	
Cow Head																			
Cow Head	Short Cat Path Pond	Sep 11, 2025	41.00	12	130.0	39.00	7.17	74		6.30	LTD	LTD	12.00	19	LTD	0.580	9	2	
Cow Head - PWDU	Short Cat Path Pond	Sep 11, 2025	5.30	LTD	13.0	1.20	6.53	7		LTD	LTD	LTD	0.49	1	LTD	0.120	2	LTD	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	A	C	C	A	C	A	A						
Aesthetic (A) or Contaminant (C) Parameter																		
Cox's Cove																		
Cox's Cove	Cox's Brook	Sep 17, 2025	15.00	14	73.0	23.00	7.06	41		0.35	LTD	LTD	6.70	10	LTD	0.270	5	2
Crow Head																		
Crow Head	Oars Pond	Aug 13, 2025	16.00	<u>27</u>	270.0	30.00	7.12	150		0.53	LTD	LTD	5.50	67	LTD	1.200	39	6
Cupids																		
Cupids	Brigus Long Pond (to Brigus)	Aug 28, 2025	2.40	LTD	51.0	6.90	<u>6.38</u>	28		0.32	LTD	LTD	1.60	12	LTD	0.270	7	2
Daniel's Harbour																		
Daniel's Harbour	Unnamed Spring & Brook	Sep 11, 2025	170.00	7	600.0	200.00	8.26	330		0.13	LTD	LTD	46.00	70	LTD	1.200	43	9
Deep Bight																		
Deep Bight	Deep Bight River	Aug 20, 2025	18.00	LTD	83.0	16.00	7.26	46		0.13	LTD	LTD	5.10	11	LTD	0.270	9	3
Deer Lake																		
Deer Lake (+Reidville)	Humber Canal, Grand Lake	Sep 18, 2025	7.20	13	40.0	13.00	6.85	22		0.10	LTD	LTD	3.80	6	LTD	0.220	2	1
Dildo																		
Dildo, Broad Cove (+South Dildo)	Broad Cove Pond	Sep 25, 2025	LTD	LTD	53.0	6.30	<u>5.55</u>	29		0.34	LTD	LTD	1.30	12	LTD	0.190	4	2
Dover																		
Dover	Hare Bay Pond	Aug 19, 2025	LTD	<u>51</u>	27.0	3.90	<u>6.23</u>	15		0.26	LTD	LTD	0.76	5	LTD	0.200	4	LTD
Eddies Cove West																		
Eddies Cove West	Unnamed	Aug 13, 2025	160.00	<u>41</u>	350.0	170.00	8.30	190		1.70	LTD	LTD	42.00	10	LTD	0.480	6	2
Elliston																		
Elliston	Big Pond	Sep 17, 2025	2.50	LTD	160.0	9.90	<u>6.38</u>	87		0.33	LTD	LTD	2.10	41	LTD	0.480	23	5
Embree																		
Embree (+Little Burnt Bay)	Troke's Cove Pond	Aug 06, 2025	5.90	<u>21</u>	74.0	15.00	6.95	41		0.39	LTD	LTD	4.20	16	LTD	0.280	8	2
Englee																		
Englee	Island Cove Pond	Aug 11, 2025	LTD	<u>42</u>	40.0	8.70	<u>5.81</u>	22		1.20	LTD	LTD	2.40	9	LTD	0.200	3	1
Fairbanks-Hillgrade																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0		250	1.5			200	500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C		A	C			A	A
Aesthetic (A) or Contaminant (C) Parameter																		
Fairbanks-Hillgrade																		
Fairbanks-Hillgrade	Saltine's Pond	Aug 13, 2025	14.00	<u>16</u>	120.0	18.00	7.31	67		0.55	LTD	LTD	4.80	24	LTD	0.390	15	2
Fermeuse																		
Fermeuse, Kingman's	Merrymeeting Pond, Bear Cove Pond (2 intakes)	Aug 12, 2025	2.10	LTD	57.0	7.30	<u>6.26</u>	32		0.67	LTD	LTD	1.70	13	LTD	0.250	7	2
Ferryland																		
Ferryland	Deep Cove Pond	Aug 12, 2025	9.60	LTD	99.0	7.50	7.24	55		0.62	LTD	LTD	1.80	20	LTD	0.390	17	3
Fleur de Lys																		
Fleur De Lys	First Pond, Narrow Pond	Aug 06, 2025	5.20	<u>33</u>	91.0	12.00	6.80	51		0.46	LTD	LTD	2.80	20	LTD	0.580	12	2
Flower's Cove																		
Flower's Cove (+Nameless Cove)	French Island Pond	Aug 12, 2025	87.00	<u>20</u>	210.0	97.00	8.01	120		0.52	LTD	LTD	20.00	11	LTD	0.330	5	1
Fogo Island																		
Fogo	Freeman's Pond	Sep 17, 2025	LTD	<u>40</u>	170.0	9.80	<u>4.03</u>	93		1.10	LTD	LTD	1.60	36	LTD	0.500	16	3
Joe Batt's Arm-Barr'd Islands-Shoal Bay	Long Pond	Sep 17, 2025	4.40	9	100.0	7.60	6.77	58		0.69	LTD	LTD	1.20	25	LTD	0.420	15	3
Seldom-Little Seldom	Bullock Cove Pond	Sep 17, 2025	LTD	<u>23</u>	82.0	6.20	<u>5.09</u>	46		0.27	LTD	LTD	1.10	19	LTD	0.210	10	1
Tilting	Sandy Cove Pond	Sep 17, 2025	6.40	9	110.0	7.00	6.96	59		0.49	LTD	LTD	1.30	24	LTD	0.470	17	2
Seldom-Little Seldom - PWDU	Bullock Cove Pond	Sep 17, 2025	LTD	LTD	7.2	LTD	<u>6.06</u>	4		LTD	LTD	LTD	LTD	1	LTD	LTD	1	LTD
Fogo - PWDU	Freeman's Pond	Sep 17, 2025	LTD	LTD	60.0	LTD	<u>3.96</u>	33		LTD	LTD	LTD	LTD	7	LTD	LTD	1	LTD
Forresters Point																		
Forresters Point	Rudges Pond	Aug 12, 2025	100.00	<u>30</u>	300.0	110.00	8.18	170		0.84	LTD	LTD	24.00	30	LTD	0.450	18	3
Forteau																		
Forteau	Trout Brook	Aug 19, 2025	150.00	LTD	310.0	160.00	8.18	170		0.26	LTD	LTD	45.00	7	LTD	0.430	5	3
Fortune																		
Fortune (+Grand Bank)	Horsebrook	Aug 14, 2025	4.70	<u>23</u>	55.0	6.50	6.68	31		0.48	LTD	LTD	1.50	11	LTD	0.190	8	1
Fortune (+Grand Bank)	Horsebrook	Sep 09, 2025	6.20	<u>17</u>	61.0	8.20	6.78	34		0.50	LTD	LTD	2.10	12	LTD	0.230	8	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	C	A	C	A	C	A	C
Fox Cove-Mortier																		
Fox Cove-Mortier	Rock Pond	Sep 10, 2025	11.00	<u>16</u>	83.0	14.00	7.13	46		0.36	LTD	LTD	3.90	14	LTD	0.210	10	2
Francois																		
Francois	Our Pond	Aug 26, 2025	LTD	<u>63</u>	26.0	3.30	<u>5.93</u>	15		0.45	LTD	LTD	0.71	6	LTD	0.150	4	1
Gallants																		
Gallants	Gallant's Brook	Sep 18, 2025	170.00	LTD	340.0	170.00	8.21	190		LTD	LTD	LTD	45.00	6	LTD	0.360	4	3
Gambo																		
Gambo	Dark Cove Pond	Aug 19, 2025	8.20	5	93.0	9.70	7.06	51		0.32	LTD	LTD	3.10	20	LTD	0.230	13	2
Gambo	Dark Cove Pond	Sep 15, 2025	7.30	LTD	89.0	9.90	6.90	49		0.97	LTD	LTD	3.10	19	LTD	0.260	13	1
Gander																		
Gander	Gander Lake	Aug 27, 2025	25.00	12	74.0	6.00	7.45	41		0.13	LTD	LTD	1.40	6	LTD	0.160	14	LTD
Gander Bay South																		
George's Point, Harris Point	Barry's Brook	Aug 27, 2025	9.50	<u>23</u>	45.0	11.00	6.97	25		0.21	LTD	LTD	2.30	6	LTD	0.190	4	2
Garden Cove																		
Garden Cove	Arch Cove Pond	Aug 21, 2025	3.60	<u>28</u>	37.0	4.80	6.68	21		0.48	LTD	LTD	1.10	7	LTD	0.220	5	LTD
Garnish																		
Garnish	Witchazel Pond	Sep 11, 2025	LTD	<u>17</u>	60.0	11.00	<u>6.07</u>	33		0.67	LTD	LTD	2.90	15	LTD	0.300	6	2
Gaskiers																		
Gaskiers-Point La Haye	Big Hare Hill Pond	Aug 11, 2025	11.00	<u>39</u>	80.0	14.00	7.08	44		1.00	LTD	LTD	2.20	15	LTD	0.510	9	2
Gaultois																		
Gaultois	Piccaire Pond	Sep 09, 2025	LTD	<u>270</u>	38.0	4.70	<u>5.49</u>	21		0.92	LTD	LTD	0.85	7	LTD	0.300	5	LTD
Gaultois - PWDU	Piccaire Pond	Sep 09, 2025	130.00	15	390.0	9.00	8.12	220		1.30	LTD	LTD	1.70	18	LTD	94.000	15	1
George's Brook-Milton																		
George's Brook-Milton	George's Brook	Sep 17, 2025	8.00	6	62.0	10.00	7.12	35		0.22	LTD	LTD	3.10	11	LTD	0.200	7	3
Georgetown																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C			A	C		A	A
Aesthetic (A) or Contaminant (C) Parameter																		
Georgetown																		
Georgetown	Third Pond	Aug 25, 2025	4.20	LTD	77.0	7.40	6.81	43		0.32	LTD	LTD	1.60	18	LTD	0.410	11	3
Gillams																		
Gillams	Meaters Pond	Sep 17, 2025	23.00	7	81.0	17.00	7.19	45		0.29	LTD	LTD	4.90	12	LTD	0.310	8	2
Glenburnie-Birchy Head-Shoal Brook																		
Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Sep 04, 2025	39.00	<u>29</u>	110.0	41.00	7.72	62		LTD	LTD	LTD	9.10	7	LTD	0.660	6	5
Glenwood																		
Glenwood	Gander Lake (The Outflow)	Aug 27, 2025	LTD	<u>38</u>	26.0	6.10	<u>5.96</u>	14		0.32	LTD	LTD	1.40	5	LTD	0.160	2	LTD
Glovertown																		
Glovertown	Northwest Pond	Sep 16, 2025	3.20	<u>39</u>	41.0	5.40	6.53	23		0.49	LTD	LTD	1.50	9	LTD	0.210	5	LTD
Goobies																		
Goobies	Water Pond	Aug 21, 2025	5.40	10	31.0	5.50	6.86	17		0.76	LTD	LTD	1.60	5	LTD	0.190	4	LTD
Goose Cove East																		
Goose Cove East	Jack's Pond	Aug 11, 2025	29.00	<u>42</u>	110.0	27.00	7.69	59		0.48	LTD	LTD	8.60	13	LTD	0.190	11	2
Grand Bank																		
Grand Bank (Backup Supply)	Grand Bank Brook (Backup Supply)	Aug 14, 2025	12.00	<u>29</u>	84.0	19.00	7.02	47		2.00	LTD	LTD	5.80	15	LTD	0.240	7	1
Grand Falls-Windsor																		
Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Aug 04, 2025	5.40	LTD	86.0	32.00	7.17	48		0.18	LTD	LTD	12.00	4	LTD	0.110	2	25
Grand Le Pierre																		
Grand Le Pierre	Nip Nose Pond	Sep 11, 2025	4.00	<u>41</u>	23.0	5.10	6.56	13		0.37	LTD	LTD	1.50	3	LTD	0.130	2	LTD
Great Brehat																		
Great Brehat	Little Steady Pond	Aug 12, 2025	11.00	<u>79</u>	79.0	17.00	7.08	44		0.46	LTD	LTD	4.90	11	LTD	0.210	8	5
Green Island Brook																		
Green Island Brook	Green Island Brook	Aug 12, 2025	84.00	<u>24</u>	190.0	91.00	7.95	110		0.74	LTD	LTD	19.00	9	LTD	0.290	5	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Units			15	6.5 - 8.5			500	1.0			5.0	250	1.5	200		500
			Guidelines for Canadian Drinking Water Quality			Aesthetic (A) or Contaminant (C) Parameter	A	A	A	C	C	A	C	A	A	A			
Greenspond																			
Greenspond	Shambler's Cove Pond	Aug 19, 2025	LTD	<u>21</u>	120.0	7.00	<u>4.17</u>	69		0.22	LTD	LTD	1.40	27	LTD	0.370	13	3	
Hampden																			
Hampden	Elliot Brook	Sep 17, 2025	36.00	14	99.0	40.00	7.44	55		0.30	LTD	LTD	13.00	7	LTD	0.330	4	1	
Hant's Harbour																			
Hant's Harbour	Eastern Pond (Halfway Brook)	Sep 23, 2025	LTD	LTD	42.0	4.90	<u>5.93</u>	23		0.26	LTD	LTD	0.96	10	LTD	0.190	6	2	
Happy Adventure																			
Happy Adventure	Goose Neck Pond	Sep 16, 2025	LTD	<u>16</u>	45.0	7.10	<u>5.69</u>	25		0.65	LTD	LTD	1.80	11	LTD	0.270	5	1	
Happy Valley-Goose Bay																			
Happy Valley-Goose Bay	Spring Gulch	Aug 07, 2025	29.00	LTD	110.0	30.00	7.49	63		0.31	LTD	LTD	6.30	15	LTD	2.100	8	3	
Happy Valley-Goose Bay	Well Field (connect summer 2002)	Aug 07, 2025	34.00	9	120.0	31.00	7.65	64		0.28	LTD	LTD	6.60	15	LTD	2.100	8	3	
Harbour Breton																			
Harbour Breton	Connaigra Pond, Hutchings Pond	Aug 20, 2025	14.00	<u>21</u>	91.0	25.00	7.20	51		LTD	LTD	LTD	7.00	15	LTD	0.220	7	2	
Harbour Grace																			
Harbour Grace, Harbour Grace South (+Riverhead)	Bannerman Lake	Aug 28, 2025	3.20	LTD	38.0	6.80	<u>6.43</u>	21		0.58	LTD	LTD	1.80	9	LTD	0.170	4	1	
Harbour Main-Chapel's Cove-Lakeview																			
Harbour Main, Chapel's Cove, Lakeview	Maloney's River	Aug 25, 2025	15.00	LTD	110.0	19.00	7.60	60		0.11	LTD	LTD	6.20	21	LTD	0.370	13	2	
Hare Bay																			
Hare Bay (+Dover)	Hare Bay Pond	Aug 19, 2025	LTD	<u>53</u>	27.0	3.40	<u>6.13</u>	15		0.58	LTD	LTD	0.58	5	LTD	0.230	4	LTD	
Hawke's Bay																			
Hawke's Bay	Torrent River	Sep 03, 2025	14.00	<u>26</u>	63.0	20.00	6.89	35		0.95	LTD	LTD	5.10	9	LTD	0.290	3	2	
Heart's Content																			
Heart's Content	Southern Cove Pond	Sep 23, 2025	3.20	10	49.0	4.10	6.58	27		0.22	LTD	LTD	0.88	11	LTD	0.170	7	1	
Heart's Delight-Islington																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	A						
Heart's Delight-Islington																		
Heart's Delight-Islington	Long Pond	Sep 25, 2025	24.00	LTD	110.0	5.50	7.14	59		LTD	LTD	LTD	1.10	22	LTD	0.270	17	3
Heart's Desire																		
Heart's Desire	Terrence Pond	Sep 25, 2025	LTD	LTD	64.0	8.20	<u>6.09</u>	36		LTD	LTD	LTD	2.00	16	LTD	0.260	8	2
Hermitage																		
Hermitage-Sandyville	Granfer's Pond	Aug 26, 2025	LTD	<u>20</u>	95.0	5.10	<u>4.23</u>	53		0.59	LTD	LTD	1.00	20	LTD	0.210	9	1
Hermitage-Sandyville - PWDU	Granfer's Pond	Aug 26, 2025	LTD	LTD	32.0	LTD	<u>4.24</u>	18		LTD	LTD	LTD	LTD	4	LTD	LTD	1	LTD
Herring Neck																		
Herring Neck, Hatchet Harbour, Salt Harbour, Shoal Cove, Sunnyside	Gut Pond	Aug 13, 2025	28.00	9	270.0	39.00	7.56	150		0.48	LTD	LTD	10.00	62	LTD	0.690	36	7
Hickman's Harbour-Robinson Bight																		
Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Sep 17, 2025	9.10	5	64.0	10.00	7.27	36		0.48	LTD	LTD	2.80	11	LTD	0.160	8	2
Hopedale																		
Hopedale	American Pond	Jul 23, 2025	3.60	<u>25</u>	36.0	8.00	<u>6.43</u>	20		1.00	LTD	LTD	2.40	7	LTD	0.230	3	1
Howley																		
Howley	Sandy Lake	Aug 20, 2025	6.20	<u>47</u>	46.0	7.40	6.90	26		0.15	LTD	LTD	1.80	8	LTD	0.220	6	LTD
Howley - PWDU	Sandy Lake	Aug 20, 2025	LTD	LTD	22.0	LTD	<u>6.47</u>	12		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Hughes Brook																		
Hughes Brook	Reservoir	Sep 22, 2025	170.00	6	350.0	170.00	8.26	190		0.19	LTD	LTD	38.00	9	LTD	0.290	6	4
Humber Arm South																		
Halfway Point, Benoit's Cove, John's Beach	Dormody's Brook	Sep 05, 2025	55.00	LTD	130.0	61.00	7.93	74		0.10	LTD	LTD	1.30	8	LTD	0.160	4	LTD
Frenchman's Cove Area	Gurges Pond	Sep 05, 2025	20.00	6	87.0	23.00	7.57	48		0.49	LTD	LTD	5.60	11	LTD	0.380	8	4
Indian Bay																		
Indian Bay	Indian Bay Brook	Aug 19, 2025	5.40	10	45.0	6.90	6.88	25		0.34	LTD	LTD	1.60	8	LTD	0.200	6	LTD
Irishtown-Summerside																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				Units	15		6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
				Guidelines for Canadian Drinking Water Quality														
				Aesthetic (A) or Contaminant (C) Parameter	A		A	A		C	C			A	C		A	A
Irishtown-Summerside																		
Irishtown	Irishtown Brook	Sep 18, 2025	40.00	9	120.0	50.00	7.46	68		0.17	LTD	LTD	14.00	9	LTD	0.250	5	3
Summerside	Pynn's Pond	Sep 18, 2025	8.60	<u>32</u>	43.0	11.00	6.99	24		0.51	LTD	LTD	2.90	7	LTD	0.200	4	1
Isle aux Morts																		
Isle aux Morts	Burnt Ground Pond	Sep 09, 2025	LTD	<u>46</u>	150.0	9.20	<u>3.71</u>	81		1.50	LTD	LTD	2.90	23	LTD	0.180	3	1
Isle aux Morts - PWDU	Burnt Ground Pond	Sep 09, 2025	LTD	LTD	9.5	LTD	<u>5.81</u>	5		LTD	LTD	LTD	0.17	2	LTD	LTD	1	LTD
Jackson's Arm																		
Jackson's Arm	Unnamed Brook	Sep 16, 2025	3.80	9	35.0	8.90	<u>6.26</u>	20		0.25	LTD	LTD	2.50	7	LTD	0.320	2	LTD
Jackson's Arm - PWDU	Unnamed Brook	Sep 16, 2025	2.20	LTD	100.0	LTD	<u>6.10</u>	57		LTD	LTD	LTD	0.11	LTD	LTD	0.120	1	LTD
Jackson's Cove-Langdon's Cove-Silverdale																		
Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Sep 04, 2025	13.00	9	110.0	17.00	7.36	59		0.89	LTD	LTD	5.30	19	LTD	0.280	12	3
Keels																		
Keels	Boland's Pond	Sep 17, 2025	3.60	<u>53</u>	120.0	6.10	<u>6.32</u>	67		1.30	LTD	LTD	0.58	30	LTD	0.550	19	2
King's Point																		
King's Point	Bulley's Pond	Sep 04, 2025	4.80	<u>24</u>	26.0	7.00	6.74	15		0.66	LTD	LTD	2.00	4	LTD	0.160	2	LTD
L'Anse au Clair																		
L'Anse au Clair	Park Pond	Aug 19, 2025	110.00	LTD	240.0	110.00	8.10	130		0.37	LTD	LTD	33.00	7	LTD	0.340	5	2
L'Anse au Loup																		
L'Anse au Loup	L'anse Au Loup River	Aug 19, 2025	13.00	<u>22</u>	47.0	14.00	7.27	26		0.43	LTD	LTD	3.80	6	LTD	0.210	4	LTD
LaScie																		
La Scie	Stakes Pond	Aug 06, 2025	3.20	<u>33</u>	67.0	9.20	<u>6.32</u>	37		0.52	LTD	LTD	2.40	16	LTD	0.270	9	2
Labrador City																		
Labrador City	Beverly Lake	Jul 31, 2025	45.00	6	110.0	50.00	7.68	63		2.40	LTD	LTD	12.00	4	LTD	1.400	1	3
Lamaline																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	C	A	C	A	A					
Lamaline																		
Lamaline	Upper Hodges Pond	Sep 09, 2025	14.00	11	89.0	14.00	7.30	49		0.37	LTD	LTD	4.00	15	LTD	0.270	11	1
Lamaline - PWDU	Upper Hodges Pond	Sep 09, 2025	3.00	LTD	7.2	LTD	6.54	4		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Lark Harbour																		
Lark Harbour	Fairfax Brook	Sep 05, 2025	25.00	8	140.0	28.00	7.64	79		5.20	LTD	LTD	5.30	25	LTD	0.380	16	4
Lawn																		
Lawn	Brazil Pond	Sep 09, 2025	5.90	35	42.0	8.60	6.67	24		2.70	LTD	LTD	2.20	8	LTD	0.180	5	2
Lawn - PWDU	Brazil Pond	Sep 09, 2025	3.10	LTD	19.0	1.50	6.46	10		LTD	LTD	LTD	0.35	4	LTD	LTD	3	LTD
Leading Tickles																		
Leading Tickles	Cook's Pond	Aug 11, 2025	8.70	42	81.0	12.00	6.66	45		0.49	LTD	LTD	3.30	16	LTD	0.260	11	2
Leading Tickles - PWDU	Cook's Pond	Aug 11, 2025	LTD	LTD	5.9	LTD	6.38	3		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Lewin's Cove																		
Lewin's Cove	Big Pond	Sep 09, 2025	2.90	13	52.0	11.00	6.43	29		1.60	LTD	LTD	3.10	11	LTD	0.250	5	2
Lewisporte																		
Lewisporte	Stanhope Pond	Sep 16, 2025	7.90	12	61.0	14.00	6.67	34		0.52	LTD	LTD	4.10	10	LTD	0.190	5	2
Little Bay																		
Little Bay	Mine Pond	Sep 04, 2025	65.00	LTD	330.0	54.00	8.24	190		LTD	LTD	LTD	18.00	50	LTD	0.150	41	22
Little Bay	First Pond	Sep 04, 2025	34.00	6	99.0	34.00	7.45	55		LTD	LTD	LTD	12.00	6	LTD	LTD	6	3
Little Burnt Bay																		
Little Burnt Bay	Troke's Cove Pond	Aug 06, 2025	6.00	16	83.0	15.00	6.79	46		0.36	LTD	LTD	4.40	18	LTD	0.280	9	2
Little Harbour East																		
Little Harbour East (Placentia Bay)	Unnamed Pond	Sep 22, 2025	10.00	35	61.0	15.00	7.11	34		0.27	LTD	LTD	4.50	9	LTD	0.250	6	2
Little St. Lawrence																		
Little St. Lawrence	Butler's Brook (2 Intakes)	Sep 09, 2025	11.00	29	61.0	13.00	7.04	34		0.89	LTD	LTD	2.90	9	0.260	0.320	7	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate		
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0		250	1.5		200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	A	C	C	A	C	A	A					
Long Harbour-Mount Arlington Heights																				
Long Harbour-Mount Arlington Heights	Shingle Pond and/or Trout Pond (2 Intakes)	Sep 23, 2025	11.00	LTD	95.0	6.90	7.23	53		LTD	LTD	LTD	1.70	19	LTD	0.210	15	3		
Loon Bay																				
Loon Bay	Southeast Pond	Aug 12, 2025	15.00	LTD	66.0	16.00	7.37	37		0.19	LTD	LTD	5.00	9	LTD	0.260	6	LTD		
Lourdes																				
Lourdes (+West Bay)	Victor's Brook	Sep 19, 2025	130.00	LTD	460.0	160.00	7.64	250		LTD	LTD	LTD	48.00	49	LTD	0.810	20	15		
Lower Lance Cove																				
Lower Lance Cove	Big Long Pond	Sep 17, 2025	4.80	13	39.0	6.20	6.84	22		0.42	LTD	LTD	1.70	7	LTD	0.130	4	1		
Lumsden																				
Lumsden	Gull Pond	Aug 27, 2025	27.00	LTD	220.0	4.20	7.36	120		1.00	LTD	LTD	0.56	14	LTD	0.290	44	51		
Lushes Bight-Beaumont-Beaumont North																				
Lushes Bight, Beaumont	Milkboy's Pond/Gull Pond	Aug 26, 2025	7.00	<u>45</u>	52.0	12.00	7.03	29		0.33	LTD	LTD	3.40	9	LTD	0.180	6	1		
Lushes Bight, Beaumont - PWDU	Milkboy's Pond/Gull Pond	Aug 26, 2025	LTD	LTD	40.0	LTD	<u>6.31</u>	22		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD		
Main Brook																				
Main Brook	Joe Burt's Pond	Aug 11, 2025	36.00	12	100.0	42.00	7.64	57		1.40	LTD	LTD	12.00	8	LTD	0.230	3	1		
Mainland																				
Mainland	Caribou Brook	Sep 19, 2025	160.00	LTD	400.0	180.00	8.29	230		0.33	LTD	LTD	52.00	24	LTD	0.570	16	9		
Makkovik																				
Makkovik	Ranger Bight Pond	Jul 23, 2025	4.50	<u>45</u>	34.0	8.30	6.63	19		1.90	LTD	LTD	2.60	6	LTD	0.180	3	1		
Makkovik - PWDU	Ranger Bight Pond	Jul 23, 2025	4.20	LTD	30.0	6.10	6.65	17		LTD	LTD	LTD	2.00	6	LTD	0.180	3	LTD		
Mary's Harbour																				
Mary's Harbour	St. Mary's River	Aug 19, 2025	LTD	<u>68</u>	18.0	2.30	<u>6.30</u>	10		0.48	LTD	LTD	0.52	3	LTD	LTD	3	LTD		
Mary's Harbour - PWDU	St. Mary's River	Aug 19, 2025	LTD	LTD	4.0	LTD	<u>6.30</u>	2		LTD	LTD	LTD	LTD	LTD	LTD	LTD	0	LTD		
Marystown																				

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	C	A	C	A	C	A	C	A	C	
Marystown																		
Marystown	Fox Hill Reservoir / Clam Pond	Sep 11, 2025	9.30	6	110.0	9.30	7.05	60		0.35	LTD	LTD	2.80	24	LTD	0.210	15	3
Massey Drive																		
Massey Drive	Trout Pond, Third Pond (2 intakes)	Sep 17, 2025	22.00	LTD	95.0	19.00	7.46	53		LTD	LTD	LTD	5.90	12	LTD	0.350	11	3
Mclvers																		
Mclvers	Mclvers Brook	Sep 17, 2025	46.00	11	140.0	45.00	7.69	78		0.17	LTD	LTD	14.00	10	LTD	0.410	10	4
Meadows																		
Meadows, Summerside West	Meaters Pond	Sep 17, 2025	10.00	10	67.0	17.00	7.06	37		0.52	LTD	LTD	5.10	10	LTD	0.280	5	2
Merritt's Harbour																		
Merritt's Harbour	Jimmy's Pond	Aug 13, 2025	14.00	<u>29</u>	180.0	24.00	7.10	100		0.38	LTD	LTD	5.20	43	LTD	0.530	25	5
Middle Arm																		
Middle Arm	Dam Pond Brook	Sep 29, 2025	10.00	<u>23</u>	39.0	11.00	7.19	22		0.14	LTD	LTD	3.60	5	LTD	0.120	3	LTD
Miles Cove																		
Miles Cove	Paddock's Pond	Aug 26, 2025	6.50	10	54.0	14.00	6.82	30		0.13	LTD	LTD	4.40	10	LTD	LTD	4	2
Millertown																		
Millertown	Water Pond	Aug 25, 2025	9.60	8	48.0	11.00	6.94	27		0.26	LTD	LTD	3.60	7	LTD	LTD	6	LTD
Milltown-Head of Bay D'Espoir																		
Milltown, Head of Bay D'Espoir	Jersey Pond	Aug 20, 2025	9.50	<u>25</u>	69.0	21.00	6.91	38		0.39	LTD	LTD	5.50	11	LTD	0.200	5	3
Ming's Bight																		
Ming's Bight	Middle Brook Pond	Aug 06, 2025	15.00	<u>26</u>	61.0	19.00	7.48	34		0.45	LTD	LTD	5.80	7	LTD	0.120	4	LTD
Morrisville																		
Morrisville	Morrisville Pond	Aug 20, 2025	16.00	LTD	76.0	19.00	7.34	42		0.26	LTD	LTD	5.60	9	LTD	0.210	6	3
Mount Moriah																		
Mount Moriah	Trout Pond, Third Pond (2 intakes)	Sep 17, 2025	23.00	LTD	97.0	20.00	7.48	54		0.15	LTD	LTD	6.10	12	LTD	0.360	11	3
Mount Pearl																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500	Aesthetic (A) or Contaminant (C) Parameter					
				A	A	C	C	A	C	A	A							
Mount Pearl																		
Mount Pearl	Bay Bulls Big Pond	Sep 16, 2025	23.00	LTD	97.0	23.00	7.54	54		LTD	LTD	LTD	8.50	15	LTD	0.230	7	1
Musgrave Harbour																		
Musgrave Harbour	Rocky Pond	Aug 27, 2025	13.00	LTD	110.0	8.20	7.46	60		0.85	LTD	LTD	1.50	23	LTD	0.300	18	2
Nain																		
Nain	Trouser Lake	Sep 08, 2025	5.30	LTD	27.0	7.20	7.01	15		0.16	LTD	LTD	2.10	3	LTD	0.170	2	2
Nameless Cove																		
Nameless Cove / Flower Cove	French Island Pond	Aug 12, 2025	89.00	<u>19</u>	210.0	93.00	8.05	120		0.50	LTD	LTD	19.00	11	LTD	0.340	5	2
Natuashish																		
Natuashish (Sango Bay)	Sango Brook and Wellfield	Aug 28, 2025	50.00	LTD	700.0	64.00	7.77	390		LTD	0.13	LTD	10.00	160	1.400	5.800	100	27
New Chelsea-New Melbourne-Brownsdale-Sibley's Cove-I																		
Sibley's Cove, Lead Cove	Sibley's Cove Pond	Sep 23, 2025	3.00	LTD	52.0	5.10	6.53	29		0.20	LTD	LTD	0.95	12	LTD	0.190	8	2
New Perlican																		
New Perlican	New Perlican River	Sep 23, 2025	6.20	6	61.0	7.20	6.81	34		0.12	LTD	LTD	1.80	12	LTD	0.220	9	2
New-Wes-Valley																		
Wesleyville-Badger's Quay-Pool's Island, Brookfield-Poundcove-Newtown-Templeman	Little Northwest Pond	Aug 19, 2025	8.20	<u>23</u>	99.0	4.70	7.11	55		0.48	LTD	LTD	0.86	21	LTD	0.260	17	1
Nippers Harbour																		
Nippers Harbour	Blackhead Pond Brook	Aug 06, 2025	8.70	<u>18</u>	34.0	9.90	7.03	19		0.41	LTD	LTD	3.10	5	LTD	0.110	3	LTD
Norman's Cove-Long Cove																		
Norman's Cove-Long Cove	John Newhooks Pond	Aug 20, 2025	4.40	9	53.0	6.20	6.93	30		0.17	LTD	LTD	1.60	11	LTD	0.160	8	1
Norris Arm																		
Norris Arm (south)	Mill Lake	Aug 06, 2025	5.30	<u>22</u>	39.0	9.90	6.59	22		0.17	LTD	LTD	2.60	8	LTD	0.290	3	1
Norris Point																		
Norris Point	Neddy Harbour Pond	Aug 20, 2025	120.00	7	270.0	130.00	8.05	150		0.25	LTD	LTD	27.00	11	LTD	0.390	6	2

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500							
Guidelines for Canadian Drinking Water Quality				A	A	C	C	A	C	A	C	A	C	A	C	A	C	A	C
Aesthetic (A) or Contaminant (C) Parameter																			
North Harbour																			
North Harbour	Grandfather's Pond	Aug 21, 2025	LTD	<u>52</u>	50.0	2.70	<u>6.25</u>	28		0.74	LTD	LTD	0.41	11	LTD	0.160	8	1	
North West River																			
North West River	Wellfield (Well # 1 & Well # 2)	Aug 06, 2025	47.00	LTD	160.0	65.00	7.96	89		0.13	LTD	LTD	21.00	1	0.130	2.500	3	26	
Northern Arm																			
Northern Arm	Northern Arm Lake	Aug 05, 2025	6.30	LTD	87.0	32.00	7.09	49		1.10	LTD	LTD	12.00	5	LTD	0.120	2	25	
Old Perican																			
Old Perican	Bell Pond	Sep 23, 2025	LTD	LTD	70.0	4.90	<u>5.30</u>	39		0.24	LTD	LTD	0.80	17	LTD	0.300	10	2	
Pacquet																			
Pacquet	Big Brook	Aug 06, 2025	2.10	<u>140</u>	28.0	3.10	<u>6.17</u>	16		0.48	LTD	LTD	0.56	5	LTD	0.160	4	LTD	
Pacquet - PWDU	Big Brook	Aug 06, 2025	2.00	LTD	6.0	LTD	<u>6.42</u>	3		0.14	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD	
Paradise																			
Paradise	Bay Bulls Big Pond	Sep 16, 2025	21.00	LTD	97.0	24.00	7.55	54		LTD	LTD	LTD	8.90	15	LTD	0.220	7	1	
Parkers Cove																			
Parkers Cove	Unnamed brook	Sep 10, 2025	3.70	<u>39</u>	58.0	3.70	6.60	32		0.43	LTD	LTD	0.80	12	LTD	0.140	10	LTD	
Parson's Pond																			
Parson's Pond	Cold Brook	Sep 11, 2025	240.00	LTD	730.0	280.00	7.87	410		LTD	LTD	LTD	89.00	72	LTD	1.700	45	10	
Pasadena																			
Pasadena	Blue Gulch Pond	Aug 20, 2025	14.00	7	56.0	20.00	7.26	31		0.19	LTD	LTD	6.50	6	LTD	0.240	3	2	
Peterview																			
Peterview	Northern Arm Lake	Aug 05, 2025	5.70	LTD	86.0	31.00	7.05	48		0.21	LTD	LTD	12.00	5	LTD	0.120	1	25	
Petit Forte																			
Petit Forte	Reddy's Pond	Sep 10, 2025	2.40	<u>42</u>	50.0	6.20	<u>6.32</u>	28		0.58	LTD	LTD	1.10	11	LTD	0.370	6	2	
Petty Harbour-Maddox Cove																			
Petty Harbour-Maddox Cove	Western Barrens Pond	Sep 26, 2025	7.30	LTD	57.0	5.00	7.29	31		0.35	LTD	LTD	1.30	10	LTD	0.210	10	1	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0		250	1.5		200		500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C		A	C		A		A
Aesthetic (A) or Contaminant (C) Parameter																		
Phillips Head																		
Phillips Head	Dogberry Brook	Aug 11, 2025	49.00	LTD	130.0	46.00	7.83	73		0.26	LTD	LTD	15.00	10	LTD	0.250	7	2
Pidgeon Cove-St. Barbe																		
Pigeon Cove - St. Barbe	Long Pond	Aug 12, 2025	82.00	<u>30</u>	210.0	87.00	8.00	120		0.64	LTD	LTD	16.00	14	LTD	0.240	9	1
Pilley's Island																		
Pilley's Island	Loadabats Pond	Aug 26, 2025	58.00	LTD	230.0	69.00	7.74	130		0.26	LTD	LTD	22.00	35	LTD	0.580	21	3
Placentia																		
Placentia, Jersey side, SE Placentia	Larkins Pond	Aug 21, 2025	12.00	9	110.0	21.00	7.22	63		0.15	LTD	LTD	6.80	24	LTD	0.330	12	3
Freshwater, Argentinia site, Dunville	Clarkes Pond	Aug 21, 2025	8.30	<u>28</u>	100.0	21.00	6.91	56		0.74	LTD	LTD	6.20	22	LTD	0.300	10	4
Pleasantview																		
Pleasantview	Little Arm Pond	Aug 11, 2025	12.00	<u>18</u>	77.0	11.00	7.25	43		1.20	LTD	LTD	2.90	14	LTD	0.250	10	1
Plum Point																		
Plum Point	Grand Pond	Aug 13, 2025	80.00	<u>26</u>	250.0	84.00	8.03	140		0.56	LTD	LTD	18.00	29	LTD	0.410	17	2
Point Lance																		
Point Lance	Unnamed Pond	Sep 23, 2025	13.00	<u>84</u>	96.0	20.00	7.03	54		0.42	LTD	LTD	3.70	14	LTD	0.330	10	7
Point Leamington																		
Point Leamington	Little Pond	Aug 11, 2025	4.10	8	49.0	13.00	6.50	27		0.42	LTD	LTD	3.80	11	LTD	0.180	4	1
Point May																		
Point May	Short's Pond	Sep 09, 2025	8.00	<u>42</u>	96.0	9.40	6.88	54		0.50	LTD	LTD	2.50	20	LTD	0.170	14	2
Point May - PWDU	Short's Pond	Sep 09, 2025	5.60	LTD	82.0	4.10	6.97	45		0.18	LTD	LTD	1.00	19	LTD	0.110	12	LTD
Point of Bay																		
Point of Bay	Indian Cove Pond	Aug 11, 2025	8.40	10	68.0	12.00	7.20	38		0.55	LTD	LTD	3.60	13	LTD	0.150	8	1
Pollards Point																		
Pollards Point, Country Cove	Country Cove Pond	Sep 16, 2025	22.00	11	110.0	25.00	7.43	62		0.28	LTD	LTD	8.60	18	LTD	0.380	12	1

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	5.0	1.0	5.0	5.0	250	1.5	200	500		
Aesthetic (A) or Contaminant (C) Parameter				A	A	A	C	C	A	C	A	C	A	C	A	A		
Pollards Point																		
Pollards Point East	George Ricks Pond	Sep 16, 2025	7.80	<u>16</u>	29.0	8.00	7.01	16		0.21	LTD	LTD	2.50	4	LTD	0.340	2	LTD
Pool's Cove																		
Pool's Cove	Widgeon Pond	Aug 26, 2025	17.00	12	99.0	16.00	7.28	55		0.61	LTD	LTD	4.20	16	LTD	0.250	14	LTD
Port Albert																		
Port Albert	Beaverton Pond	Sep 16, 2025	15.00	<u>18</u>	120.0	18.00	7.21	65		0.51	LTD	LTD	5.50	21	LTD	0.240	16	2
Port Anson																		
Port Anson	Anchor Pond	Aug 26, 2025	13.00	<u>20</u>	97.0	16.00	7.13	54		0.22	LTD	LTD	4.80	18	LTD	0.160	13	1
Port Blandford																		
Port Blandford	Noseworthy's Pond	Sep 16, 2025	9.20	6	140.0	9.30	7.21	80		0.30	LTD	LTD	2.90	34	LTD	0.210	22	2
Port Hope Simpson																		
Port Hope Simpson	Arnold's Brook and Pond	Aug 19, 2025	6.20	<u>51</u>	67.0	3.60	6.71	37		1.00	LTD	LTD	0.88	14	LTD	0.220	11	LTD
Port Saunders																		
Port Saunders	Tom Taylor's Pond	Sep 03, 2025	97.00	11	250.0	110.00	7.81	140		0.53	LTD	LTD	25.00	18	LTD	0.550	8	2
Port Saunders - PWDU	Tom Taylor's Pond	Sep 03, 2025	62.00	LTD	180.0	72.00	7.71	100		LTD	LTD	LTD	17.00	17	LTD	0.460	7	LTD
Port au Choix																		
Port au Choix	Winterhouse Pond	Sep 03, 2025	110.00	LTD	310.0	120.00	7.91	170		0.38	LTD	LTD	33.00	26	LTD	0.540	12	3
Port au Choix - PWDU	Winterhouse Pond	Sep 03, 2025	3.60	LTD	11.0	LTD	6.53	6		LTD	LTD	LTD	0.34	2	LTD	LTD	2	LTD
Port au Port West-Aguathuna-Felix Cove																		
Port au Port West	Jim Rowe's Brook	Sep 22, 2025	190.00	LTD	540.0	200.00	8.02	300		0.10	LTD	LTD	54.00	42	0.220	1.800	25	11
Portland Creek																		
Portland Creek	Unnamed Streams	Sep 11, 2025	160.00	11	370.0	160.00	8.09	210		0.82	LTD	LTD	54.00	16	LTD	0.690	12	2
Portugal Cove South																		
Portugal Cove South	Wrights Brook	Aug 11, 2025	9.30	9	57.0	8.70	7.01	31		0.31	LTD	LTD	1.90	9	LTD	0.170	7	3
Portugal Cove-St. Phillips																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500						
Guidelines for Canadian Drinking Water Quality				A	A	C	C	A	C	A	C	A	C	A	C	A	C	A
Aesthetic (A) or Contaminant (C) Parameter																		
Portugal Cove-St. Phillips																		
Portugal Cove-St. Phillips	Bay Bulls Big Pond	Sep 16, 2025	22.00	LTD	99.0	24.00	7.58	55		0.15	LTD	LTD	9.00	15	LTD	0.230	7	1
Postville																		
Postville	Big Pond	Jul 23, 2025	5.50	<u>32</u>	56.0	5.80	6.85	31		0.47	LTD	LTD	1.60	10	LTD	0.300	9	1
Postville - PWDU	Big Pond	Jul 23, 2025	LTD	6	11.0	LTD	<u>6.29</u>	6		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Pouch Cove																		
Pouch Cove	North Three Island Pond	Aug 25, 2025	6.70	LTD	63.0	8.00	7.18	35		0.12	LTD	LTD	2.10	15	LTD	0.270	9	LTD
Purcell's Harbour																		
Purcell's Harbour	Purcell's Harbour Pond	Aug 13, 2025	8.50	<u>89</u>	150.0	13.00	6.76	83		1.30	LTD	LTD	2.70	36	LTD	0.370	23	3
Pynn's Brook																		
Pynn's Brook	Pynn's Brook	Sep 18, 2025	69.00	14	170.0	74.00	7.85	97		LTD	LTD	LTD	25.00	6	LTD	0.440	5	10
Ramea																		
Ramea	Northwest Pond	Aug 24, 2025	12.00	LTD	320.0	45.00	7.64	180		0.54	LTD	LTD	12.00	61	LTD	1.300	42	40
Ramea - PWDU	Northwest Pond	Aug 24, 2025	10.00	LTD	250.0	34.00	7.36	140		0.24	LTD	LTD	9.30	47	LTD	1.000	30	30
Random Sound West																		
Queen's Cove	Reservoir	Sep 18, 2025	13.00	<u>27</u>	61.0	17.00	7.06	34		0.36	LTD	LTD	5.50	5	LTD	0.270	4	6
Rattling Brook																		
Rattling Brook	Mark's Pond Brook	Sep 04, 2025	5.90	7	35.0	4.80	6.97	20		0.12	LTD	LTD	1.50	6	LTD	0.150	5	LTD
Red Bay																		
Red Bay	Northern Brook	Aug 19, 2025	4.40	<u>34</u>	49.0	3.50	6.67	27		0.42	LTD	LTD	0.73	10	LTD	0.150	8	LTD
Reidville																		
Reidville	Humber Canal, Grand Lake	Aug 20, 2025	6.60	14	50.0	13.00	6.81	28		0.20	LTD	LTD	3.80	9	LTD	0.230	4	1
Rigolet																		
Rigolet	Rigolet Pond	Jul 23, 2025	4.50	<u>110</u>	61.0	6.00	6.55	34		1.10	LTD	LTD	1.70	12	LTD	LTD	10	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C			A	C		A	A
Aesthetic (A) or Contaminant (C) Parameter																		
Rigolet																		
Rigolet - PWDU	Rigolet Pond	Jul 23, 2025	LTD	LTD	5.3	LTD	<u>6.14</u>	3		LTD	LTD	LTD	0.16	LTD	LTD	LTD	1	LTD
River of Ponds																		
River of Ponds	Burnt Head Ponds	Sep 03, 2025	66.00	6	190.0	70.00	7.92	100		4.50	LTD	LTD	18.00	15	LTD	0.340	10	1
Robert's Arm																		
Robert's Arm	Young's Pond / Dam Pond	Aug 26, 2025	25.00	LTD	84.0	31.00	7.37	46		0.28	LTD	LTD	9.80	9	LTD	LTD	4	1
Rocky Harbour																		
Rocky Harbour	Gull Pond	Aug 20, 2025	65.00	<u>18</u>	180.0	77.00	7.82	99		0.20	LTD	LTD	21.00	13	LTD	0.420	6	2
Roddickton-Bide Arm																		
Bide Arm	First Clay Cove Pond	Aug 11, 2025	100.00	10	220.0	100.00	8.09	120		0.17	LTD	LTD	30.00	7	LTD	0.210	4	LTD
Roddickton	East Brook Pond	Aug 11, 2025	69.00	7	160.0	74.00	7.90	90		0.66	LTD	LTD	22.00	7	LTD	0.240	3	1
Rose Blanche-Harbour Le Cou																		
Rose Blanche-Harbour Le Cou	Rose Blanche Brook	Sep 09, 2025	3.70	<u>110</u>	41.0	3.30	<u>6.43</u>	23		1.10	LTD	LTD	0.80	8	LTD	0.180	6	LTD
Rushoon																		
Rushoon	Big Pond Brook	Sep 10, 2025	4.50	13	45.0	6.10	6.85	25		0.24	LTD	LTD	1.60	10	LTD	0.150	6	2
Salmon Cove																		
Salmon Cove	Rocky Pond	Sep 09, 2025	3.20	LTD	40.0	5.50	<u>6.41</u>	22		0.39	LTD	LTD	1.50	9	LTD	0.160	5	1
Seal Cove (FB)																		
Seal Cove, F.B.	Big Black Duck Pond	Aug 26, 2025	3.30	<u>130</u>	35.0	5.10	<u>6.27</u>	19		0.92	LTD	LTD	1.20	7	LTD	0.230	5	1
Seal Cove, F.B. - PWDU	Big Black Duck Pond	Aug 26, 2025	LTD	LTD	5.9	LTD	<u>6.06</u>	3		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Seal Cove (WB)																		
Seal Cove, W.B.	Seal Cove Brook & Long Pond	Sep 29, 2025	14.00	<u>22</u>	75.0	14.00	7.22	41		0.41	LTD	LTD	4.50	12	LTD	0.470	9	1
Seal Cove, W.B. - PWDU	Seal Cove Brook & Long Pond	Sep 29, 2025	5.00	LTD	9.7	2.40	6.86	5		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Sheshatshiu																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500							
Aesthetic (A) or Contaminant (C) Parameter				A	A	C	C	A	C	A	C	A	A						
Sheshatshiu																			
Sheshatshui - Indian Band Council	Wells 1, 2 & 3	Aug 06, 2025	92.00	LTD	420.0	80.00	7.95	240		0.63	0.06	LTD	19.00	58	0.280	3.900	44	20	
Shoe Cove																			
Shoe Cove	Second Pond	Aug 06, 2025	4.70	<u>81</u>	66.0	8.70	6.62	36		0.46	LTD	LTD	2.30	14	LTD	0.210	10	LTD	
Small Point-Adam's Cove-Blackhead-Broad Cove																			
Adam's Cove	#1 Well - Reg Burseley Well	Sep 02, 2025	85.00	LTD	260.0	75.00	7.95	150		LTD	LTD	LTD	20.00	20	LTD	0.430	23	20	
Broad Cove	#6 Well - Herb Trickett Well	Sep 02, 2025	98.00	LTD	300.0	88.00	7.96	170		0.26	LTD	LTD	26.00	25	LTD	1.000	22	14	
Small Point	#8 Well - Effie Flight Wells	Jul 09, 2025	85.00	9	260.0	110.00	7.95	140		0.28	LTD	LTD	25.00	22	LTD	0.460	11	8	
Small Point	#8 Well - Effie Flight Wells	Sep 02, 2025	85.00	LTD	300.0	100.00	7.86	170		LTD	LTD	LTD	24.00	35	LTD	0.520	16	10	
Small Point	#9 Well - Walter Reynolds Well	Sep 02, 2025	21.00	LTD	140.0	30.00	6.96	80		0.11	LTD	LTD	8.00	25	LTD	0.780	14	5	
Small Point	#9 Well - Walter Reynolds Well	Sep 09, 2025	21.00	LTD	150.0	31.00	7.01	82		LTD	LTD	LTD	8.40	25	LTD	0.830	14	6	
Broad Cove	#10 Well - Cantwood Hill Well	Jul 09, 2025	95.00	LTD	290.0	110.00	8.02	160		0.44	LTD	LTD	31.00	25	LTD	1.800	14	17	
Smith's Harbour																			
Smith's Harbour	Fleshetts Brook	Sep 29, 2025	7.90	<u>27</u>	32.0	8.80	6.58	18		0.23	LTD	LTD	2.40	4	LTD	0.110	3	LTD	
Sop's Arm																			
Sop's Arm	Little Tickle Pond	Sep 16, 2025	11.00	<u>32</u>	39.0	14.00	7.11	22		0.25	LTD	LTD	3.80	4	LTD	0.300	2	LTD	
South Brook																			
South Brook	Next to Brook	Aug 25, 2025	44.00	LTD	180.0	56.00	7.53	98		LTD	LTD	LTD	17.00	26	LTD	0.830	12	5	
South Dildo																			
South Dildo	Broad Cove Pond	Sep 25, 2025	LTD	LTD	51.0	5.80	<u>5.59</u>	28		0.39	LTD	LTD	1.20	11	LTD	0.190	5	1	
South River																			
South River	Brigus Long Pond (to Brigus)	Aug 28, 2025	3.10	6	50.0	7.90	<u>6.42</u>	28		0.25	LTD	LTD	2.00	11	LTD	0.280	6	2	
Southern Harbour																			
Southern Harbour	Brigades Pond	Aug 19, 2025	6.00	5	52.0	14.00	6.69	29		0.42	LTD	LTD	4.20	10	LTD	0.290	5	2	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				Units															
				mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
				15	6.5 - 8.5	500	1.0	5.0	250	1.5	200	500							
				Aesthetic (A) or Contaminant (C) Parameter	A	A	C	C	A	C	A	C	A	C	A	C	A	C	
Spaniard's Bay																			
Spaniard's Bay (+Upper Island Cove, + Bryant's Cove)	Kelly's Pond (Spider's Pond)	Aug 28, 2025	LTD	LTD	33.0	4.10	<u>5.77</u>	18		0.19	LTD	LTD	0.93	8	LTD	0.150	4	1	
Springdale																			
Springdale	Sullivan's Pond (2 Intakes)	Sep 04, 2025	12.00	9	52.0	20.00	7.04	29		0.14	LTD	LTD	6.30	6	LTD	LTD	2	1	
St. Anthony																			
St. Anthony	St. Anthony Pond	Aug 12, 2025	15.00	<u>39</u>	66.0	24.00	7.14	37		0.34	LTD	LTD	2.20	10	LTD	0.330	3	1	
St. Anthony Bight																			
St. Anthony Bight	Cabbox Pond	Aug 12, 2025	6.50	<u>160</u>	63.0	10.00	6.53	35		2.20	LTD	LTD	2.50	12	LTD	0.290	8	2	
St. Bernard's-Jacques Fontaine																			
St. Bernard's-Jacques Fontaine	Rattle Brook	Sep 11, 2025	7.70	<u>26</u>	49.0	11.00	6.98	27		0.37	LTD	LTD	3.40	6	LTD	0.200	5	3	
St. Bride's																			
St. Bride's	North Side Brook	Sep 23, 2025	20.00	14	110.0	19.00	6.90	60		0.62	LTD	LTD	3.70	19	LTD	0.200	13	LTD	
St. Bride's	South Side Brook	Sep 23, 2025	29.00	<u>110</u>	97.0	27.00	LTD	54		1.70	LTD	LTD	6.90	13	LTD	0.200	9	LTD	
St. John's																			
St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Sep 17, 2025	21.00	LTD	98.0	24.00	7.63	55		LTD	LTD	LTD	8.70	15	LTD	0.240	7	1	
St. John's	Windsor Lake	Sep 16, 2025	34.00	LTD	150.0	38.00	7.71	82		0.26	LTD	LTD	14.00	21	LTD	0.320	12	2	
St. John's	Petty Harbour Long Pond	Sep 16, 2025	45.00	LTD	130.0	49.00	7.73	73		LTD	LTD	LTD	19.00	11	LTD	0.270	5	1	
St. Jude's																			
St. Jude's	Uncle Arthur Brook	Sep 18, 2025	45.00	<u>19</u>	140.0	50.00	7.62	79		0.55	LTD	LTD	15.00	5	LTD	0.310	8	13	
St. Jude's	Chute Brook	Sep 18, 2025	39.00	11	99.0	39.00	7.56	55		0.23	LTD	LTD	12.00	5	LTD	0.290	5	2	
St. Lawrence																			
St. Lawrence	St. Lawrence River	Sep 09, 2025	LTD	<u>24</u>	40.0	6.70	<u>5.86</u>	22		0.88	LTD	LTD	1.80	9	0.160	0.230	4	1	
St. Lawrence - PWDU	St. Lawrence River	Sep 09, 2025	LTD	7	45.0	7.10	<u>5.63</u>	25		0.25	LTD	LTD	2.00	10	0.140	0.220	4	2	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate	
			mg/L	TCU	µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			Units			15	6.5 - 8.5			500	1.0			5.0	250	1.5	200		500
			Guidelines for Canadian Drinking Water Quality			Aesthetic (A) or Contaminant (C) Parameter	A	A	A	C	C	A	C	A	A	A			
St. Lewis																			
St. Lewis	Tub Harbour Pond	Aug 19, 2025	4.30	<u>62</u>	60.0	12.00	6.58	33		0.84	LTD	LTD	3.40	13	LTD	0.380	6	1	
St. Lunaire-Griquet																			
St. Lunaire-Griquet	Joe's Pond	Aug 12, 2025	3.40	<u>49</u>	77.0	16.00	<u>6.13</u>	43		0.54	LTD	LTD	4.50	18	LTD	0.330	7	2	
Gunnors Cove	Lookout Brook	Aug 12, 2025	36.00	<u>150</u>	140.0	39.00	7.54	75		2.90	LTD	LTD	12.00	16	LTD	0.350	12	2	
St. Lunaire-Griquet - PWDU	Joe's Pond	Aug 12, 2025	3.80	LTD	5.4	LTD	<u>6.36</u>	3		0.22	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD	
St. Mary's																			
St. Mary's	Wellfield	Jul 22, 2025	96.00	LTD	300.0	51.00	8.34	170		0.12	LTD	LTD	13.00	21	0.290	1.000	44	21	
St. Pauls																			
St. Pauls	Two Mile Pond	Sep 11, 2025	66.00	<u>18</u>	250.0	86.00	7.51	140		1.00	LTD	LTD	28.00	30	LTD	0.970	16	4	
St. Shott's																			
St. Shott's	Unnamed Pond	Aug 11, 2025	5.40	11	93.0	8.50	6.73	52		1.00	LTD	LTD	1.30	21	LTD	0.230	13	3	
Steady Brook																			
Steady Brook	Wellfield + Steady Brook	Aug 20, 2025	17.00	<u>27</u>	160.0	44.00	7.32	87		0.27	LTD	LTD	16.00	21	LTD	0.560	13	18	
Stephenville																			
Stephenville	Well Field	Sep 19, 2025	160.00	LTD	390.0	160.00	7.97	220		0.51	LTD	LTD	46.00	18	LTD	0.930	18	8	
Stoneville																			
Stoneville	Dog Bay Pond Brook	Sep 16, 2025	9.30	12	55.0	11.00	7.15	31		0.51	LTD	LTD	3.10	8	LTD	0.210	6	1	
Straitsview																			
Straitsview	Saddle Hill Pond	Aug 12, 2025	16.00	<u>53</u>	130.0	26.00	7.32	75		0.60	LTD	LTD	7.00	25	LTD	0.500	16	5	
Summerford																			
Summerford (+Cottlesville)	Rushy Cove Pond	Aug 12, 2025	38.00	<u>31</u>	180.0	53.00	7.60	99		0.42	LTD	LTD	18.00	25	LTD	0.440	12	4	
Sunnyside (T.B.)																			
Sunnyside	Center Cove River	Sep 22, 2025	5.20	<u>20</u>	58.0	7.40	6.92	32		0.45	LTD	LTD	2.10	10	LTD	0.190	9	2	
Terrenceville																			

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Units				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Guidelines for Canadian Drinking Water Quality				A			A	A		C	C			A	C		A	A
Aesthetic (A) or Contaminant (C) Parameter																		
Terrenceville																		
Terrenceville	Big Brook	Sep 11, 2025	10.00	<u>16</u>	67.0	7.60	7.03	37		0.54	LTD	LTD	2.20	12	LTD	0.240	9	1
Thornlea																		
Thornlea	Big Bakeapple Pond	Aug 20, 2025	3.00	11	54.0	5.30	6.52	30		0.18	LTD	LTD	1.00	12	LTD	0.190	8	2
Tizzard's Harbour																		
Tizzard's Harbour	Rocky Pond	Aug 13, 2025	3.90	<u>80</u>	100.0	9.60	<u>6.39</u>	58		0.64	LTD	LTD	1.50	25	LTD	0.260	15	3
Torbay																		
Torbay	North Pond	Aug 25, 2025	12.00	9	95.0	9.50	7.17	53		1.30	LTD	LTD	2.60	18	LTD	0.390	15	3
Trepassey																		
Trepassey	Miller's Pond	Aug 11, 2025	LTD	10	62.0	9.50	<u>5.80</u>	34		0.27	LTD	LTD	2.00	15	LTD	0.200	6	2
Trinity																		
Trinity, T.B.	Indian Pond	Sep 17, 2025	LTD	<u>28</u>	40.0	2.60	<u>6.24</u>	22		0.31	LTD	LTD	0.36	9	LTD	0.140	6	LTD
Trinity Bay North																		
Melrose	Whirl Pond	Sep 17, 2025	11.00	<u>28</u>	90.0	8.40	7.07	50		0.44	LTD	LTD	2.10	17	LTD	0.240	13	2
Port Union, Catalina (+Little Catalina)	Whirl Pond	Sep 17, 2025	9.40	<u>28</u>	91.0	6.10	7.09	50		0.47	LTD	LTD	1.20	17	LTD	0.240	15	2
Triton																		
Triton, Jim's Cove, Card's Harbour	Triton Pond	Aug 26, 2025	26.00	<u>49</u>	140.0	29.00	7.31	75		0.55	LTD	LTD	8.50	24	LTD	0.420	15	3
Trout River																		
Trout River	Feeder Brook	Sep 04, 2025	54.00	LTD	150.0	56.00	7.79	82		0.26	LTD	LTD	5.10	11	LTD	0.220	8	2
Twillingate																		
Twillingate	Wild Cove Pond	Aug 13, 2025	3.90	<u>16</u>	130.0	19.00	<u>6.26</u>	74		0.24	LTD	LTD	4.40	33	LTD	0.500	16	5
Upper Island Cove																		
Upper Island Cove	Kelly's Pond (Spider's Pond)	Aug 28, 2025	LTD	LTD	34.0	4.30	<u>6.05</u>	19		0.20	LTD	LTD	1.00	8	LTD	0.150	4	1
Victoria																		
Victoria (+Salmon Cove)	Rocky Pond	Aug 25, 2025	2.20	8	39.0	4.30	<u>6.37</u>	22		0.51	LTD	LTD	0.99	10	LTD	0.160	5	1

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality				15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Aesthetic (A) or Contaminant (C) Parameter				A			A	A		C	C			A	C		A	A
Victoria																		
Victoria (+Salmon Cove)	Rocky Pond	Sep 09, 2025	LTD	LTD	37.0	4.40	<u>6.14</u>	21		0.46	LTD	LTD	1.00	9	LTD	0.160	5	1
Victoria (+Salmon Cove)	Rocky Pond	Sep 09, 2025	LTD	LTD	38.0	4.40	<u>6.19</u>	21		0.39	LTD	LTD	1.00	9	LTD	0.160	5	1
Wabush																		
Wabush	Wahnahnish Lake	Jul 31, 2025	33.00	8	87.0	39.00	7.55	48		0.72	LTD	LTD	9.20	3	LTD	0.970	1	3
West Bay																		
West Bay	Victor's Brook	Sep 23, 2025	140.00	10	410.0	160.00	7.94	230		0.18	LTD	LTD	48.00	37	LTD	0.760	18	15
West St. Modeste																		
West St. Modeste	Well Field	Jul 09, 2025	75.00	<u>81</u>	220.0	40.00	7.61	130		1.40	0.07	LTD	10.00	19	0.290	2.100	30	5
West St. Modeste	Well Field	Aug 19, 2025	76.00	<u>48</u>	230.0	45.00	7.83	130		0.42	0.07	LTD	11.00	21	0.230	2.400	33	5
Whitbourne																		
Whitbourne	Hodges River	Aug 06, 2025	4.80	12	91.0	12.00	6.74	51		0.27	LTD	LTD	2.90	20	LTD	0.280	11	1
Whiteway																		
Whiteway (+Cavendish)	Long Pond	Sep 25, 2025	6.90	LTD	70.0	7.70	7.01	39		0.46	LTD	LTD	1.50	14	LTD	0.290	10	2
Whiteway - PWDU	Long Pond	Sep 25, 2025	3.90	LTD	42.0	2.90	6.56	24		LTD	LTD	LTD	0.54	10	LTD	0.190	6	LTD
Wild Cove																		
Wild Cove	Hedderson's Pond Brook	Sep 29, 2025	14.00	<u>59</u>	53.0	17.00	7.11	29		0.32	LTD	LTD	5.20	6	LTD	0.670	4	LTD
Winterton																		
Winterton	Western Pond	Sep 23, 2025	3.50	7	40.0	5.80	<u>6.40</u>	22		0.13	LTD	LTD	1.40	9	LTD	0.210	5	1
Wooddale																		
Wooddale	Northern Arm Lake	Aug 04, 2025	5.70	LTD	85.0	31.00	7.02	47		LTD	LTD	LTD	12.00	4	LTD	0.110	2	25
Woodstock																		
Woodstock	Mill Pond	Aug 06, 2025	LTD	<u>120</u>	27.0	4.60	<u>5.94</u>	15		0.84	LTD	LTD	1.00	5	LTD	0.190	3	LTD
Woody Point																		

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador

Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
			Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality			15				6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
Aesthetic (A) or Contaminant (C) Parameter			A				A	A		C	C			A	C		A	A
Woody Point																		
Woody Point	Winterhouse Brook	Sep 04, 2025	51.00	LTD	140.0	57.00	7.97	78		LTD	LTD	LTD	3.60	11	LTD	0.260	7	2

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

Quality Assurance / Quality Control (QA/QC) - The department is striving to improve the quality of the data using standard QA/QC protocols. This is an evolving process which may result in minor changes to the reported data.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

The exceedance report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ.

Aesthetic (A) Parameters - Aesthetic parameters reflect substances or characteristics of drinking water that can affect its acceptance by consumers but which usually do not pose any health effects. Aesthetic exceedances are highlighted in **blue text** and underlined.

Contaminants (C) - Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant and Aesthetic Exceedances

Turbidity - The maximum acceptable concentration for turbidity is 1 NTU. Turbidity refers to the water's ability to transmit light or the cloudiness of the water. Turbidity in tap water can be the result of turbid raw water and influences within the distribution system. Turbidity is usually the result of fine organic and inorganic particles which do not settle out. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process.

Boron - The interim maximum acceptable concentration for boron in drinking water is 5.0 mg/L. Boron is widespread in the environment, occurring naturally in over 80 minerals and in the earth's crust. Levels in well water have been reported to be more variable and often higher than those in surface waters, most likely due to erosion from natural resources. High levels of this contaminant can cause adverse health effects for some people

Fluoride - The maximum acceptable concentration for fluoride in drinking water is 1.5mg/L. The fluoride concentration in natural water varies widely as it depends on such factors as the source of the water and the geological formations present. Trace amounts of fluoride may be essential for human nutrition and the presence of small quantities leads to a reduction of dental caries. High levels of this contaminant can cause adverse health effects for some people.

Colour - An aesthetic objective of 15 true colour units (TCU) has been established for colour in drinking water. Colour in drinking water may be due to the presence of coloured organic substances or metals such as iron, manganese and copper. Highly coloured industrial wastes also contribute to colour. The presence of colour is not directly linked to health but it can be aesthetically displeasing.

pH -The acceptable range for drinking water pH is 6.5 - 8.5. The control of pH is primarily based on minimizing corrosion and encrustation in the distribution system. Tap water with low pH may accelerate the corrosion process in the distribution system, and contribute to increased levels of copper, lead and possibly other metals. Incrustation and scaling problems may become more frequent above pH 8.5

TDS - The aesthetic objective for TDS in drinking water is 500 mg/L. The term "total dissolved solids"(TDS) refers mainly to the inorganic substances that are dissolved in water. At low levels TDS contributes to the palatability of water. At high levels it may cause excessive hardness, taste, mineral deposition and corrosion.

Chloride - The aesthetic objective for chloride in drinking water is 250 mg/L. Chloride can be in water from a variety of sources, including the dissolution of salt deposits and salting of roads for ice control. No evidence has been found suggesting that ingestion of chloride is harmful to humans. However, high levels of chloride in water can impart undesirable tastes to water and beverages prepared from water.

Sodium - The aesthetic objective for sodium in drinking water is 200 mg/L. Since the body has very effective means to control levels of sodium, sodium is not an acutely toxic element in the normal range of environmental or dietary concentrations. At extremely high dosages it has adverse health effects. Sodium levels may be of interest to authorities who wish to prescribe sodium restricted diets for their patients..

Sulphate - The aesthetic objective for sulphate in drinking water is 500 mg/L. Sulphates, which occur naturally in numerous minerals, are used in the mining and pulping industries and in wood preservation. Large quantities of sulphate can result in catharsis and gastrointestinal irritation. The presence of sulphate above the aesthetic limit can result in noticeable taste. Some sensitive individuals may find the taste objectionable at lower sulphate concentrations

mg/L = milligrams per litre or parts per million µS/cm = micro Siemens per centimeter NTU = nephelometric turbidity units TDS = total dissolved solids TSS = total suspended solids TCU = true colour units Nitrate(ite) = Nitrate + Nitrite DOC = dissolved organic carbon

Notes:
Guidelines for Canadian Drinking Water Quality have not been developed for all the parameters listed in this report.
pH has no units