Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Anchor Point																		
Anchor Point	Well Cove Brook	Feb 04, 2026	140.00	32	310.0	160.00	7.78	170		0.35	LTD	LTD	31.00	20	LTD	0.510	10	3
Appleton																		
Appleton (+Glenwood)	Gander Lake (The Outflow)	Feb 25, 2026	LTD	31	30.0	6.10	5.29	17		0.16	LTD	LTD	1.40	6	LTD	0.170	2	LTD
Aquaforte																		
Aquaforte	Davies Pond	Jan 29, 2026	LTD	34	77.0	5.40	5.94	43		0.72	LTD	LTD	0.83	18	LTD	0.320	12	2
Arnold's Cove																		
Arnold's Cove	Steve's Pond (2 Intakes)	Jan 22, 2026	22.00	17	80.0	5.70	7.33	44		0.48	LTD	LTD	1.50	10	LTD	0.180	14	1
Avondale																		
Avondale	Lees Pond	Jan 26, 2026	7.10	LTD	84.0	10.00	7.01	46		0.58	LTD	LTD	3.00	17	LTD	0.240	12	2
Baie Verte																		
Baie Verte	Southern Arm Pond	Feb 10, 2026	LTD	18	31.0	6.50	5.44	17		0.20	LTD	LTD	1.70	7	LTD	0.270	2	LTD
Baine Harbour																		
Baine Harbour	Baine Harbour Pond	Mar 10, 2026	4.90	69	65.0	12.00	6.53	36		0.18	LTD	LTD	3.20	14	LTD	0.270	7	3
Bartletts Harbour																		
Bartletts Harbour	Long Pond (same as Castors River North)	Feb 05, 2026	110.00	21	270.0	120.00	7.86	150		0.15	LTD	LTD	26.00	21	LTD	0.570	12	3
Bay L'Argent																		
Bay L'Argent	Sugarloaf Hill Pond	Mar 10, 2026	4.40	17	150.0	9.00	6.54	81		2.70	LTD	LTD	1.70	37	0.110	0.360	25	2
Bay L'Argent	Sugarloaf Hill Pond	Mar 19, 2026	6.80	11	120.0	5.90	7.11	66		1.20	LTD	LTD	1.20	30	LTD	0.250	20	2
Bay Roberts																		
Bay Roberts	Rocky Pond	Jan 30, 2026	LTD	LTD	76.0	9.00	5.71	42		0.23	LTD	LTD	2.30	18	LTD	0.230	10	3
Bay de Verde																		
Bay de Verde	Island Pond	Feb 11, 2026	LTD	17	73.0	5.60	4.99	41		0.51	LTD	LTD	0.47	17	LTD	0.460	9	3
Beaches																		
Beaches	Grassey Pond Brook	Mar 04, 2026	8.00	50	43.0	15.00	7.23	24		0.20	LTD	LTD	4.80	4	LTD	0.870	3	2

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Beachside																		
Beachside	Long Pond	Feb 18, 2026	15.00	26	94.0	19.00	7.21	53		0.12	LTD	LTD	6.30	16	LTD	LTD	12	2
Bellburns																		
Bellburns	Bound Brook Tributary	Feb 11, 2026	180.00	LTD	390.0	190.00	8.02	220		LTD	LTD	LTD	49.00	21	LTD	0.560	13	6
Belleoram																		
Belleoram	Rabbits Pond	Feb 04, 2026	4.20	46	73.0	6.90	6.42	41		0.33	LTD	LTD	0.89	15	LTD	0.350	12	2
Bellevue																		
Bellevue	Big Pond	Feb 12, 2026	5.40	25	98.0	13.00	6.53	55		0.37	LTD	LTD	3.30	22	LTD	0.330	14	3
Bellevue Beach																		
Bellevue Beach	Unnamed Brook	Feb 12, 2026	LTD	29	59.0	8.00	5.82	33		0.28	LTD	LTD	1.70	14	LTD	0.170	7	3
Benton																		
Benton	Little Pond	Mar 02, 2026	6.90	150	240.0	16.00	6.27	130		2.30	LTD	LTD	5.00	62	LTD	0.510	40	5
Birchy Bay																		
Birchy Bay	Jumper's Pond	Jan 26, 2026	13.00	35	99.0	15.00	6.99	55		0.48	LTD	LTD	4.80	18	LTD	0.130	14	LTD
Bird Cove																		
Bird Cove (+Brig Bay)	Inner Gilmour Pond	Feb 04, 2026	100.00	49	230.0	110.00	7.77	130		0.14	LTD	LTD	23.00	15	LTD	0.350	8	3
Bishop's Falls																		
Bishop's Falls	Northern Arm Lake	Jan 20, 2026	6.30	LTD	88.0	35.00	6.97	49		0.10	LTD	LTD	13.00	4	LTD	LTD	2	24
Black Duck Cove																		
Black Duck Cove	Long Pond - Black Duck Cove Intake	Feb 04, 2026	150.00	43	320.0	160.00	7.77	180		0.18	LTD	LTD	31.00	20	LTD	0.570	12	3
Bonavista																		
Bonavista	Long Pond	Jan 20, 2026	14.00	16	110.0	7.80	6.98	63		0.29	LTD	LTD	1.40	22	LTD	0.210	20	3
Botwood																		
Botwood	Northern Arm Lake	Jan 20, 2026	5.60	LTD	89.0	35.00	7.00	49		LTD	LTD	LTD	13.00	4	LTD	0.100	2	24
Branch																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Branch																		
Branch	Drilled Wells	Mar 10, 2026	110.00	LTD	280.0	88.00	8.04	160		0.13	LTD	LTD	30.00	18	LTD	2.600	23	8
Brent's Cove																		
Brent's Cove	Paddy's Pond	Feb 11, 2026	5.00	130	73.0	12.00	6.06	40		1.50	LTD	LTD	2.80	16	LTD	0.380	9	2
Brig Bay																		
Brig Bay	Inner Gilmour Pond	Feb 04, 2026	100.00	45	230.0	110.00	7.75	130		0.28	LTD	LTD	23.00	15	LTD	0.370	8	3
Brighton																		
Brighton	Hynes Cove Pond	Feb 26, 2026	21.00	19	110.0	24.00	7.03	59		0.12	LTD	LTD	7.20	18	LTD	0.140	10	2
Brigus																		
Brigus (+Cupids, +South River)	Brigus Long Pond (to Brigus)	Feb 05, 2026	LTD	16	52.0	6.30	5.92	29		0.60	LTD	LTD	1.30	12	LTD	0.260	7	1
Buchans																		
Buchans	Buchans Lake aka Sandy Lake	Feb 25, 2026	LTD	33	28.0	7.20	5.77	16		0.22	LTD	LTD	2.20	5	LTD	0.100	2	LTD
Buchans Junction																		
Buchans Junction	Lapland Pond	Feb 25, 2026	12.00	25	59.0	14.00	6.76	33		0.53	LTD	LTD	4.50	8	LTD	0.150	7	LTD
Burgeo																		
Burgeo	Long Pond	Feb 19, 2026	LTD	29	99.0	7.00	4.05	55		0.25	LTD	LTD	1.10	15	LTD	0.300	7	2
Burgeo	Long Pond	Mar 26, 2026	7.00	55	54.0	2.30	7.06	30		0.36	LTD	LTD	0.35	10	LTD	0.220	10	1
Burgeo	Long Pond	Mar 26, 2026	7.00	57	54.0	2.50	7.26	30		0.34	LTD	LTD	0.38	10	LTD	0.220	10	1
Burgeo	Long Pond	Mar 26, 2026	LTD	44	44.0	2.80	5.20	25		0.61	LTD	LTD	0.42	10	LTD	0.240	6	1
Burgoyne's Cove																		
Burgoyne's Cove	Lower Rocky Pond	Jan 19, 2026	5.90	LTD	40.0	8.50	6.77	22		0.25	LTD	LTD	2.30	7	LTD	0.210	5	2
Burin																		
Burin (+Lewin's Cove)	Big Pond	Mar 10, 2026	LTD	16	62.0	11.00	6.05	35		0.34	LTD	LTD	2.90	14	LTD	0.280	7	2
Burin	Long Pond	Mar 10, 2026	6.40	18	56.0	9.20	6.20	31		0.11	LTD	LTD	2.30	12	LTD	0.210	6	2

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Burin																		
Port au Bras	Gripe Cove Pond	Mar 10, 2026	3.20	11	110.0	22.00	6.80	60		0.24	LTD	LTD	6.40	20	LTD	0.390	11	8
Burlington																		
Burlington	Eastern Island Pond	Feb 10, 2026	6.70	51	68.0	8.60	6.51	38		0.31	LTD	LTD	2.30	14	LTD	0.130	11	LTD
Burnt Islands																		
Burnt Islands	Long Lake	Feb 04, 2026	LTD	56	57.0	4.30	5.80	32		0.24	LTD	LTD	0.70	14	LTD	0.280	10	2
Burnt Islands - PWDU	Long Lake	Feb 04, 2026	LTD	LTD	2.8	LTD	5.96	2		LTD	LTD	LTD	LTD	LTD	LTD	LTD	0	LTD
Campbellton																		
Campbellton	Indian Arm Brook	Jan 20, 2026	6.70	53	41.0	8.20	6.63	23		0.27	LTD	LTD	2.20	7	LTD	0.140	5	1
Cape Freels North																		
Cape Freels North	Long Pond	Mar 02, 2026	3.40	170	110.0	11.00	5.81	59		1.10	LTD	LTD	1.20	26	LTD	0.730	16	3
Cape St. George																		
Cape St. George, Red Brook, De-Grau, Marches Point	Rouzes Brook	Mar 10, 2026	190.00	LTD	430.0	200.00	8.26	240		0.18	LTD	LTD	49.00	29	LTD	0.660	16	5
Caplin Cove-Southport																		
Southport	Button's Pond	Mar 04, 2026	4.10	14	76.0	9.60	6.43	42		0.41	LTD	LTD	1.80	16	LTD	0.210	11	2
Carbonear																		
Carbonear	Little Island Pond	Feb 05, 2026	LTD	6	40.0	6.30	6.02	22		0.28	LTD	LTD	1.30	9	LTD	0.160	4	2
Carmanville																		
Carmanville	Grandfathers Pond	Feb 25, 2026	4.50	10	62.0	7.70	6.50	34		0.23	LTD	LTD	1.20	12	LTD	0.190	9	2
Castor River North																		
Castor River North	Long Pond (same as Bartletts Harbour)	Feb 05, 2026	120.00	24	270.0	120.00	7.91	150		LTD	LTD	LTD	27.00	21	LTD	0.560	12	3
Castor River South																		
Castor River South	Unnamed	Feb 05, 2026	200.00	LTD	400.0	210.00	7.95	220		LTD	LTD	LTD	53.00	13	LTD	0.810	7	4
Cavendish																		

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Cavendish																		
Cavendish	Long Pond	Jan 29, 2026	8.10	9	86.0	13.00	6.67	48		0.46	LTD	LTD	2.60	18	LTD	0.400	12	2
Centreville-Wareham-Trinity																		
Centreville-Wareham	Northwest Pond	Mar 03, 2026	8.40	33	53.0	6.60	6.71	30		0.24	LTD	LTD	1.70	9	LTD	0.140	9	1
Trinity	Southwest Feeder Pond	Mar 03, 2026	4.30	27	58.0	4.90	6.42	32		0.24	LTD	LTD	1.20	13	LTD	0.150	10	LTD
Chanceport																		
Chanceport	Bridger's Cove Pond	Feb 17, 2026	26.00	61	270.0	50.00	7.02	150		0.62	LTD	LTD	14.00	66	LTD	0.610	34	7
Channel-Port aux Basques																		
Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Feb 04, 2026	4.30	LTD	95.0	26.00	6.89	53		0.18	LTD	LTD	8.50	16	LTD	0.280	8	15
Charlottetown (Labrador)																		
Charlottetown (Labrador)	Middle Pond	Mar 02, 2026	LTD	44	54.0	7.60	4.35	30		0.40	LTD	LTD	1.80	9	LTD	0.230	3	LTD
Charlottetown (Labrador)	Middle Pond	Mar 20, 2026	LTD	42	57.0	7.20	4.27	32		0.35	LTD	LTD	1.70	9	LTD	0.220	3	LTD
Charlottetown (Labrador)	Middle Pond	Mar 20, 2026	LTD	46	53.0	7.30	4.55	29		0.33	LTD	LTD	1.70	9	LTD	0.230	3	LTD
Charlottetown (Labrador)	Middle Pond	Mar 20, 2026	LTD	44	51.0	7.90	4.44	28		0.40	LTD	LTD	1.80	9	LTD	0.250	3	LTD
Charlottetown (Labrador) - PWDU	Middle Pond	Mar 02, 2026	LTD	LTD	28.0	LTD	4.31	15		LTD	LTD	LTD	LTD	3	LTD	LTD	0	LTD
Clarenville																		
Clarenville, Shoal Harbour	Shoal Harbour River	Mar 05, 2026	15.00	LTD	140.0	25.00	7.20	75		0.38	LTD	LTD	9.20	16	LTD	0.170	16	22
Clarke's Beach																		
Clarkes Beach	Clarkes Pond	Jan 30, 2026	LTD	LTD	39.0	6.60	6.02	22		0.29	LTD	LTD	1.50	8	LTD	0.200	4	2
Come By Chance																		
Come By Chance	Butchers Brook	Jan 22, 2026	17.00	LTD	69.0	15.00	7.58	38		LTD	LTD	LTD	5.30	12	LTD	LTD	6	LTD
Comfort Cove-Newstead																		
Comfort Cove-Newstead	Steady Cove Pond	Jan 26, 2026	7.10	29	110.0	24.00	6.33	61		0.37	LTD	LTD	5.70	25	LTD	1.000	11	4
Conception Bay South																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Conception Bay South																		
Conception Bay South	Bay Bulls Big Pond	Mar 05, 2026	22.00	LTD	100.0	27.00	7.43	57		0.12	LTD	LTD	9.70	16	LTD	0.230	8	2
Conche																		
Conche	Martin's Brook	Feb 03, 2026	7.20	89	84.0	14.00	6.63	46		0.60	LTD	LTD	4.10	18	LTD	0.170	11	2
Conne River																		
Conne River	Southwest Brook	Feb 16, 2026	6.20	LTD	26.0	2.20	7.15	15		LTD	LTD	LTD	0.51	5	LTD	0.110	5	LTD
Cook's Harbour																		
Cook's Harbour	Unnamed Pond	Feb 04, 2026	140.00	12	480.0	160.00	7.80	270		0.25	LTD	LTD	53.00	67	LTD	1.200	33	7
Corner Brook																		
Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Feb 20, 2026	30.00	LTD	99.0	23.00	7.59	55		LTD	LTD	LTD	7.00	10	LTD	0.350	11	3
Cottlesville																		
Cottlesville	Rushy Cove Pond	Jan 26, 2026	41.00	34	180.0	57.00	7.30	97		0.20	LTD	LTD	20.00	25	LTD	0.450	13	4
Cottrell's Cove																		
Cottrell's Cove	Cottrell's Pond	Feb 10, 2026	51.00	17	160.0	56.00	7.47	87		0.60	LTD	LTD	18.00	17	LTD	0.370	10	2
Cow Head																		
Cow Head	Short Cat Path Pond	Feb 11, 2026	25.00	17	120.0	35.00	6.95	69		1.50	LTD	LTD	11.00	22	LTD	0.480	11	2
Cow Head - PWDU	Short Cat Path Pond	Feb 11, 2026	LTD	LTD	7.1	LTD	5.94	4		LTD	LTD	LTD	0.11	LTD	LTD	LTD	1	LTD
Cox's Cove																		
Cox's Cove	Cox's Brook	Mar 10, 2026	13.00	27	64.0	19.00	7.13	36		0.13	LTD	LTD	5.40	9	LTD	0.220	5	2
Crow Head																		
Crow Head	Oars Pond	Feb 17, 2026	10.00	30	380.0	47.00	6.40	210		0.25	LTD	LTD	7.50	100	LTD	1.600	54	1
Cupids																		
Cupids	Brigus Long Pond (to Brigus)	Feb 05, 2026	LTD	11	57.0	6.30	5.82	32		0.52	LTD	LTD	1.20	13	LTD	0.270	8	1
Daniel's Harbour																		
Daniel's Harbour	Unnamed Spring & Brook	Feb 11, 2026	130.00	LTD	410.0	140.00	7.96	230		LTD	LTD	LTD	34.00	50	LTD	0.930	29	8

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Deadman's Bay																		
Deadman's Bay	Deadman's Pond	Mar 02, 2026	LTD	72	30.0	4.70	5.64	17		0.39	LTD	LTD	0.83	6	LTD	0.190	4	LTD
Deep Bight																		
Deep Bight	Deep Bight River	Mar 05, 2026	8.80	26	65.0	11.00	6.93	36		0.16	LTD	LTD	3.70	11	LTD	0.120	8	2
Deer Lake																		
Deer Lake (+Reidville)	Humber Canal, Grand Lake	Mar 06, 2026	8.30	14	40.0	13.00	6.91	22		0.12	LTD	LTD	3.80	5	LTD	0.240	2	2
Dildo																		
Dildo, Broad Cove (+South Dildo)	Broad Cove Pond	Feb 09, 2026	LTD	18	55.0	6.70	4.73	31		0.59	LTD	LTD	1.20	11	LTD	0.190	5	2
Dover																		
Dover	Hare Bay Pond	Mar 03, 2026	LTD	38	48.0	4.70	4.53	27		0.42	LTD	LTD	0.99	9	LTD	0.200	4	LTD
Dover	Hare Bay Pond	Mar 18, 2026	5.30	57	48.0	4.10	6.49	27		0.35	LTD	LTD	0.81	9	LTD	0.190	8	LTD
Eddies Cove West																		
Eddies Cove West	Unnamed	Feb 05, 2026	150.00	29	300.0	150.00	8.01	170		0.40	LTD	LTD	37.00	13	LTD	0.350	7	2
Elliston																		
Elliston	Big Pond	Jan 20, 2026	2.70	LTD	180.0	12.00	6.00	99		0.14	LTD	LTD	2.70	47	LTD	0.350	27	5
Embree																		
Embree (+Little Burnt Bay)	Troke's Cove Pond	Jan 20, 2026	7.10	19	76.0	15.00	6.61	42		0.31	LTD	LTD	4.20	15	LTD	0.270	8	2
Englee																		
Englee	Island Cove Pond	Feb 03, 2026	5.30	75	47.0	13.00	6.32	26		0.50	LTD	LTD	3.80	9	LTD	0.180	4	1
Fairbanks-Hillgrade																		
Fairbanks-Hillgrade	Saltine's Pond	Feb 17, 2026	14.00	24	110.0	20.00	7.06	59		0.23	LTD	LTD	5.10	LTD	LTD	0.380	14	LTD
Fermeuse																		
Fermeuse, Kingman's	Merrymeeting Pond, Bear Cove Pond (2 intakes)	Jan 29, 2026	LTD	10	59.0	5.40	5.41	33		0.65	LTD	LTD	0.79	14	LTD	0.260	7	2
Ferryland																		
Ferryland	Deep Cove Pond	Jan 29, 2026	4.20	LTD	92.0	7.30	6.41	51		1.10	LTD	LTD	1.40	21	LTD	0.330	13	4

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Flat Bay																		
Flat Bay (East)	#5 Well	Feb 12, 2026	150.00	LTD	420.0	150.00	7.97	230		0.62	LTD	LTD	49.00	44	LTD	1.100	31	6
Fleur de Lys																		
Fleur De Lys	First Pond, Narrow Pond	Feb 10, 2026	7.20	31	94.0	14.00	6.53	52		0.30	LTD	LTD	3.40	21	LTD	0.670	13	3
Flower's Cove																		
Flower's Cove (+Nameless Cove)	French Island Pond	Feb 04, 2026	110.00	18	260.0	120.00	7.66	140		0.18	LTD	LTD	25.00	16	LTD	0.450	7	2
Fogo Island																		
Fogo	Freeman's Pond	Mar 04, 2026	LTD	46	210.0	16.00	3.88	120		0.48	LTD	LTD	2.40	48	0.120	0.610	22	4
Joe Batt's Arm-Barr'd Islands-Shoal Bay	Long Pond	Mar 04, 2026	2.50	29	130.0	13.00	6.02	72		0.27	LTD	LTD	1.80	32	LTD	0.570	21	4
Seldom-Little Seldom	Bullock Cove Pond	Mar 04, 2026	LTD	41	120.0	11.00	4.49	66		0.42	LTD	LTD	1.90	24	LTD	0.320	11	2
Tilting	Sandy Cove Pond	Mar 04, 2026	15.00	71	190.0	21.00	6.80	110		0.78	LTD	LTD	3.70	45	LTD	0.650	29	3
Seldom-Little Seldom - PWDU	Bullock Cove Pond	Mar 04, 2026	LTD	LTD	6.7	LTD	5.41	4		LTD	LTD	LTD	LTD	2	LTD	0.300	1	LTD
Fogo - PWDU	Freeman's Pond	Mar 04, 2026	LTD	LTD	56.0	LTD	3.99	31		LTD	LTD	LTD	LTD	6	LTD	LTD	1	LTD
Forresters Point																		
Forresters Point	Rudges Pond	Feb 04, 2026	160.00	33	430.0	170.00	7.79	240		0.24	LTD	LTD	38.00	43	LTD	0.800	26	6
Fortune																		
Fortune (+Grand Bank)	Horsebrook	Mar 05, 2026	3.20	23	82.0	11.00	6.66	45		0.69	LTD	LTD	2.20	19	LTD	0.350	11	2
Fox Cove-Mortier																		
Fox Cove-Mortier	Rock Pond	Mar 10, 2026	5.80	17	91.0	14.00	6.74	51		0.33	LTD	LTD	3.50	20	LTD	0.240	12	3
Francois																		
Francois	Our Pond	Feb 03, 2026	LTD	32	33.0	4.00	5.91	18		0.13	LTD	LTD	0.77	8	LTD	0.170	4	LTD
Gallants																		
Gallants	Gallant's Brook	Mar 11, 2026	160.00	LTD	320.0	170.00	8.13	180		LTD	LTD	LTD	45.00	10	LTD	0.280	5	3
Gambo																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Gambo																		
Gambo	Dark Cove Pond	Mar 03, 2026	9.80	11	91.0	11.00	6.79	50		0.25	LTD	LTD	3.60	18	LTD	0.240	13	2
Gander																		
Gander	Gander Lake	Feb 25, 2026	17.00	21	61.0	6.40	7.17	34		0.24	LTD	LTD	1.50	6	LTD	0.170	11	LTD
Gander Bay South																		
George's Point, Harris Point	Barry's Brook	Feb 25, 2026	6.50	80	52.0	13.00	6.55	29		0.38	LTD	LTD	2.60	8	LTD	0.150	6	2
Gander Bay South - PWDU	Barry's Brook	Feb 25, 2026	LTD	LTD	21.0	1.30	5.80	12		LTD	LTD	LTD	0.29	6	LTD	LTD	3	LTD
Garden Cove																		
Garden Cove	Arch Cove Pond	Mar 09, 2026	4.00	31	63.0	4.90	6.37	35		0.30	LTD	LTD	1.20	13	LTD	0.170	10	1
Garnish																		
Garnish	Witchazel Pond	Mar 05, 2026	LTD	15	84.0	12.00	4.78	47		0.28	LTD	LTD	2.60	20	LTD	0.360	9	2
Gaskiers																		
Gaskiers-Point La Haye - PWDU	Well	Feb 09, 2026	67.00	LTD	220.0	57.00	8.00	120		LTD	LTD	LTD	13.00	20	0.140	0.910	22	13
Gaultois																		
Gaultois	Piccaire Pond	Mar 10, 2026	LTD	120	87.0	11.00	5.17	48		0.48	LTD	LTD	1.40	19	LTD	0.420	10	3
Gaultois - PWDU	Piccaire Pond	Mar 10, 2026	4.90	LTD	80.0	14.00	6.60	45		LTD	LTD	LTD	1.90	18	LTD	0.460	9	2
George's Brook-Milton																		
George's Brook-Milton	George's Brook	Mar 05, 2026	4.40	25	53.0	7.00	6.69	30		0.16	LTD	LTD	2.00	10	LTD	0.190	8	2
Georgetown																		
Georgetown	Third Pond	Jan 26, 2026	4.00	9	100.0	8.60	6.49	56		0.25	LTD	LTD	1.90	25	LTD	0.420	16	3
Gillams																		
Gillams	Meaters Pond	Mar 10, 2026	15.00	8	71.0	17.00	7.19	40		0.14	LTD	LTD	5.00	10	LTD	0.280	7	3
Glenburnie-Birchy Head-Shoal Brook																		
Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Jan 27, 2026	25.00	25	83.0	28.00	7.36	46		LTD	LTD	LTD	6.20	10	LTD	0.390	6	2
Glenwood																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Glenwood																		
Glenwood	Gander Lake (The Outflow)	Feb 25, 2026	LTD	31	30.0	5.70	5.37	16		0.20	LTD	LTD	1.30	5	LTD	0.140	2	LTD
Glovertown																		
Glovertown	Northwest Pond	Mar 05, 2026	3.20	37	36.0	5.40	6.31	20		0.13	LTD	LTD	1.50	7	LTD	0.200	5	LTD
Goobies																		
Goobies	Water Pond	Mar 09, 2026	3.50	31	31.0	6.70	6.27	17		0.26	LTD	LTD	1.90	6	LTD	0.180	3	LTD
Goose Cove East																		
Goose Cove East	Jack's Pond	Feb 03, 2026	39.00	35	210.0	52.00	7.29	110		0.36	LTD	LTD	17.00	36	LTD	0.390	21	4
Grand Bank																		
Grand Bank	Horsebrook	Mar 05, 2026	3.80	LTD	84.0	11.00	6.50	47		0.16	LTD	LTD	2.20	20	LTD	0.350	12	3
Grand Falls-Windsor																		
Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Jan 20, 2026	6.10	LTD	89.0	33.00	7.06	49		LTD	LTD	LTD	12.00	4	LTD	0.130	2	24
Grand Le Pierre																		
Grand Le Pierre	Nip Nose Pond	Mar 06, 2026	3.10	17	39.0	5.80	6.45	22		0.25	LTD	LTD	1.60	8	LTD	0.180	5	1
Great Brehat																		
Great Brehat	Little Steady Pond	Feb 04, 2026	15.00	58	140.0	31.00	6.94	78		0.38	LTD	LTD	9.10	26	LTD	0.300	14	10
Green Island Brook																		
Green Island Brook	Green Island Brook	Feb 04, 2026	98.00	25	200.0	100.00	7.87	110		0.20	LTD	LTD	20.00	9	LTD	0.350	5	2
Greenspond																		
Greenspond	Shambler's Cove Pond	Mar 03, 2026	LTD	34	120.0	7.70	4.32	64		0.28	LTD	LTD	1.50	26	LTD	0.350	14	3
Grey River																		
Grey River	Big Charlie's Pond	Mar 09, 2026	LTD	78	65.0	7.80	5.57	36		0.43	LTD	LTD	0.88	15	LTD	0.280	8	9
Hampden																		
Hampden	Elliot Brook	Feb 11, 2026	26.00	12	69.0	29.00	7.26	38		0.11	LTD	LTD	9.70	6	LTD	0.250	3	2

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Hant's Harbour																		
Hant's Harbour	Eastern Pond (Halfway Brook)	Feb 11, 2026	LTD	16	52.0	6.60	5.29	29		0.22	LTD	LTD	1.30	12	LTD	0.160	6	2
Happy Adventure																		
Happy Adventure	Goose Neck Pond	Mar 10, 2026	LTD	42	55.0	9.00	5.37	30		0.33	LTD	LTD	2.40	11	LTD	0.260	5	2
Happy Valley-Goose Bay																		
Happy Valley-Goose Bay	Spring Gulch	Mar 05, 2026	14.00	LTD	34.0	13.00	7.15	19		0.32	LTD	LTD	2.80	2	LTD	1.300	1	1
Happy Valley-Goose Bay	Well Field (connect summer 2002)	Mar 04, 2026	30.00	LTD	99.0	32.00	7.28	55		0.15	LTD	LTD	6.80	12	LTD	2.200	6	2
Harbour Breton																		
Harbour Breton	Connaigra Pond, Hutchings Pond	Feb 04, 2026	14.00	23	84.0	22.00	6.86	47		0.24	LTD	LTD	6.30	15	LTD	0.250	8	2
Harbour Grace																		
Harbour Grace, Harbour Grace South (+Riverhead)	Bannerman Lake	Jan 29, 2026	LTD	LTD	47.0	6.70	5.27	26		0.40	LTD	LTD	1.60	11	LTD	0.140	5	2
Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Jan 08, 2026	93.00	LTD	220.0	87.00	7.99	120		LTD	LTD	LTD	28.00	11	LTD	0.280	9	7
Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Jan 08, 2026	94.00	LTD	230.0	89.00	7.95	130		LTD	LTD	LTD	28.00	11	LTD	0.280	9	7
Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Jan 29, 2026	94.00	LTD	220.0	92.00	7.88	120		LTD	LTD	LTD	29.00	11	LTD	0.280	10	7
Harbour Main-Chapel's Cove-Lakeview																		
Harbour Main, Chapel's Cove, Lakeview	Maloney's River	Jan 26, 2026	5.90	10	89.0	12.00	6.90	50		0.27	LTD	LTD	3.90	19	LTD	0.270	12	3
Hare Bay																		
Hare Bay (+Dover)	Hare Bay Pond	Mar 03, 2026	LTD	52	39.0	4.30	5.21	22		0.27	LTD	LTD	0.88	9	LTD	0.200	4	LTD
Hare Bay (+Dover)	Hare Bay Pond	Mar 18, 2026	5.40	65	48.0	3.70	6.52	27		0.29	LTD	LTD	0.70	9	LTD	0.190	9	LTD
Hare Bay (+Dover)	Hare Bay Pond	Mar 18, 2026	5.40	52	48.0	3.90	6.52	27		0.37	LTD	LTD	0.76	9	LTD	0.190	9	LTD
Hare Bay (+Dover)	Hare Bay Pond	Mar 18, 2026	4.90	56	47.0	4.10	6.46	26		0.23	LTD	LTD	0.80	9	LTD	0.200	9	LTD
Hawke's Bay																		
Hawke's Bay	Torrent River	Feb 05, 2026	11.00	41	63.0	21.00	6.79	35		0.23	LTD	LTD	5.40	10	LTD	0.290	4	2

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Heart's Content																		
Heart's Content	Southern Cove Pond	Jan 29, 2026	3.00	11	47.0	4.80	6.22	26		0.30	LTD	LTD	0.95	11	LTD	0.140	7	2
Heart's Delight-Islington																		
Heart's Delight-Islington	Long Pond	Jan 29, 2026	7.10	LTD	130.0	7.60	6.99	70		0.41	LTD	LTD	1.40	30	LTD	0.280	21	4
Heart's Desire																		
Heart's Desire	Terrence Pond	Feb 09, 2026	2.10	LTD	60.0	7.90	6.17	34		0.22	LTD	LTD	1.80	13	LTD	0.270	8	2
Hermitage																		
Hermitage-Sandyville	Granfer's Pond	Feb 04, 2026	2.20	42	80.0	7.00	5.71	45		0.35	LTD	LTD	1.20	18	LTD	0.260	12	2
Hermitage-Sandyville - PWDU	Granfer's Pond	Feb 04, 2026	LTD	LTD	7.7	LTD	6.23	4		LTD	LTD	LTD	LTD	2	LTD	LTD	1	LTD
Herring Neck																		
Herring Neck, Hatchet Harbour, Salt Harbour, Shoal Cove, Sunnyside	Gut Pond	Feb 17, 2026	27.00	12	260.0	41.00	7.29	150		0.17	LTD	LTD	10.00	62	LTD	0.680	35	7
Hickman's Harbour-Robinson Bight																		
Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Mar 03, 2026	8.20	10	52.0	10.00	6.86	29		0.22	LTD	LTD	2.90	8	LTD	0.150	6	2
Howley																		
Howley	Sandy Lake	Feb 06, 2026	6.10	33	46.0	7.40	6.68	25		0.42	LTD	LTD	1.90	8	LTD	0.220	7	LTD
Howley - PWDU	Sandy Lake	Feb 06, 2026	LTD	LTD	2.6	LTD	6.21	1		LTD	LTD	LTD	LTD	LTD	LTD	LTD	0	LTD
Hughes Brook																		
Hughes Brook	Reservoir	Mar 10, 2026	180.00	LTD	350.0	180.00	8.18	190		0.28	LTD	LTD	39.00	10	LTD	0.300	6	4
Humber Arm South																		
Halfway Point, Benoit's Cove, John's Beach	Dormody's Brook	Feb 20, 2026	52.00	LTD	120.0	56.00	7.83	68		LTD	LTD	LTD	1.20	8	LTD	0.140	4	LTD
Frenchman's Cove Area	Gurges Pond	Feb 20, 2026	17.00	10	82.0	22.00	7.22	46		0.11	LTD	LTD	5.30	10	LTD	0.360	8	4
Indian Bay																		
Indian Bay	Indian Bay Brook	Mar 03, 2026	3.60	26	43.0	5.60	6.51	24		0.31	LTD	LTD	1.20	8	LTD	0.160	6	1
Irishtown-Summerside																		

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Irishtown-Summerside																		
Irishtown	Irishtown Brook	Mar 10, 2026	4.90	30	75.0	21.00	6.58	42		0.61	LTD	LTD	5.80	15	LTD	0.190	6	3
Summerside	Pynn's Pond	Mar 10, 2026	3.40	22	48.0	11.00	6.37	27		0.13	LTD	LTD	2.80	10	LTD	0.180	5	2
Isle aux Morts																		
Isle aux Morts	Burnt Ground Pond	Feb 04, 2026	3.80	39	68.0	17.00	6.44	38		0.44	LTD	LTD	5.40	16	LTD	0.280	7	2
Isle aux Morts - PWDU	Burnt Ground Pond	Feb 04, 2026	LTD	LTD	18.0	LTD	6.08	10		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Jackson's Arm																		
Jackson's Arm	Unnamed Brook	Feb 11, 2026	LTD	20	43.0	9.40	5.04	24		0.36	LTD	LTD	2.70	9	LTD	0.340	3	LTD
Jackson's Arm - PWDU	Unnamed Brook	Feb 11, 2026	LTD	LTD	110.0	LTD	5.39	62		LTD	LTD	LTD	0.12	LTD	LTD	LTD	0	LTD
Jackson's Cove-Langdon's Cove-Silverdale																		
Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Feb 18, 2026	14.00	14	100.0	18.00	7.07	57		0.29	LTD	LTD	5.30	19	LTD	0.250	12	3
Keels																		
Keels	Boland's Pond	Jan 20, 2026	2.30	61	130.0	5.20	5.76	73		0.55	LTD	LTD	0.54	31	LTD	0.390	24	2
King's Point																		
King's Point	Bulley's Pond	Feb 18, 2026	LTD	21	42.0	6.00	4.64	24		0.20	LTD	LTD	1.80	7	LTD	0.110	2	1
La Poile																		
La Poile	Black Duck Pond	Feb 10, 2026	LTD	78	51.0	6.90	5.63	28		0.36	LTD	LTD	1.10	12	LTD	0.340	7	2
LaScie																		
La Scie	Stakes Pond	Feb 11, 2026	4.10	27	61.0	9.00	6.54	34		0.15	LTD	LTD	2.30	14	LTD	0.260	9	2
Labrador City																		
Labrador City	Beverly Lake	Feb 25, 2026	51.00	LTD	110.0	53.00	7.64	61		0.18	LTD	LTD	13.00	3	LTD	1.500	1	3
Lamaline																		
Lamaline	Upper Hodges Pond	Mar 05, 2026	7.20	LTD	120.0	21.00	6.75	68		0.25	LTD	LTD	5.00	29	LTD	0.280	14	4
Lamaline - PWDU	Upper Hodges Pond	Mar 05, 2026	2.50	LTD	9.6	LTD	6.39	5		LTD	LTD	LTD	LTD	2	LTD	LTD	2	LTD

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Lark Harbour																		
Lark Harbour	Fairfax Brook	Feb 20, 2026	17.00	LTD	140.0	27.00	7.20	79		0.40	LTD	LTD	4.90	27	LTD	0.330	16	4
Lawn																		
Lawn	Brazil Pond	Mar 05, 2026	LTD	8	78.0	11.00	5.78	44		0.43	LTD	LTD	2.50	19	LTD	0.220	9	2
Lawn - PWDU	Brazil Pond	Mar 05, 2026	LTD	LTD	50.0	3.50	5.29	28		LTD	LTD	LTD	0.83	13	LTD	0.150	8	LTD
Leading Tickles																		
Leading Tickles	Cook's Pond	Feb 10, 2026	4.80	31	110.0	18.00	6.57	59		0.41	LTD	LTD	4.50	22	LTD	0.300	14	2
Leading Tickles - PWDU	Cook's Pond	Feb 10, 2026	LTD	LTD	8.7	LTD	6.15	5		LTD	LTD	LTD	LTD	1	LTD	LTD	1	LTD
Lewin's Cove																		
Lewin's Cove	Big Pond	Mar 05, 2026	LTD	13	59.0	11.00	5.77	33		0.39	LTD	LTD	2.80	14	LTD	0.290	7	2
Lewisporte																		
Lewisporte	Stanhope Pond	Jan 20, 2026	8.80	32	64.0	17.00	6.51	35		0.29	LTD	LTD	4.90	11	LTD	0.220	6	1
Little Bay																		
Little Bay	Mine Pond	Feb 18, 2026	38.00	16	170.0	64.00	7.34	93		0.13	LTD	LTD	21.00	10	LTD	0.160	9	25
Little Bay	First Pond	Feb 18, 2026	29.00	LTD	81.0	30.00	7.41	45		LTD	LTD	LTD	9.90	6	LTD	LTD	5	3
Little Burnt Bay																		
Little Burnt Bay	Troke's Cove Pond	Jan 20, 2026	8.00	15	83.0	16.00	6.58	46		0.26	LTD	LTD	4.40	17	LTD	0.300	10	2
Little Harbour East																		
Little Harbour East (Placentia Bay)	Unnamed Pond	Mar 09, 2026	2.70	49	70.0	12.00	6.33	39		0.40	LTD	LTD	2.70	16	LTD	0.330	8	2
Little St. Lawrence																		
Little St. Lawrence	Butler's Brook (2 Intakes)	Mar 05, 2026	2.30	14	72.0	10.00	6.38	40		0.18	LTD	LTD	2.10	16	LTD	0.380	9	3
Long Harbour-Mount Arlington Heights																		
Long Harbour-Mount Arlington Heights	Shingle Pond and/or Trout Pond (2 Intakes)	Jan 23, 2026	14.00	LTD	160.0	9.90	7.06	91		LTD	LTD	LTD	2.00	38	LTD	0.160	29	6
Loon Bay																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Loon Bay																		
Loon Bay	Southeast Pond	Jan 20, 2026	6.60	34	55.0	15.00	6.89	31		0.24	LTD	LTD	4.40	8	LTD	0.150	6	1
Lourdes																		
Lourdes (+West Bay)	Victor's Brook	Mar 09, 2026	66.00	43	220.0	85.00	7.73	120		2.30	LTD	LTD	25.00	27	LTD	0.460	13	6
Lumsden																		
Lumsden	Gull Pond	Mar 02, 2026	27.00	LTD	230.0	4.90	6.72	130		1.30	LTD	LTD	0.66	12	LTD	0.170	42	58
Lushes Bight-Beaumont-Beaumont North																		
Lushes Bight, Beaumont	Milkboy's Pond/Gull Pond	Feb 26, 2026	9.90	57	61.0	15.00	6.71	34		0.22	LTD	LTD	4.40	10	LTD	0.200	6	2
Lushes Bight, Beaumont - PWDU	Milkboy's Pond/Gull Pond	Feb 26, 2026	4.20	LTD	130.0	LTD	6.19	75		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
Main Brook																		
Main Brook	Joe Burt's Pond	Feb 03, 2026	44.00	15	110.0	50.00	7.48	64		0.22	LTD	LTD	14.00	9	LTD	0.250	3	2
Marystown																		
Marystown	Fox Hill Reservoir / Clam Pond	Mar 10, 2026	9.00	LTD	110.0	10.00	6.99	63		LTD	LTD	LTD	2.80	26	LTD	0.230	18	4
Massey Drive																		
Massey Drive	Trout Pond, Third Pond (2 intakes)	Feb 20, 2026	30.00	LTD	99.0	22.00	7.59	55		LTD	LTD	LTD	7.00	10	LTD	0.330	12	3
McIvers																		
McIvers	McIvers Brook	Mar 10, 2026	16.00	33	98.0	25.00	7.33	55		0.20	LTD	LTD	7.80	16	LTD	0.230	9	3
Meadows																		
Meadows, Summerside West	Meaters Pond	Mar 10, 2026	2.90	7	65.0	18.00	7.00	36		0.21	LTD	LTD	5.20	10	LTD	0.290	5	3
Merritt's Harbour																		
Merritt's Harbour	Jimmy's Pond	Feb 17, 2026	12.00	35	210.0	27.00	6.73	110		0.27	LTD	LTD	5.80	53	LTD	0.680	29	6
Middle Arm																		
Middle Arm	Dam Pond Brook	Feb 10, 2026	5.00	49	27.0	7.30	6.70	15		0.13	LTD	LTD	2.30	4	LTD	LTD	3	LTD
Miles Cove																		
Miles Cove	Paddock's Pond	Feb 26, 2026	4.60	28	57.0	15.00	6.39	32		LTD	LTD	LTD	4.40	11	LTD	LTD	4	2

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Millertown																		
Millertown	Water Pond	Feb 25, 2026	15.00	110	78.0	17.00	6.64	43		0.59	LTD	LTD	5.60	11	LTD	0.200	9	LTD
Millertown	Water Pond	Mar 17, 2026	20.00	89	64.0	19.00	6.67	36		0.57	LTD	LTD	6.10	8	LTD	0.210	6	LTD
Millertown	Water Pond	Mar 17, 2026	23.00	76	83.0	21.00	6.76	46		0.54	LTD	LTD	7.00	11	LTD	0.240	9	LTD
Millertown	Water Pond	Mar 17, 2026	17.00	89	64.0	19.00	6.70	35		0.66	LTD	LTD	6.20	7	LTD	0.200	6	LTD
Milltown-Head of Bay D'Espoir																		
Milltown, Head of Bay D'Espoir	Jersey Pond	Feb 16, 2026	6.60	21	53.0	15.00	6.55	30		0.32	LTD	LTD	3.80	10	LTD	0.200	5	4
Ming's Bight																		
Ming's Bight	Middle Brook Pond	Feb 11, 2026	16.00	26	63.0	21.00	7.21	35		0.18	LTD	LTD	6.20	8	LTD	LTD	4	2
Morrisville																		
Morrisville	Morrisville Pond	Feb 16, 2026	9.60	32	64.0	16.00	6.96	35		0.16	LTD	LTD	4.40	11	LTD	0.220	7	3
Mount Moriah																		
Mount Moriah	Trout Pond, Third Pond (2 intakes)	Feb 20, 2026	28.00	LTD	97.0	21.00	7.55	54		LTD	LTD	LTD	6.50	10	LTD	0.340	11	3
Mount Pearl																		
Mount Pearl	Bay Bulls Big Pond	Mar 05, 2026	22.00	LTD	100.0	26.00	7.40	57		0.15	LTD	LTD	9.30	16	LTD	0.220	8	2
Musgrave Harbour																		
Musgrave Harbour	Rocky Pond	Feb 25, 2026	38.00	LTD	180.0	10.00	7.54	100		LTD	LTD	LTD	1.80	30	LTD	0.420	32	5
Nameless Cove																		
Nameless Cove / Flower Cove	French Island Pond	Feb 04, 2026	110.00	13	260.0	130.00	7.68	140		LTD	LTD	LTD	26.00	15	LTD	0.470	7	2
Natuashish																		
Natuashish (Sango Bay)	Sango Brook and Wellfield	Feb 15, 2026	52.00	LTD	630.0	60.00	7.77	350		LTD	0.12	LTD	9.60	140	1.600	5.500	98	23
New Chelsea-New Melbourne-Brownsdale-Sibley's Cove-I																		
Sibley's Cove, Lead Cove	Sibley's Cove Pond	Feb 11, 2026	3.20	16	58.0	6.40	6.13	32		0.15	LTD	LTD	1.30	13	LTD	0.170	9	2
New Perlican																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
New Perlican																		
New Perlican	New Perlican River	Feb 11, 2026	2.80	12	52.0	6.10	6.26	29		0.18	LTD	LTD	1.40	12	LTD	0.170	8	2
New-Wes-Valley																		
Wesleyville-Badger's Quay-Pool's Island, Brookfield-Poundcove-Newtown-Templeman	Little Northwest Pond	Mar 02, 2026	25.00	81	140.0	6.80	7.19	79		0.33	LTD	LTD	1.30	26	LTD	0.340	30	2
Newman's Cove																		
Newman's Cove	Heale Pond Brook	Jan 20, 2026	2.40	150	64.0	6.80	5.64	36		2.30	LTD	LTD	0.98	13	LTD	0.360	10	2
Nippers Harbour																		
Nippers Harbour	Blackhead Pond Brook	Feb 11, 2026	5.10	55	30.0	8.10	6.59	16		0.18	LTD	LTD	2.40	5	LTD	0.130	3	LTD
Norman's Cove-Long Cove																		
Norman's Cove-Long Cove	John Newhooks Pond	Jan 22, 2026	4.00	6	54.0	5.50	6.61	30		0.28	LTD	LTD	1.30	11	LTD	0.130	7	1
Norris Arm																		
Norris Arm (south)	Mill Lake	Jan 20, 2026	2.30	15	40.0	10.00	6.07	22		0.13	LTD	LTD	2.80	8	LTD	0.280	3	1
Norris Point																		
Norris Point	Neddy Harbour Pond	Feb 06, 2026	160.00	LTD	320.0	170.00	7.76	180		0.23	LTD	LTD	40.00	13	LTD	0.590	6	1
North Harbour																		
North Harbour	Grandfather's Pond	Mar 09, 2026	LTD	120	37.0	4.00	5.42	20		1.10	LTD	LTD	0.63	7	LTD	0.250	4	2
Northern Arm																		
Northern Arm	Northern Arm Lake	Jan 20, 2026	9.40	LTD	92.0	33.00	7.10	51		LTD	LTD	LTD	12.00	4	LTD	0.100	2	24
Old Perlican																		
Old Perlican	Bell Pond	Feb 11, 2026	LTD	9	91.0	6.60	5.04	50		0.32	LTD	LTD	1.10	22	LTD	0.270	12	3
Pacquet																		
Pacquet	Big Brook	Feb 11, 2026	LTD	68	36.0	4.20	5.63	20		0.27	LTD	LTD	0.65	8	LTD	0.240	5	1
Pacquet - PWDU	Big Brook	Feb 11, 2026	LTD	LTD	5.8	LTD	6.03	3		LTD	LTD	LTD	LTD	1	LTD	LTD	1	LTD
Paradise																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Paradise																		
Paradise	Bay Bulls Big Pond	Mar 05, 2026	25.00	LTD	110.0	29.00	7.64	60		0.14	LTD	LTD	11.00	16	LTD	0.230	8	2
Parkers Cove																		
Parkers Cove	Unnamed brook	Mar 10, 2026	2.40	44	57.0	5.60	6.13	31		0.37	LTD	LTD	0.96	13	LTD	0.180	8	2
Parson's Pond																		
Parson's Pond	Cold Brook	Feb 11, 2026	250.00	LTD	690.0	250.00	7.91	380		LTD	LTD	LTD	80.00	69	LTD	1.500	40	9
Pasadena																		
Pasadena	Blue Gulch Pond	Mar 06, 2026	20.00	8	61.0	20.00	6.92	34		0.13	LTD	LTD	6.60	7	0.180	0.210	3	2
Peterview																		
Peterview	Northern Arm Lake	Jan 20, 2026	8.10	LTD	90.0	34.00	7.04	50		0.29	LTD	LTD	13.00	4	LTD	0.110	2	24
Petit Forte																		
Petit Forte	Reddy's Pond	Mar 06, 2026	LTD	45	54.0	7.10	5.96	30		0.37	LTD	LTD	1.10	12	LTD	0.370	8	2
Petty Harbour-Maddox Cove																		
Petty Harbour-Maddox Cove	Western Barrens Pond	Feb 16, 2026	4.80	12	47.0	4.20	6.61	26		0.30	LTD	LTD	0.80	10	LTD	0.220	8	2
Phillips Head																		
Phillips Head	Dogberry Brook	Feb 10, 2026	25.00	18	79.0	25.00	7.34	44		0.21	LTD	LTD	8.10	8	LTD	0.100	6	2
Piccadilly Head																		
Piccadilly Head (+West Bay)	Unnamed Brook	Mar 09, 2026	120.00	27	270.0	120.00	8.05	150		0.45	LTD	LTD	38.00	15	0.110	0.370	9	5
Pidgeon Cove-St. Barbe																		
Pigeon Cove - St. Barbe	Long Pond	Feb 04, 2026	130.00	32	300.0	140.00	7.78	160		0.15	LTD	LTD	27.00	20	LTD	0.450	13	3
Pilley's Island																		
Pilley's Island	Loadabats Pond	Feb 26, 2026	66.00	15	230.0	64.00	7.62	130		LTD	LTD	LTD	21.00	29	LTD	0.540	18	3
Placentia																		
Placentia, Jerseyside, SE Placentia	Larkins Pond	Jan 23, 2026	7.10	7	110.0	20.00	6.64	62		0.39	LTD	LTD	5.70	25	LTD	0.310	14	3
Freshwater, Argentia site, Dunville	Clarkes Pond	Jan 23, 2026	2.70	17	100.0	18.00	6.17	56		0.75	LTD	LTD	4.90	24	LTD	0.290	11	3

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Pleasantview																		
Pleasantview	Little Arm Pond	Feb 10, 2026	17.00	39	100.0	18.00	6.86	56		0.39	LTD	LTD	5.20	17	LTD	0.330	12	2
Plum Point																		
Plum Point	Grand Pond	Feb 04, 2026	100.00	31	280.0	110.00	7.80	150		0.30	LTD	LTD	23.00	27	LTD	0.510	17	3
Point Lance																		
Point Lance	Unnamed Pond	Mar 10, 2026	LTD	36	120.0	16.00	6.18	67		0.35	LTD	LTD	1.90	30	LTD	0.470	15	4
Point Leamington																		
Point Leamington	Little Pond	Feb 10, 2026	LTD	19	42.0	9.40	5.09	23		0.22	LTD	LTD	2.80	9	LTD	LTD	3	1
Point May																		
Point May	Short's Pond	Mar 05, 2026	3.40	5	110.0	16.00	6.42	62		0.30	LTD	LTD	3.20	28	LTD	0.240	14	3
Point May - PWDU	Short's Pond	Mar 05, 2026	LTD	LTD	81.0	7.50	5.87	45		LTD	LTD	LTD	1.40	22	LTD	0.150	12	LTD
Point of Bay																		
Point of Bay	Indian Cove Pond	Feb 10, 2026	12.00	30	80.0	14.00	6.81	44		0.30	LTD	LTD	4.50	14	LTD	0.110	10	1
Pollards Point																		
Pollards Point, Country Cove	Country Cove Pond	Feb 11, 2026	23.00	8	100.0	26.00	7.24	58		0.20	LTD	LTD	8.90	19	LTD	0.450	11	2
Pollards Point East	George Ricks Pond	Feb 11, 2026	15.00	41	43.0	15.00	6.93	24		0.88	LTD	LTD	LTD	4	LTD	LTD	LTD	LTD
Pollards Point East	George Ricks Pond	Mar 04, 2026	17.00	50	49.0	17.00	6.77	27		4.30	LTD	LTD	5.70	4	LTD	0.520	3	LTD
Pollards Point East	George Ricks Pond	Mar 04, 2026	16.00	54	49.0	16.00	6.49	27		4.00	LTD	LTD	5.30	4	LTD	0.500	3	2
Pool's Cove																		
Pool's Cove	Widgeon Pond	Feb 04, 2026	12.00	23	73.0	15.00	6.80	41		0.29	LTD	LTD	3.60	12	LTD	0.380	8	2
Port Albert																		
Port Albert	Beaverton Pond	Mar 04, 2026	35.00	37	140.0	34.00	7.08	77		0.20	LTD	LTD	11.00	21	LTD	0.240	12	2
Port Anson																		
Port Anson	Anchor Pond	Feb 26, 2026	23.00	37	110.0	21.00	6.97	62		0.64	LTD	LTD	6.70	18	LTD	0.200	13	1

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Port Anson																		
Port Anson	Anchor Pond	Mar 18, 2026	25.00	43	110.0	23.00	6.97	63		1.50	LTD	LTD	7.40	18	LTD	0.220	14	1
Port Blandford																		
Port Blandford	Noseworthy's Pond	Mar 10, 2026	21.00	11	160.0	14.00	6.86	88		LTD	LTD	LTD	4.30	35	LTD	0.210	26	5
Port Rexton																		
Port Rexton	#1 Well - Lois Long Well	Mar 11, 2026	63.00	LTD	330.0	110.00	7.67	180		0.12	LTD	LTD	32.00	52	0.130	0.700	21	17
Port Rexton (Seasonal Use)	#2 Well - Edmund Brown's Well	Mar 11, 2026	69.00	LTD	210.0	74.00	7.60	120		0.37	LTD	LTD	23.00	16	LTD	0.480	10	13
Hunchback Hill	#3 Well - Harold Vivian's Well	Mar 11, 2026	77.00	LTD	360.0	92.00	7.94	200		LTD	LTD	LTD	27.00	55	0.180	0.510	40	16
Ship Cove	#5 Well - Mabel Clarke's Well	Mar 11, 2026	11.00	9	300.0	40.00	6.79	170		0.67	LTD	LTD	13.00	80	LTD	1.500	42	6
Ship Cove	#6 Well - Banister's Well	Mar 11, 2026	100.00	LTD	270.0	100.00	7.97	150		0.23	LTD	LTD	27.00	14	LTD	0.700	15	17
Champneys Arm	Champney's Arm Well	Mar 11, 2026	99.00	LTD	350.0	120.00	7.80	200		0.14	LTD	LTD	34.00	50	LTD	0.430	25	5
Port Saunders																		
Port Saunders	Tom Taylor's Pond	Feb 05, 2026	110.00	25	250.0	120.00	7.79	140		0.20	LTD	LTD	26.00	18	LTD	0.620	10	2
Port Saunders - PWDU	Tom Taylor's Pond	Feb 05, 2026	51.00	LTD	150.0	54.00	7.56	82		LTD	LTD	LTD	14.00	16	LTD	0.470	7	LTD
Port au Choix																		
Port au Choix	Winterhouse Pond	Feb 05, 2026	150.00	LTD	370.0	160.00	7.80	210		0.30	LTD	LTD	44.00	31	LTD	0.740	14	3
Port au Choix - PWDU	Winterhouse Pond	Feb 05, 2026	4.10	LTD	12.0	1.00	6.66	7		LTD	LTD	LTD	0.40	2	LTD	LTD	2	LTD
Port au Port West-Aguathuna-Felix Cove																		
Port au Port West	Jim Rowe's Brook	Mar 05, 2026	210.00	LTD	530.0	230.00	8.09	300		LTD	0.06	LTD	56.00	41	0.310	2.600	25	13
Portland Creek																		
Portland Creek	Unnamed Streams	Feb 11, 2026	160.00	LTD	340.0	160.00	7.98	190		LTD	LTD	LTD	53.00	15	LTD	0.620	11	4
Portugal Cove South																		
Portugal Cove South	Wrights Brook	Feb 09, 2026	5.70	8	63.0	9.10	6.62	35		LTD	LTD	LTD	1.70	13	LTD	0.270	8	2
Portugal Cove-St. Phillips																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Portugal Cove-St. Phillips																		
Portugal Cove-St. Phillips	Bay Bulls Big Pond	Mar 03, 2026	23.00	LTD	100.0	28.00	7.38	57		0.21	LTD	LTD	10.00	16	LTD	0.220	9	2
Pouch Cove																		
Pouch Cove	North Three Island Pond	Feb 16, 2026	3.70	LTD	67.0	8.70	6.50	37		LTD	LTD	LTD	1.90	17	LTD	0.250	9	1
Purcell's Harbour																		
Purcell's Harbour	Purcell's Harbour Pond	Feb 17, 2026	7.50	110	210.0	23.00	6.30	120		1.10	LTD	LTD	5.20	57	LTD	0.620	32	5
Pynn's Brook																		
Pynn's Brook	Pynn's Brook	Mar 06, 2026	50.00	16	130.0	54.00	7.71	71		0.20	LTD	LTD	18.00	5	LTD	0.310	5	7
Ramea																		
Ramea	Northwest Pond	Mar 10, 2026	7.60	24	400.0	53.00	7.39	220		0.75	LTD	LTD	11.00	88	LTD	1.700	57	36
Ramea - PWDU	Northwest Pond	Mar 10, 2026	15.00	9	400.0	50.00	7.44	220		0.28	LTD	LTD	11.00	89	LTD	1.600	58	35
Random Sound West																		
Queen's Cove	Reservoir	Mar 10, 2026	3.90	73	29.0	7.60	6.43	16		0.43	LTD	LTD	2.30	5	LTD	0.110	3	2
Rattling Brook																		
Rattling Brook	Mark's Pond Brook	Feb 18, 2026	3.00	46	30.0	4.00	6.33	17		0.13	LTD	LTD	1.20	5	LTD	0.120	4	LTD
Reidville																		
Reidville	Humber Canal, Grand Lake	Feb 06, 2026	8.70	14	40.0	13.00	6.73	22		LTD	LTD	LTD	3.80	6	LTD	0.220	3	LTD
River of Ponds																		
River of Ponds	Burnt Head Ponds	Feb 05, 2026	74.00	21	200.0	77.00	7.73	110		0.13	LTD	LTD	20.00	17	LTD	0.340	10	1
Robert's Arm																		
Robert's Arm	Young's Pond / Dam Pond	Feb 26, 2026	29.00	10	89.0	34.00	7.10	50		0.43	LTD	LTD	11.00	9	LTD	0.150	4	1
Rocky Harbour																		
Rocky Harbour	Gull Pond	Feb 06, 2026	78.00	18	190.0	82.00	7.68	110		LTD	LTD	LTD	22.00	13	LTD	0.460	6	1
Roddickton-Bide Arm																		
Bide Arm	First Clay Cove Pond	Feb 03, 2026	120.00	9	230.0	110.00	7.86	130		LTD	LTD	LTD	33.00	7	LTD	0.260	5	LTD

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Roddickton-Bide Arm																		
Roddickton	East Brook Pond	Feb 03, 2026	69.00	21	150.0	71.00	7.65	82		0.20	LTD	LTD	22.00	7	LTD	0.210	3	1
Rose Blanche-Harbour Le Cou																		
Rose Blanche-Harbour Le Cou	Rose Blanche Brook	Feb 04, 2026	LTD	21	54.0	4.40	6.16	30		0.15	LTD	LTD	0.83	12	LTD	0.190	9	2
Rushoon																		
Rushoon	Big Pond Brook	Mar 10, 2026	LTD	30	55.0	7.90	6.35	31		0.29	LTD	LTD	1.80	13	LTD	0.190	7	2
Salmon Cove																		
Salmon Cove	Rocky Pond	Jan 30, 2026	2.10	LTD	39.0	4.80	6.26	22		0.18	LTD	LTD	1.20	9	LTD	0.140	5	1
Salvage																		
Salvage	Wild Cove Pond	Mar 05, 2026	7.00	65	160.0	14.00	6.36	88		0.41	LTD	LTD	3.70	37	LTD	0.460	26	4
Seal Cove (FB)																		
Seal Cove, F.B.	Big Black Duck Pond	Feb 04, 2026	LTD	82	60.0	8.90	5.82	33		0.40	LTD	LTD	1.50	13	LTD	0.300	8	2
Seal Cove, F.B. - PWDU	Big Black Duck Pond	Feb 04, 2026	LTD	LTD	7.9	LTD	6.06	4		LTD	LTD	LTD	LTD	2	LTD	LTD	1	LTD
Seal Cove (WB)																		
Seal Cove, W.B.	Seal Cove Brook & Long Pond	Feb 10, 2026	7.30	61	69.0	13.00	6.76	38		0.29	LTD	LTD	3.80	13	LTD	0.380	9	1
Sheaves Cove																		
Sheaves Cove	Unnamed Brook	Mar 10, 2026	110.00	22	260.0	120.00	7.91	140		0.63	LTD	LTD	38.00	17	LTD	0.370	9	4
Shoe Cove																		
Shoe Cove	Second Pond	Feb 11, 2026	3.30	120	66.0	12.00	6.15	36		0.42	LTD	LTD	3.00	15	LTD	0.210	9	2
Smith's Harbour																		
Smith's Harbour	Fleshetts Brook	Feb 10, 2026	LTD	81	28.0	8.20	6.43	16		0.34	LTD	LTD	2.10	5	LTD	0.110	3	LTD
Sop's Arm																		
Sop's Arm	Little Tickle Pond	Feb 11, 2026	9.20	55	33.0	13.00	6.75	18		0.31	LTD	LTD	3.70	4	LTD	0.310	2	LTD
South Brook																		
South Brook	Next to Brook	Feb 25, 2026	41.00	LTD	170.0	54.00	7.44	94		LTD	LTD	LTD	17.00	23	LTD	0.830	11	4

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
South Dildo																		
South Dildo	Broad Cove Pond	Feb 09, 2026	LTD	19	59.0	6.80	5.02	33		0.55	LTD	LTD	1.30	11	LTD	0.200	5	2
South River																		
South River	Brigus Long Pond (to Brigus)	Feb 05, 2026	3.40	14	56.0	7.40	6.35	31		0.45	LTD	LTD	1.80	13	LTD	0.260	8	1
Southern Harbour																		
Southern Harbour	Brigades Pond	Jan 22, 2026	LTD	LTD	64.0	11.00	5.28	36		0.55	LTD	LTD	3.10	14	LTD	0.210	5	2
Spaniard's Bay																		
Spaniard's Bay (+Upper Island Cove, + Bryant's Cove)	Kelly's Pond (Spider's Pond)	Jan 30, 2026	12.00	33	98.0	4.90	6.89	54		0.28	LTD	LTD	1.00	9	LTD	0.160	6	2
Springdale																		
Springdale	Sullivan's Pond (2 Intakes)	Feb 18, 2026	14.00	15	49.0	17.00	6.83	27		0.12	LTD	LTD	5.30	6	LTD	LTD	2	2
St. Anthony																		
St. Anthony	St. Anthony Pond	Feb 04, 2026	17.00	39	69.0	29.00	7.01	39		0.18	LTD	LTD	2.60	10	LTD	0.370	4	1
St. Anthony Bight																		
St. Anthony Bight	Cabbox Pond	Feb 04, 2026	4.90	180	60.0	13.00	6.07	33		0.55	LTD	LTD	3.20	11	LTD	0.270	7	2
St. Bernard's-Jacques Fontaine																		
St. Bernard's-Jacques Fontaine	Rattle Brook	Mar 10, 2026	2.00	39	53.0	9.00	6.21	29		0.28	LTD	LTD	2.10	12	LTD	0.250	6	2
St. Bride's																		
St. Bride's	North Side Brook	Mar 10, 2026	LTD	8	100.0	11.00	6.18	56		0.13	LTD	LTD	1.80	24	LTD	0.350	14	3
St. Bride's	South Side Brook	Mar 10, 2026	2.50	37	80.0	9.60	6.21	44		0.59	LTD	LTD	1.90	19	LTD	0.290	10	3
St. John's																		
St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Mar 05, 2026	23.00	LTD	100.0	27.00	7.44	57		0.18	LTD	LTD	9.70	16	LTD	0.220	8	2
St. John's	Windsor Lake	Mar 03, 2026	32.00	LTD	150.0	37.00	7.45	83		0.17	LTD	LTD	14.00	25	LTD	0.340	14	3
St. John's	Petty Harbour Long Pond	Mar 03, 2026	46.00	LTD	130.0	51.00	7.64	72		LTD	LTD	LTD	19.00	11	LTD	0.300	6	2
St. Judes																		

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
St. Judes																		
St. Judes	Uncle Arthur Brook	Mar 06, 2026	40.00	14	110.0	42.00	7.42	64		1.10	LTD	LTD	12.00	7	LTD	0.210	6	7
St. Judes	Uncle Arthur Brook	Mar 20, 2026	9.40	33	51.0	17.00	7.01	29		0.14	LTD	LTD	4.90	7	LTD	0.190	4	3
St. Judes	Chute Brook	Mar 06, 2026	28.00	10	76.0	28.00	7.39	42		0.10	LTD	LTD	8.00	6	LTD	0.190	4	3
St. Lawrence																		
St. Lawrence	St. Lawrence River	Mar 05, 2026	LTD	LTD	64.0	8.20	4.76	35		0.19	LTD	LTD	1.70	14	LTD	0.280	7	2
St. Lawrence - PWDU	St. Lawrence River	Mar 05, 2026	LTD	LTD	61.0	8.50	5.07	34		0.28	LTD	LTD	2.00	15	LTD	0.260	7	LTD
St. Lunaire-Griquet																		
St. Lunaire-Griquet	Joe's Pond	Feb 04, 2026	3.60	70	86.0	20.00	5.94	48		LTD	LTD	LTD	5.30	19	LTD	0.310	8	2
Gunners Cove	Lookout Brook	Feb 04, 2026	36.00	21	170.0	49.00	7.22	97		0.26	LTD	LTD	15.00	30	LTD	0.370	16	4
St. Lunaire-Griquet - PWDU	Joe's Pond	Feb 04, 2026	LTD	LTD	14.0	LTD	6.10	8		LTD	LTD	LTD	LTD	LTD	LTD	LTD	1	LTD
St. Pauls																		
St. Pauls	Two Mile Pond	Feb 06, 2026	45.00	27	220.0	66.00	7.41	120		0.73	LTD	LTD	21.00	37	LTD	0.790	17	4
St. Shott's																		
St. Shott's	Unnamed Pond	Feb 09, 2026	2.20	LTD	82.0	8.10	6.22	46		LTD	LTD	LTD	0.98	21	LTD	0.350	12	2
Steady Brook																		
Steady Brook	Wellfield + Steady Brook	Mar 06, 2026	27.00	16	170.0	50.00	7.45	97		0.13	LTD	LTD	18.00	22	LTD	0.650	11	20
Stephenville																		
Stephenville	Well Field	Mar 05, 2026	170.00	LTD	370.0	150.00	8.02	210		0.30	LTD	LTD	45.00	17	LTD	0.930	19	7
Stoneville																		
Stoneville	Dog Bay Pond Brook	Mar 04, 2026	6.40	26	53.0	11.00	6.59	30		0.37	LTD	LTD	2.90	9	LTD	0.190	7	1
Straitsview																		
Straitsview	Saddle Hill Pond	Feb 04, 2026	23.00	69	230.0	43.00	6.90	130		0.41	LTD	LTD	11.00	49	LTD	0.640	26	10
Summerford																		

Newfoundland Labrador

Water Resources Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Summerford																		
Summerford (+Cottlesville)	Rushy Cove Pond	Feb 17, 2026	42.00	25	170.0	58.00	7.20	95		0.19	LTD	LTD	20.00	27	LTD	0.440	12	5
Sunnyside (T.B.)																		
Sunnyside	Center Cove River	Jan 22, 2026	2.70	19	50.0	5.40	6.13	28		0.48	LTD	LTD	1.30	11	LTD	0.150	7	LTD
Terrenceville																		
Terrenceville	Big Brook	Mar 06, 2026	3.90	13	57.0	5.60	6.63	32		0.23	LTD	LTD	1.30	12	LTD	0.240	9	1
Thornlea																		
Thornlea	Big Bakeapple Pond	Feb 12, 2026	2.10	34	65.0	6.90	5.98	36		0.60	LTD	LTD	1.30	15	LTD	0.190	10	2
Tizzard's Harbour																		
Tizzard's Harbour	Rocky Pond	Feb 17, 2026	3.40	74	96.0	11.00	6.06	54		0.49	LTD	LTD	1.70	25	LTD	0.290	14	3
Torbay																		
Torbay	North Pond	Feb 16, 2026	8.10	LTD	88.0	8.80	6.94	49		0.77	LTD	LTD	1.90	18	LTD	0.410	15	4
Trepassey																		
Trepassey	Miller's Pond	Feb 09, 2026	6.60	LTD	81.0	8.70	6.53	45		0.22	LTD	LTD	1.50	19	LTD	0.260	12	2
Trinity																		
Trinity, T.B.	Indian Pond	Jan 21, 2026	LTD	29	39.0	2.90	5.84	22		0.28	LTD	LTD	0.38	9	LTD	0.150	6	LTD
Trinity Bay North																		
Little Catalina	Whirl Pond	Jan 21, 2026	6.20	46	62.0	4.10	6.58	34		0.66	LTD	LTD	0.74	12	LTD	0.130	11	1
Melrose	Whirl Pond	Jan 21, 2026	6.60	36	63.0	4.10	6.56	35		0.68	LTD	LTD	0.79	13	LTD	0.130	11	1
Port Union, Catalina (+Little Catalina)	Whirl Pond	Jan 21, 2026	3.80	34	59.0	4.10	6.24	33		0.66	LTD	LTD	0.71	13	LTD	0.130	10	1
Triton																		
Triton, Jim's Cove, Card's Harbour	Triton Pond	Feb 26, 2026	25.00	30	150.0	32.00	7.01	81		0.37	LTD	LTD	9.50	30	LTD	0.410	13	3
Trout River																		
Trout River	Feeder Brook	Jan 27, 2026	42.00	LTD	130.0	44.00	7.66	70		0.19	LTD	LTD	3.60	14	LTD	0.180	9	2
Twillingate																		

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Twillingate																		
Twillingate	Wild Cove Pond	Feb 17, 2026	LTD	34	140.0	20.00	5.56	79		0.23	LTD	LTD	4.30	37	LTD	0.540	18	5
Upper Amherst Cove																		
Upper Amherst Cove	Drilled	Jan 20, 2026	130.00	LTD	350.0	130.00	7.87	200		LTD	LTD	LTD	40.00	30	LTD	0.850	19	7
Upper Island Cove																		
Upper Island Cove	Kelly's Pond (Spider's Pond)	Jan 29, 2026	LTD	8	40.0	5.10	5.52	22		0.53	LTD	LTD	1.10	9	LTD	0.130	5	2
Victoria																		
Victoria (+Salmon Cove)	Rocky Pond	Jan 30, 2026	3.00	LTD	39.0	4.50	6.19	22		0.25	LTD	LTD	1.00	9	LTD	0.140	5	2
Victoria (+Salmon Cove)	Rocky Pond	Feb 27, 2026	2.30	LTD	40.0	4.70	6.44	23		0.28	LTD	LTD	1.00	9	LTD	0.150	6	2
Victoria (+Salmon Cove)	Rocky Pond	Feb 27, 2026	LTD	LTD	37.0	4.70	6.16	21		0.32	LTD	LTD	1.10	9	LTD	0.150	6	1
Victoria (+Salmon Cove)	Rocky Pond	Feb 27, 2026	2.40	LTD	40.0	4.60	6.33	22		0.26	LTD	LTD	1.00	9	LTD	0.160	5	2
West Bay																		
West Bay	Victor's Brook	Mar 09, 2026	66.00	41	220.0	83.00	7.74	120		1.40	LTD	LTD	25.00	25	0.110	0.430	12	6
Westport																		
Westport	Western Brook Pond	Feb 10, 2026	7.50	98	37.0	10.00	6.60	21		0.33	LTD	LTD	3.00	6	LTD	0.380	3	1
Whitbourne																		
Whitbourne	Hodges River	Jan 23, 2026	LTD	16	86.0	8.70	5.33	48		0.72	LTD	LTD	2.00	22	LTD	0.280	12	2
Whiteway																		
Whiteway (+Cavendish)	Long Pond	Jan 29, 2026	7.80	7	95.0	12.00	6.63	53		0.70	LTD	LTD	2.50	21	LTD	0.350	13	2
Whiteway - PWDU	Long Pond	Jan 29, 2026	4.10	LTD	59.0	5.10	6.50	33		LTD	LTD	LTD	0.96	15	LTD	0.230	9	LTD
Wild Cove																		
Wild Cove	Hedderson's Pond Brook	Feb 10, 2026	10.00	53	49.0	16.00	6.94	27		0.11	LTD	LTD	4.50	9	LTD	0.620	4	1
Winterton																		
Winterton	Western Pond	Feb 11, 2026	LTD	17	42.0	6.60	6.00	23		0.16	LTD	LTD	1.50	9	LTD	0.190	6	2

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
	Units		mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A
Wooddale																		
Wooddale	Northern Arm Lake	Jan 20, 2026	7.60	LTD	89.0	34.00	6.99	49		0.22	LTD	LTD	13.00	4	LTD	0.110	2	24
Woodstock																		
Woodstock	Mill Pond	Feb 11, 2026	LTD	**98**	39.0	6.20	**5.55**	22		0.44	LTD	LTD	1.20	9	LTD	0.170	5	1
Woody Point																		
Woody Point	Winterhouse Brook	Jan 27, 2026	47.00	LTD	150.0	57.00	7.63	83		LTD	LTD	LTD	4.50	18	LTD	0.250	11	3

Water Resources
Management Division

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador
Physical Parameters and Major Ions

Serviced Area(s)	Source Name	Sample Date	Alkalinity	Colour	Conductivity	Hardness	pH	TDS	TSS	Turbidity	Boron	Bromide	Calcium	Chloride	Fluoride	Potassium	Sodium	Sulphate
		Units	mg/L	TCU	µS/cm	mg/L		mg/L	mg/L	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
	Guidelines for Canadian Drinking Water Quality			15			6.5 - 8.5	500		1.0	5.0			250	1.5		200	500
	Aesthetic (A) or Contaminant (C) Parameter			A			A	A		C	C			A	C		A	A

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

Quality Assurance / Quality Control (QA/QC) - The department is striving to improve the quality of the data using standard QA/QC protocols. This is an evolving process which may result in minor changes to the reported data.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

The exceedance report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ.

Aesthetic (A) Parameters - Aesthetic parameters reflect substances or characteristics of drinking water that can affect its acceptance by consumers but which usually do not pose any health effects. Aesthetic exceedances are highlighted in **blue text** and underlined.

Contaminants (C) - Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant and Aesthetic Exceedances

Turbidity - The maximum acceptable concentration for turbidity is 1 NTU. Turbidity refers to the water's ability to transmit light or the cloudiness of the water. Turbidity in tap water can be the result of turbid raw water and influences within the distribution system. Turbidity is usually the result of fine organic and inorganic particles which do not settle out. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process.

Boron - The interim maximum acceptable concentration for boron in drinking water is 5.0 mg/L. Boron is widespread in the environment, occurring naturally in over 80 minerals and in the earth's crust. Levels in well water have been reported to be more variable and often higher than those in surface waters, most likely due to erosion from natural resources. High levels of this contaminant can cause adverse health effects for some people

Fluoride - The maximum acceptable concentration for fluoride in drinking water is 1.5mg/L.The fluoride concentration in natural water varies widely as it depends on such factors as the source of the water and the geological formations present. Trace amounts of fluoride may be essential for human nutrition and the presence of small quantities leads to a reduction of dental caries. High levels of this contaminant can cause adverse health effects for some people.

Colour - An aesthetic objective of 15 true colour units (TCU) has been established for colour in drinking water. Colour in drinking water may be due to the presence of coloured organic substances or metals such as iron, manganese and copper. Highly coloured industrial wastes also contribute to colour. The presence of colour is not directly linked to health but it can be aesthetically displeasing.

pH -The acceptable range for drinking water pH is 6.5 - 8.5. The control of pH is primarily based on minimizing corrosion and encrustration in the distribution system. Tap water with low pH may accelerate the corrosion process in the distribution system, and contribute to increased levels of copper, lead and possibly other metals. Incrustation and scaling problems may become more frequent above pH 8.5

TDS - The aesthetic objective for TDS in drinking water is 500 mg/L. The term "total dissolved solids"(TDS) refers mainly to the inorganic substances that are dissolved in water. At low levels TDS contributes to the palatability of water. At high levels it may cause excessive hardness, taste, mineral deposition and corrosion.

Chloride - The aesthetic objective for chloride in drinking water is 250 mg/L. Chloride can be in water from a variety of sources, including the dissolution of salt deposits and salting of roads for ice control. No evidence has been found suggesting that ingestion of chloride is harmful to humans. However, high levels of chloride in water can impart undesirable tastes to water and beverages prepared from water.

Sodium - The aesthetic objective for sodium in drinking water is 200 mg/L. Since the body has very effective means to control levels of sodium, sodium is not an acutely toxic element in the normal range of environmental or dietary concentrations. At extremely high dosages it has adverse health effects. Sodium levels may be of interest to authorities who wish to prescribe sodium restricted diets for their patients..

Sulphate - The aesthetic objective for sulphate in drinking water is 500 mg/L. Sulphates, which occur naturally in numerous minerals, are used in the mining and pulping industries and in wood preservation. Large quantities of sulphate can result in catharsis and gastrointestinal irritation. The presence of sulphate above the aesthetic limit can result in noticeable taste. Some sensitive individuals may find the taste objectionable at lower sulphate concentrations

mg/L = milligrams per litre or parts per million µS/cm = micro Siemens per centimeter NTU = nephelometric turbidity units TDS = total dissolved solids TSS = total suspended solids TCU = true colour units Nitrate(ite) = Nitrate + Nitrite DOC = dissolved organic carbon

Notes:
Guidelines for Canadian Drinking Water Quality have not been developed for all the parameters listed in this report.
pH has no units