

## AMENDMENT TO PERMIT

Pursuant to the *Water Resources Act*, SNL 2002 cW-4.01, specifically Section(s) 49

Date: **MAY 27, 2026**

File No: **843.124.6**

Permit No: **WS13753-2024**

Amendment No: **1**

Permit Holder: **Town of Carmanville  
PO Box 239  
Carmanville NL  
A0G 1N0**

Attention: **Ms. Dianne Goodyear**

Re: **Carmanville - Water and Sewer Services - Phase 4**

### The original Permit dated JUNE 12, 2024 is amended as follows:

to allow for the reduction in the scope of work for Phase 4 as shown on the drawings numbered MI no. 17-GI-24-00026, sheets C.1.00 to C.102 inclusive as submitted on May 14, 2026. The permit expiry date has been extended to June 12, 2027.


The following condition will apply:

Water mains must not pass within 15 metres of any part of a sewage disposal system. Water service lines must not pass within 7.5 metres of a sewage disposal system. In general the following conditions should be met in regards to water service lines:

- (a) There should be no joint in the service line between the building and the connection to the watermain.
- (b) The groundwater level should not be above the service line.
- (c) The service line should be located upslope of the sewage disposal system.

If the above conditions are not met, consideration should be given to increasing the distance between the service line and the sewage disposal system, providing extra protection against contamination.

**All other terms and conditions of the original Permit will apply and failure to comply with the terms and conditions of this amendment and the original Permit will render this Permit null and void, place the Permit Holder and their agent(s) in violation of the *Water Resources Act* and make the Permit Holder responsible for taking any remedial measures as may be prescribed by this Department.**



(for) MINISTER

- cc: Mr. Chris Blanchard, B.Tech.(Env), ASCT  
Environmental Scientist  
Water Resources Management Division  
Department of Environment, Conservation and Climate Change  
P.O. Box 2006  
Corner Brook, NL A2H 6J8  
cblancha@gov.nl.ca
- cc: Ms. Deneen Spracklin, P.Eng.  
Manager, Drinking Water and Wastewater Section  
Water Resources Management Division  
Department of Environment, Conservation and Climate Change  
P.O. Box 8700  
4th Floor, West Block, Confederation Building  
St. John's, NL A1B 4J6  
dspracklin@gov.nl.ca
- cc: Mr. Wayne Lynch (Central)  
Regional Director (Central)  
Government Services  
P.O. Box 2222  
Gander, NL A1V 2N9  
waynelynch@gov.nl.ca
- cc: Mr. Wilf Maloney, P. Eng.  
Regional Engineer, Central Regional Office  
Department of Transportation and Infrastructure  
PO Box 2222  
Gander, NL A1V 2N9  
WilfMaloney@gov.nl.ca