

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Anchor Point	Anchor Point	Well Cove Brook	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 161.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 101.7 ug/l (Please see HAA report for details).

Appleton	Appleton (+Glenwood)	Gander Lake (The Outflow)	Not Given	Not Ranked
----------	----------------------	---------------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 160.5 ug/l (Please see HAA report for details).

Aquaforte	Aquaforte	Davies Pond	Not Given	Not Ranked
-----------	-----------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 238.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 308.8 ug/l (Please see HAA report for details).

Arnold's Cove	Arnold's Cove	Steve's Pond (2 Intakes)	Not Given	Not Ranked
---------------	---------------	--------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 173.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 138.2 ug/l (Please see HAA report for details).

Avondale	Avondale	Lee's Pond	Not Given	Not Ranked
----------	----------	------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 258.75 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 178.3 ug/l (Please see HAA report for details).

Baie Verte	Baie Verte	Southern Arm Pond	Not Given	Not Ranked
------------	------------	-------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 115.48 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 163.9 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Baine Harbour	Baine Harbour	Baine Harbour Pond	Not Given	Not Ranked
---------------	---------------	--------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 5, 2018 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).

Bartletts Harbour	Bartletts Harbour	Long Pond (same as Castors River North)	Not Given	Not Ranked
-------------------	-------------------	---	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 29, 1998 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Bay L'Argent	Bay L'Argent	Sugarloaf Hill Pond	Not Given	Not Ranked
--------------	--------------	---------------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 2, 2008 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Bay Roberts	Bay Roberts, Spaniard's Bay	Rocky Pond	95	excellent
-------------	-----------------------------	------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE, PH (Please see Tap Water report for details).

Bay de Verde	Bay de Verde	Island Pond	92	very good
--------------	--------------	-------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR, PH (Please see Tap Water report for details).

Beaches	Beaches	Grassey Pond Brook	Not Given	Not Ranked
---------	---------	--------------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 7, 2016 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Beachside	Beachside	Long Pond	Not Given	Not Ranked
-----------	-----------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 164.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 103.1 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Bellburns	Bellburns	Bound Brook Tributary	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 158.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 80.3 ug/l (Please see HAA report for details).</p>				
Belleoram	Belleoram	Rabbits Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Bellevue	Bellevue	Big Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 140.15 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 81.4 ug/l (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 27, 2016 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Bellevue Beach	Bellevue Beach	Unnamed Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 18, 1997 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Benton	Benton	Little Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 30, 2020 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Birchy Bay	Birchy Bay	Jumper's Pond	Not Given	Not Ranked
------------	------------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 510 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 648.3 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 27, 2021 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).

Bird Cove	Bird Cove (+Brig Bay)	Inner Gilmour Pond	Not Given	Not Ranked
-----------	-----------------------	--------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 117.13 ug/l (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 2, 2011 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Biscay Bay	Biscay Bay	Unnamed Pond	Not Given	Not Ranked
------------	------------	--------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).

Bishop's Falls	Bishop's Falls	Northern Arm Lake	Not Given	Not Ranked
----------------	----------------	-------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Black Duck Cove	Black Duck Cove	Long Pond - Black Duck Cove Intake	Not Given	Not Ranked
-----------------	-----------------	------------------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 17, 1997 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).

Black Tickle-Domino	Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	Not Given	Not Ranked
---------------------	-----------------------------------	----------------------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 81.1 ug/l (Please see HAA report for details).

Black Tickle-Domino	Black Tickle-Domino - PWDU	Martin's Pond - Tap at Pumphouse	92	very good
---------------------	----------------------------	----------------------------------	----	-----------

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Bonavista	Bonavista	Long Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 282 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 168.4 ug/l (Please see HAA report for details).</p>				
Botwood	Botwood	Northern Arm Lake	95	excellent
Branch	Branch	Valley Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1989 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
Brent's Cove	Brent's Cove	Paddy's Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 20, 1991 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Brig Bay	Brig Bay	Inner Gilmour Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 145.38 ug/l (Please see THM report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 2, 2011 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Brighton	Brighton	Hynes Cove Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 295.5 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 325.7 ug/l (Please see HAA report for details).</p>				
Brigus	Brigus (+Cupids, +South River)	Brigus Long Pond (to Brigus)	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 207.2 ug/l (Please see HAA report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Buchans	Buchans	Buchans Lake aka Sandy Lake	Not Given	Not Ranked
---------	---------	-----------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Buchans	Buchans - PWDU	Buchans Lake aka Sandy Lake	Not Given	Not Ranked
---------	----------------	-----------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Buchans Junction	Buchans Junction	Lapland Pond	Not Given	Not Ranked
------------------	------------------	--------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 31, 2020 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).

Burgeo	Burgeo	Long Pond	Not Given	Not Ranked
--------	--------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 233.15 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 309.5 ug/l (Please see HAA report for details).

Burgoyne's Cove	Burgoyne's Cove	Lower Rocky Pond	100	excellent
-----------------	-----------------	------------------	-----	-----------

Burin	Burin	Long Pond	Not Given	Not Ranked
-------	-------	-----------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 105.4 ug/l (Please see HAA report for details).

Burin	Burin (+Lewin's Cove)	Big Pond	Not Given	Not Ranked
-------	-----------------------	----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 112.3 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 132.1 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Burin	Port au Bras	Gripe Cove Pond	Not Given	Not Ranked
-------	--------------	-----------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 86.2 ug/l (Please see HAA report for details).

Burlington	Burlington	Eastern Island Pond	Not Given	Not Ranked
------------	------------	---------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 357.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 420.4 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 22, 2018 for the following reason: Partial - From Nellie Matthews to end of line. - No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Burnt Islands	Burnt Islands	Long Lake	Not Given	Not Ranked
---------------	---------------	-----------	-----------	------------

CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: LEAD (Please see Tap Water report for details).

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 129.13 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 318.9 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 8, 2019 for the following reason: Inadequately treated water was introduced into the system due to fire flows, flushing operations, interconnections, minor power outage or other pressure loss. (Please contact your regional Medical Officer of Health for more information).

Burnt Islands	Burnt Islands - PWDU	Long Lake	94	very good
---------------	----------------------	-----------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR, PH (Please see Tap Water report for details).

Campbellton	Campbellton	Indian Arm Brook	Not Given	Not Ranked
-------------	-------------	------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 115.85 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 178.5 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Cape Freels North	Cape Freels North	Long Pond	Not Given	Not Ranked
-------------------	-------------------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 14, 2008 for the following reason: Partial - - Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Cape St. George	Cape St. George, Red Brook, De-Grau, Marches Point	Rouzes Brook	97	excellent
-----------------	--	--------------	----	-----------

Caplin Cove-Southport	Southport	Button Pond	Not Given	Not Ranked
-----------------------	-----------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 9, 2018 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).

Carbonear	Carbonear	Island Pond / Flings Long Pond	92	very good
-----------	-----------	--------------------------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Carmanville	Carmanville	Grandfathers Pond	Not Given	Not Ranked
-------------	-------------	-------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Cartwright	Cartwright	Burdett's Pond	Not Given	Not Ranked
------------	------------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 222.7 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 23, 2006 for the following reason: Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss. (Please contact your regional Medical Officer of Health for more information).

Cartwright	Cartwright - PWDU	Burdett's Pond	Not Given	Not Ranked
------------	-------------------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 116.6 ug/l (Please see THM report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Castor River North	Castor River North	Long Pond (same as Bartletts Harbour)	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1991 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Castor River South	Castor River South	Unnamed	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1991 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
Cavendish	Cavendish	Long Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 110.4 ug/l (Please see THM report for details).</p>				
Centreville-Wareham-Trinity	Centreville-Wareham	Northwest Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 3, 2021 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).</p>				
Centreville-Wareham-Trinity	Trinity	Southwest Feeder Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 3, 2021 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).</p>				
Chanceport	Chanceport	Bridger's Cove Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 11, 1989 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Channel-Port aux Basques	Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Not Given	Not Ranked

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Not Given	Not Ranked
<p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 284.6 ug/l (Please see HAA report for details).</p>				
Charlottetown (Labrador)	Charlottetown (Labrador) - PWDU	Middle Pond	97	excellent
<p style="color: gray;">AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Churchill Falls	Churchill Falls	Smallwood Reservoir	Not Given	Not Ranked
<p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 92.2 ug/l (Please see HAA report for details).</p>				
Clareville	Clareville, Shoal Harbour	Shoal Harbour River	100	excellent
Clarke's Beach	Clarkes Beach	Clarkes Pond	95	excellent
<p style="color: gray;">AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Come By Chance	Come By Chance	Butchers Brook	100	excellent
Comfort Cove-Newstead	Comfort Cove-Newstead	Steady Cove Pond	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 148.1 ug/l (Please see THM report for details).</p>				
<p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 162 ug/l (Please see HAA report for details).</p>				
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	100	excellent
Conche	Conche	Martin's Brook	Not Given	Not Ranked
<p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 18, 2001 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Conne River	Conne River	Southwest Brook	97	excellent
Cook's Harbour	Cook's Harbour	Unnamed Pond	92	very good

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	100	excellent
Cottlesville	Cottlesville	Rushy Cove Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 285.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 247.3 ug/l (Please see HAA report for details).</p>				
Cottrell's Cove	Cottrell's Cove	Cottrell's Pond	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: MANGANESE (Please see Tap Water report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 14, 2019 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Cow Head	Cow Head	Short Cat Path Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 167.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 189.1 ug/l (Please see HAA report for details).</p>				
Cow Head	Cow Head - PWDU	Short Cat Path Pond	97	excellent
Cox's Cove	Cox's Cove	Cox's Brook	96	excellent
Crow Head	Crow Head	Oars Pond	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 90.9 ug/l (Please see HAA report for details).</p>				
Cupids	Cupids	Brigus Long Pond (to Brigus)	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 123.68 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 230.3 ug/l (Please see HAA report for details).</p>				
Daniel's Harbour	Daniel's Harbour	Unnamed Spring & Brook	97	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Deadman's Bay	Deadman's Bay	Deadman's Pond	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Deep Bight	Deep Bight	Deep Bight River	Not Given	Not Ranked
------------	------------	------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 112.55 ug/l (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 4, 2018 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Deer Lake	Deer Lake (+Reidville)	Humber Canal, Grand Lake	97	excellent
-----------	------------------------	--------------------------	----	-----------

Dildo	Dildo, Broad Cove (+South Dildo)	Broad Cove Pond	Not Given	Not Ranked
-------	----------------------------------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 100.15 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 246.6 ug/l (Please see HAA report for details).

Dover	Dover	Hare Bay Pond	Not Given	Not Ranked
-------	-------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 172.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 163.1 ug/l (Please see HAA report for details).

Eddies Cove West	Eddies Cove West	Unnamed	Not Given	Not Ranked
------------------	------------------	---------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 10, 2003 for the following reason: Partial - Existing Boil Advisory since before 1991. Letter issued by Brian Moores. - Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).

Elliston	Elliston	Big Pond	95	excellent
----------	----------	----------	----	-----------

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Embree	Embree (+Little Burnt Bay)	Troke's Cove Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 128.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 133 ug/l (Please see HAA report for details).</p>				
Englee	Englee	Island Cove Pond	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: MANGANESE (Please see Tap Water report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 127.3 ug/l (Please see HAA report for details).</p>				
Fairbanks-Hillgrade	Fairbanks-Hillgrade	Saltine's Pond	96	excellent
Fermeuse	Fermeuse, Kingman's	Merrymeeting Pond, Bear Cove Pond (2 intakes)	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 193.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 258.4 ug/l (Please see HAA report for details).</p>				
Ferryland	Ferryland	Deep Cove Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 368.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 443.2 ug/l (Please see HAA report for details).</p>				
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 195.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 178 ug/l (Please see HAA report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Flower's Cove	Flower's Cove (+Nameless Cove)	French Island Pond	Not Given	Not Ranked
---------------	--------------------------------	--------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 212.5 ug/l (Please see THM report for details).

Fogo Island	Fogo	Freeman's Pond	Not Given	Not Ranked
-------------	------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 141.35 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 474.9 ug/l (Please see HAA report for details).

Fogo Island	Joe Batt's Arm-Barr'd Islands-Shoal Bay	Long Pond	Not Given	Not Ranked
-------------	---	-----------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 295.9 ug/l (Please see HAA report for details).

Fogo Island	Seldom-Little Seldom	Bullock Cove Pond	Not Given	Not Ranked
-------------	----------------------	-------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 279.95 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 192.2 ug/l (Please see HAA report for details).

Fogo Island	Tilting	Sandy Cove Pond	Not Given	Not Ranked
-------------	---------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 196.85 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 195.2 ug/l (Please see HAA report for details).

Forresters Point	Forresters Point	Rudges Pond	Not Given	Not Ranked
------------------	------------------	-------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 28, 2020 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Forteau	Forteau	Trout Brook	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 106.63 ug/l (Please see THM report for details).</p> <p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 105.8 ug/l (Please see HAA report for details).</p> <p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 1, 2020 for the following reason: Inadequately treated water was introduced into the system due to fire flows, flushing operations, interconnections, minor power outage or other pressure loss. (Please contact your regional Medical Officer of Health for more information).</p>				
Fortune	Fortune (+Grand Bank)	Horsebrook	Not Given	Not Ranked
<p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 81.9 ug/l (Please see HAA report for details).</p>				
Fox Roost-Margaree	Fox Roost-Margaree - PWDU	Drilled Well and Margaree Pond	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Francois	Francois	Our Pond	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 9, 1997 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
Gallants	Gallants	Gallant's Brook	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 1, 1997 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
Gambo	Gambo	Dark Cove Pond	92	very good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Gander	Gander	Gander Lake	97	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Gander Bay South	Gander Bay South - PWDU	Barry's Brook	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Gander Bay South	George's Point, Harris Point	Barry's Brook	Not Given	Not Ranked
------------------	------------------------------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Garden Cove	Garden Cove	Arch Cove Pond	Not Given	Not Ranked
-------------	-------------	----------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 92.1 ug/l (Please see HAA report for details).

Garnish	Garnish	Witchazel Pond	Not Given	Not Ranked
---------	---------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 187.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 318 ug/l (Please see HAA report for details).

Gaskiers	Gaskiers-Point La Haye	Big Hare Hill Pond	Not Given	Not Ranked
----------	------------------------	--------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 251.48 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 291.6 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 8, 2012 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Gaultois	Gaultois	Piccaire Pond	Not Given	Not Ranked
----------	----------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 16, 2001 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Gaultois	Gaultois - PWDU	Piccaire Pond	94	very good
----------	-----------------	---------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

George's Brook-Milton	George's Brook-Milton	George's Brook	Not Given	Not Ranked
-----------------------	-----------------------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 227 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 191.4 ug/l (Please see HAA report for details).

Georgetown	Georgetown	Third Pond	97	excellent
------------	------------	------------	----	-----------

Gillams	Gillams	Meaters Pond	95	excellent
---------	---------	--------------	----	-----------

Glenburnie-Birchy Head-Shoal Brook	Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	Not Given	Not Ranked
------------------------------------	------------------------------------	------------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 3, 2012 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Glenwood	Glenwood	Gander Lake (The Outflow)	Not Given	Not Ranked
----------	----------	---------------------------	-----------	------------

CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: LEAD (Please see Tap Water report for details).

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 105.93 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 181.3 ug/l (Please see HAA report for details).

Glovertown	Glovertown	Northwest Pond	Not Given	Not Ranked
------------	------------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 114.23 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 128.5 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Goobies	Goobies	Water Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 5, 2014 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).</p>				
Goose Cove East	Goose Cove East	Jack's Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 130.3 ug/l (Please see THM report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 31, 1999 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Grand Bank	Grand Bank	Horsebrook	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 172.4 ug/l (Please see HAA report for details).</p>				
Grand Falls-Windsor	Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	92	very good
Grand Le Pierre	Grand Le Pierre	Nip Nose Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 10, 1997 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Grates Cove	Grates Cove Centre	#1C Well	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: ARSENIC (Please see Tap Water report for details).</p>				
Great Brehat	Great Brehat	Little Steady Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 17, 1997 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Green Island Brook	Green Island Brook	Green Island Brook	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 124.3 ug/l (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 3, 2020 for the following reason: Escherichia coli (E. coli) detected AND repeat samples can not be taken as required. (Please contact your regional Medical Officer of Health for more information).

Greenspond	Greenspond	Shambler's Cove Pond	Not Given	Not Ranked
------------	------------	----------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 19, 2019 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).

Hampden	Hampden	Elliot Brook	Not Given	Not Ranked
---------	---------	--------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 142.55 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 131.4 ug/l (Please see HAA report for details).

Hant's Harbour	Hant's Harbour	Eastern Pond (Halfway Brook)	92	very good
----------------	----------------	------------------------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Happy Adventure	Happy Adventure	Goose Neck Pond	Not Given	Not Ranked
-----------------	-----------------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 104.83 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 300.5 ug/l (Please see HAA report for details).

Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	Not Given	Not Ranked
------------------------	------------------------	--------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 3, 2021 for the following reason: Partial - Boil Water Advisory_

_Palliser Crescent - Inadequately treated water was introduced into the system due to fire flows, flushing operations, interconnections, minor power outage or other pressure loss. (Please contact your regional Medical Officer of Health for more information).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	95	excellent
Harbour Breton	Harbour Breton	Connaigra Pond, Hutchings Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 139.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 135.7 ug/l (Please see HAA report for details).</p>				
Harbour Grace	Harbour Grace, Harbour Grace South (+Riverhead)	Bannerman Lake	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Maloney's River	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 101.5 ug/l (Please see HAA report for details).</p>				
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Head Pond	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: LEAD, TURBIDITY (Please see Tap Water report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 20, 2003 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 121.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 129.4 ug/l (Please see HAA report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Hawke's Bay	Hawke's Bay	Torrent River	Not Given	Not Ranked
-------------	-------------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 182.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 251.4 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 20, 2020 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).

Heart's Content	Heart's Content	Southern Cove Pond	Not Given	Not Ranked
-----------------	-----------------	--------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 80.7 ug/l (Please see HAA report for details).

Heart's Delight-Islington	Heart's Delight-Islington	Long Pond	Not Given	Not Ranked
---------------------------	---------------------------	-----------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 98.9 ug/l (Please see HAA report for details).

Heart's Desire	Heart's Desire	Terrence Pond	97	excellent
----------------	----------------	---------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Hermitage	Hermitage-Sandyville	Granfer's Pond	Not Given	Not Ranked
-----------	----------------------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 204.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 19, 2012 for the following reason: Partial - 2 Harbor View Road site only - No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Hermitage	Hermitage-Sandyville - PWDU	Granfer's Pond	97	excellent
-----------	-----------------------------	----------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Herring Neck	Herring Neck, Hatchet Harbour, Salt Harbour, Shoal Cove, Sunnyside	Gut Pond	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 164.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 105.4 ug/l (Please see HAA report for details).

Hickman's Harbour-Robinson Bight	Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	100	excellent
----------------------------------	----------------------------------	---------------------	-----	-----------

Hopedale	Hopedale	American Pond	Not Given	Not Ranked
----------	----------	---------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 91.6 ug/l (Please see HAA report for details).

Howley	Howley	Sandy Lake	Not Given	Not Ranked
--------	--------	------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 143 ug/l (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 19, 2016 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Howley	Howley - PWDU	Sandy Lake	Not Given	Not Ranked
--------	---------------	------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Hughes Brook	Hughes Brook	Reservoir	97	excellent
--------------	--------------	-----------	----	-----------

Humber Arm South	Frenchman's Cove Area	Gurges Pond	100	excellent
------------------	-----------------------	-------------	-----	-----------

Humber Arm South	Halfway Point, Benoit's Cove, John's Beach	Dormody's Brook	97	excellent
------------------	--	-----------------	----	-----------

Indian Bay	Indian Bay	Indian Bay Brook	Not Given	Not Ranked
------------	------------	------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Irishtown-Summerside	Irishtown	Irishtown Brook	Not Given	Not Ranked
----------------------	-----------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 114.05 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 95.1 ug/l (Please see HAA report for details).

Irishtown-Summerside	Summerside	Pynn's Pond	Not Given	Not Ranked
----------------------	------------	-------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 184.5 ug/l (Please see HAA report for details).

Isle aux Morts	Isle aux Morts	Burnt Ground Pond	Not Given	Not Ranked
----------------	----------------	-------------------	-----------	------------

CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: LEAD, COPPER (Please see Tap Water report for details).

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 235.75 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 288.6 ug/l (Please see HAA report for details).

Isle aux Morts	Isle aux Morts - PWDU	Burnt Ground Pond	Not Given	Not Ranked
----------------	-----------------------	-------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Jackson's Arm	Jackson's Arm	Unnamed Brook	Not Given	Not Ranked
---------------	---------------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 160.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 270.5 ug/l (Please see HAA report for details).

Jackson's Arm	Jackson's Arm - PWDU	Unnamed Brook	96	excellent
---------------	----------------------	---------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Jackson's Cove-Langdon's Cove-Silverdale	Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 30, 2014 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).</p>				
Keels	Keels	Boland's Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 420.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 595.5 ug/l (Please see HAA report for details).</p>				
King's Point	King's Point	Bulley's Pond	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 137.4 ug/l (Please see HAA report for details).</p>				
L'Anse au Clair	L'Anse au Clair	Park Pond	100	excellent
L'Anse au Loup	L'Anse au Loup	L'anse Au Loup River	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 4, 2020 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).</p>				
LaScie	La Scie	Stakes Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 20, 1991 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
Labrador City	Labrador City	Beverly Lake	97	excellent
Lamaline	Lamaline	Upper Hodges Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 284.98 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 377.3 ug/l (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 20, 2015 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Lamaline	Lamaline - PWDU	Upper Hodges Pond	97	excellent
----------	-----------------	-------------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Lawn	Lawn	Brazil Pond	Not Given	Not Ranked
------	------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 13, 2019 for the following reason: Escherichia coli (E. coli) detected AND repeat samples can not be taken as required. (Please contact your regional Medical Officer of Health for more information).

Lawn	Lawn - PWDU	Brazil Pond	Not Given	Not Ranked
------	-------------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Leading Ticks	Leading Ticks	Cook's Pond	Not Given	Not Ranked
---------------	---------------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 122.15 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 151.9 ug/l (Please see HAA report for details).

Leading Ticks	Leading Ticks - PWDU	Cook's Pond	97	excellent
---------------	----------------------	-------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Lewin's Cove	Lewin's Cove	Big Pond	Not Given	Not Ranked
--------------	--------------	----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 126.53 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 138.4 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Lewisporte	Lewisporte	Stanhope Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 150.5 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 111.6 ug/l (Please see HAA report for details).</p>				
Little Bay	Little Bay	First Pond	100	excellent
Little Bay	Little Bay	Mine Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Little Burnt Bay	Little Burnt Bay	Troke's Cove Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 158.5 ug/l (Please see THM report for details).</p>				
Little Harbour East	Little Harbour East (Placentia Bay)	Unnamed Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1996 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Little St. Lawrence	Little St. Lawrence	Butler's Brook (2 Intakes)	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 23, 1999 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).</p>				
Long Harbour-Mount Arlington Heights	Long Harbour-Mount Arlington Heights	Shingle Pond and/or Trout Pond (2 Intakes)	100	excellent
Loon Bay	Loon Bay	Southeast Pond	97	excellent
Lourdes	Lourdes (+West Bay)	Victor's Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 241.05 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 189.8 ug/l (Please see HAA report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Lower Lance Cove	Lower Lance Cove	Big Long Pond	Not Given	Not Ranked
------------------	------------------	---------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 2, 2010 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Lumsden	Lumsden	Gull Pond	Not Given	Not Ranked
---------	---------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Lushes Bight-Beaumont-Beaumont North	Lushes Bight, Beaumont	Milkboy's Pond/Gull Pond	Not Given	Not Ranked
--------------------------------------	------------------------	--------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 16, 2015 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Lushes Bight-Beaumont-Beaumont North	Lushes Bight, Beaumont - PWDU	Milkboy's Pond/Gull Pond	Not Given	Not Ranked
--------------------------------------	-------------------------------	--------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

Main Brook	Main Brook	Joe Burt's Pond	Not Given	Not Ranked
------------	------------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 28, 2019 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Mainland	Mainland	Caribou Brook	Not Given	Not Ranked
----------	----------	---------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 29, 2019 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Makkovik	Makkovik	Ranger Bight Pond	90	very good
----------	----------	-------------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR (Please see Tap Water report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Makkovik	Makkovik - PWDU	Ranger Bight Pond	95	excellent
AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).				
Mary's Harbour	Mary's Harbour	St. Mary's River	Not Given	Not Ranked
THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 285.55 ug/l (Please see THM report for details).				
HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 212.8 ug/l (Please see HAA report for details).				
Mary's Harbour	Mary's Harbour - PWDU	St. Mary's River	Not Given	Not Ranked
THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 128.85 ug/l (Please see THM report for details).				
HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 112.5 ug/l (Please see HAA report for details).				
Marystown	Marystown	Fox Hill Reservoir / Clam Pond	100	excellent
Massey Drive	Massey Drive	Trout Pond, Third Pond (2 intakes)	100	excellent
Mclvers	Mclvers	Mclvers Brook	Not Given	Not Ranked
THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 128.43 ug/l (Please see THM report for details).				
HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 80.9 ug/l (Please see HAA report for details).				
Meadows	Meadows, Summerside West	Meaters Pond	Not Given	Not Ranked
HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 85.7 ug/l (Please see HAA report for details).				
Merritt's Harbour	Merritt's Harbour	Jimmy's Pond	Not Given	Not Ranked
THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 192 ug/l (Please see THM report for details).				
HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 146.5 ug/l (Please see HAA report for details).				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Middle Arm	Middle Arm	Dam Pond Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 15, 2008 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).</p>				
Miles Cove	Miles Cove	Paddock's Pond	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Millertown	Millertown	Water Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 14, 2017 for the following reason: Partial - Partial Boil Water Advisory from the post office to end of line and 29 Beothuk Drive to end of line for the public water supply of Millertown, Water Pond. - No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Milltown-Head of Bay D'Espoir	Milltown, Head of Bay D'Espoir	Jersey Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Ming's Bight	Ming's Bight	Middle Brook Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 23, 2020 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Morrisville	Morrisville	Morrisville Pond	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 21, 2006 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Mount Moriah	Mount Moriah	Trout Pond, Third Pond (2 intakes)	100	excellent
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	100	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Musgrave Harbour	Musgrave Harbour	Rocky Pond	Not Given	Not Ranked
<p style="color: red; margin: 0;">THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p style="color: red; margin: 0;">HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Nain	Nain	Trouser Lake	Not Given	Not Ranked
<p style="color: red; margin: 0;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 24, 2021 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Nameless Cove	Nameless Cove / Flower Cove	French Island Pond	Not Given	Not Ranked
<p style="color: red; margin: 0;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 180.75 ug/l (Please see THM report for details).</p> <p style="color: red; margin: 0;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 108 ug/l (Please see HAA report for details).</p>				
Natuashish	Natuashish (Sango Bay)	Sango Brook and Wellfield	Not Given	Not Ranked
<p style="color: red; margin: 0;">CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: FLUORIDE (Please see Tap Water report for details).</p> <p style="color: red; margin: 0;">THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p style="color: red; margin: 0;">HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p style="color: red; margin: 0;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 28, 2020 for the following reason: Inadequately treated water was introduced into the system due to fire flows, flushing operations, interconnections, minor power outage or other pressure loss. (Please contact your regional Medical Officer of Health for more information).</p>				
New Chelsea-New Melbourne-Brownsdale-Sibley's Cove-Lead Cove	Sibley's Cove, Lead Cove	Sibley's Cove Pond	95	excellent
<p style="color: red; margin: 0;">AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
New Perlican	New Perlican	New Perlican River	Not Given	Not Ranked
<p style="color: red; margin: 0;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 3, 2021 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
New-Wes-Valley	Newtown-Templeton	Carter's Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
New-Wes-Valley	Wesleyville-Badger's Quay-Pool's Island, Brookfield-Poundcove	Little Northwest Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Newman's Cove	Newman's Cove	Heale Pond Brook	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: MANGANESE, TURBIDITY (Please see Tap Water report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 26, 2008 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Nippers Harbour	Nippers Harbour	Blackhead Pond Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 25, 1996 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Norman's Cove-Long Cove	Norman's Cove-Long Cove	John Newhooks Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 147.4 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 135.5 ug/l (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 28, 2018 for the following reason: Partial - The portion of Hilltop Lane from the Post Office on Route 201 to the residence of Scott & Christine Smith - Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Norris Arm	Norris Arm (south)	Mill Lake	Not Given	Not Ranked
------------	--------------------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 127.13 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 149.4 ug/l (Please see HAA report for details).

Norris Point	Norris Point	Neddy Harbour Pond	100	excellent
--------------	--------------	--------------------	-----	-----------

North Harbour	North Harbour	Grandfather's Pond	Not Given	Not Ranked
---------------	---------------	--------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 81.6 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1996 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

North West River	North West River	Wellfield (#1 & #3 Well) + #2 Well	100	excellent
------------------	------------------	------------------------------------	-----	-----------

Northern Arm	Northern Arm	Northern Arm Lake	97	excellent
--------------	--------------	-------------------	----	-----------

Old Perlican	Old Perlican	Bell Pond	Not Given	Not Ranked
--------------	--------------	-----------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 102.6 ug/l (Please see HAA report for details).

Pacquet	Pacquet	Big Brook	Not Given	Not Ranked
---------	---------	-----------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 25, 2020 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Pacquet	Pacquet - PWDU	Big Brook	94	very good
---------	----------------	-----------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Paradise	Paradise	Bay Bulls Big Pond	100	excellent
----------	----------	--------------------	-----	-----------

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Parkers Cove	Parkers Cove	Unnamed brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 263.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 212.9 ug/l (Please see HAA report for details).</p>				
Parson's Pond	Parson's Pond	Cold Brook	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 5, 2019 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).</p>				
Pasadena	Pasadena	Blue Gulch Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 158.25 ug/l (Please see THM report for details).</p>				
Peterview	Peterview	Northern Arm Lake	100	excellent
Petit Forte	Petit Forte	Reddy's Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1996 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).</p>				
Petty Harbour-Maddox Cove	Petty Harbour-Maddox Cove	Western Barrens Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 127.8 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 115.4 ug/l (Please see HAA report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Phillips Head	Phillips Head	Dogberry Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 172.95 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 150.3 ug/l (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 29, 2020 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).</p>				
Piccadilly Head	Piccadilly Head (+West Bay)	Unnamed Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 28, 2010 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).</p>				
Piccadilly Slant-Abraham's Cove	Abraham's Cove	#2 Well - Abraham's Cove	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 28, 2010 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).</p>				
Pidgeon Cove-St. Barbe	Pigeon Cove - St. Barbe	Long Pond	94	very good
Pilley's Island	Pilley's Island	Loadabats Pond	95	excellent
Placentia	Dunville	Wyses Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 139.83 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 317.7 ug/l (Please see HAA report for details).</p>				
Placentia	Freshwater, Argentia site	Clarkes Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 141.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 186.6 ug/l (Please see HAA report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Placentia	Placentia, Jersey side, SE Placentia	Larkins Pond	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 155.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 192 ug/l (Please see HAA report for details).

Pleasantview	Pleasantview	Little Arm Pond	Not Given	Not Ranked
--------------	--------------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 331.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 253.6 ug/l (Please see HAA report for details).

Plum Point	Plum Point	Grand Pond	Not Given	Not Ranked
------------	------------	------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 106.88 ug/l (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 17, 1997 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Point Lance	Point Lance	Unnamed Pond	Not Given	Not Ranked
-------------	-------------	--------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1989 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).

Point Leamington	Point Leamington	Little Pond	Not Given	Not Ranked
------------------	------------------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 135.78 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 184.1 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Point May	Point May	Short's Pond	Not Given	Not Ranked
-----------	-----------	--------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 573.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 720.5 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 25, 2021 for the following reason: None Listed (Please contact your regional Medical Officer of Health for more information).

Point May	Point May - PWDU	Short's Pond	Not Given	Not Ranked
-----------	------------------	--------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 354.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 86.6 ug/l (Please see HAA report for details).

Point of Bay	Point of Bay	Indian Cove Pond	Not Given	Not Ranked
--------------	--------------	------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 154.33 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 165.8 ug/l (Please see HAA report for details).

Pollards Point	Pollards Point East	George Ricks Pond	Not Given	Not Ranked
----------------	---------------------	-------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1987 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).

Pollards Point	Pollards Point, Country Cove	Country Cove Pond	Not Given	Not Ranked
----------------	------------------------------	-------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 17, 2015 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Pool's Cove	Pool's Cove	Widgeon Pond	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 137.18 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 143.7 ug/l (Please see HAA report for details).

Port Albert	Port Albert	Beaverton Pond	91	very good
AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR, MANGANESE (Please see Tap Water report for details).				

Port Anson	Port Anson	Anchor Pond	Not Given	Not Ranked
------------	------------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 253 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 304.5 ug/l (Please see HAA report for details).

Port Blandford	Port Blandford	Noseworthy's Pond	Not Given	Not Ranked
THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 155.65 ug/l (Please see THM report for details).				
HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 94 ug/l (Please see HAA report for details).				
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 15, 2021 for the following reason: Partial - Branch Line to Terra Nova Golf resort - Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).				

Port Hope Simpson	Port Hope Simpson	Arnold's Brook and Pond	Not Given	Not Ranked
-------------------	-------------------	-------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 399.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 273.3 ug/l (Please see HAA report for details).

Port Saunders	Port Saunders	Tom Taylor's Pond	Not Given	Not Ranked
THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 165.9 ug/l (Please see THM report for details).				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Port Saunders	Port Saunders - PWDU	Tom Taylor's Pond	100	excellent
Port au Choix	Port au Choix	Winterhouse Pond	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 145.5 ug/l (Please see THM report for details).</p> <p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 113.1 ug/l (Please see HAA report for details).</p>				
Port au Choix	Port au Choix - PWDU	Winterhouse Pond	97	excellent
Portland Creek	Portland Creek	Unnamed Streams	100	excellent
Portugal Cove South	Portugal Cove South	Wrights Brook	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 139.53 ug/l (Please see THM report for details).</p> <p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 30, 2019 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	100	excellent
Postville	Postville	Big Pond	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 275.75 ug/l (Please see THM report for details).</p> <p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 332.5 ug/l (Please see HAA report for details).</p>				
Postville	Postville - PWDU	Big Pond	97	excellent
<p style="color: red;">AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Pouch Cove	Pouch Cove	North Three Island Pond	90	very good

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Purcell's Harbour	Purcell's Harbour	Purcell's Harbour Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 163.43 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 106.5 ug/l (Please see HAA report for details).</p>				
Pynn's Brook	Pynn's Brook	Pynn's Brook	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 10, 2016 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Ramea	Ramea	Northwest Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 240.68 ug/l (Please see THM report for details).</p>				
Ramea	Ramea - PWDU	Northwest Pond	92	very good
Random Sound West	Queen's Cove	Reservoir	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 252.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 305.8 ug/l (Please see HAA report for details).</p>				
Rattling Brook	Rattling Brook	Mark's Pond Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 270.68 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 349.9 ug/l (Please see HAA report for details).</p>				
Red Bay	Red Bay	Northern Brook	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 1, 1994 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Reidville	Reidville	Humber Canal, Grand Lake	Not Given	Not Ranked
-----------	-----------	--------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 133.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 125.8 ug/l (Please see HAA report for details).

Rigolet	Rigolet	Rigolet Pond	Not Given	Not Ranked
---------	---------	--------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 8, 2018 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Rigolet	Rigolet - PWDU	Rigolet Pond	Not Given	Not Ranked
---------	----------------	--------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

River of Ponds	River of Ponds	Burnt Head Ponds	Not Given	Not Ranked
----------------	----------------	------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 108.53 ug/l (Please see THM report for details).

Robert's Arm	Robert's Arm	Young's Pond / Dam Pond	Not Given	Not Ranked
--------------	--------------	-------------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 107.9 ug/l (Please see HAA report for details).

Rocky Harbour	Rocky Harbour	Gull Pond	Not Given	Not Ranked
---------------	---------------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 222 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 153.3 ug/l (Please see HAA report for details).

Roddickton-Bide Arm	Bide Arm	First Clay Cove Pond	Not Given	Not Ranked
---------------------	----------	----------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 111.33 ug/l (Please see THM report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Roddickton-Bide Arm	Roddickton	East Brook Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 136 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 109.3 ug/l (Please see HAA report for details).</p>				
Rose Blanche-Harbour Le Cou	Rose Blanche-Harbour Le Cou	Rose Blanche Brook	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 18, 2020 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).</p>				
Rushoon	Rushoon	Big Pond Brook	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 14, 2015 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Salmon Cove	Salmon Cove	Rocky Pond	95	excellent
Salvage	Salvage	Wild Cove Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 309.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 408.1 ug/l (Please see HAA report for details).</p>				
Seal Cove (FB)	Seal Cove, F.B.	Big Black Duck Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 17, 2005 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
Seal Cove (FB)	Seal Cove, F.B. - PWDU	Big Black Duck Pond	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Seal Cove (WB)	Seal Cove, W.B.	Seal Cove Brook & Long Pond	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 20, 2015 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Sheaves Cove	Sheaves Cove	Unnamed Brook	Not Given	Not Ranked
--------------	--------------	---------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 8, 2008 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Sheshatshiu	Sheshatshiu - Indian Band Council	Wells 1, 2 & 3	94	very good
-------------	-----------------------------------	----------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).

Shoe Cove	Shoe Cove	Second Pond	Not Given	Not Ranked
-----------	-----------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 25, 2005 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).

Small Point-Adam's Cove-Blackhead-Broad Cove	Adam's Cove	#1 Well - Reg Burse Well	94	very good
--	-------------	--------------------------	----	-----------

Small Point-Adam's Cove-Blackhead-Broad Cove	Blackhead + Adam's Cove	#4 Well - Leonard King Well	100	excellent
--	-------------------------	-----------------------------	-----	-----------

Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#7 Well - Gin Badcock Well	100	excellent
--	------------	----------------------------	-----	-----------

Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#6 Well - Herb Trickett Well	100	excellent
--	------------	------------------------------	-----	-----------

Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#8 Well - Effie Flight Wells	100	excellent
--	-------------	------------------------------	-----	-----------

Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#9 Well - Walter Reynolds Well	100	excellent
--	-------------	--------------------------------	-----	-----------

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Smith's Harbour	Smith's Harbour	Fleshetts Brook	Not Given	Not Ranked
-----------------	-----------------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 10, 2019 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).

Sop's Arm	Sop's Arm	Little Tickle Pond	Not Given	Not Ranked
-----------	-----------	--------------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1990 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

South Brook	South Brook	Next to Brook	100	excellent
-------------	-------------	---------------	-----	-----------

South Dildo	South Dildo	Broad Cove Pond	Not Given	Not Ranked
-------------	-------------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 107.28 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 144.8 ug/l (Please see HAA report for details).

South River	South River	Brigus Long Pond (to Brigus)	Not Given	Not Ranked
-------------	-------------	------------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 106.8 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 259.5 ug/l (Please see HAA report for details).

Southern Harbour	Southern Harbour	Brigades Pond	Not Given	Not Ranked
------------------	------------------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 27, 2018 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Spaniard's Bay	Spaniard's Bay (+Upper Island Cove, + Bryant's Cove)	Kelly's Pond (Spider's Pond)	Not Given	Not Ranked
----------------	--	------------------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 120.1 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Springdale	Springdale	Sullivan's Pond (2 Intakes)	Not Given	Not Ranked
<p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 84.9 ug/l (Please see HAA report for details).</p>				
St. Anthony	St. Anthony	St. Anthony Pond	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 124.43 ug/l (Please see THM report for details).</p> <p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 145.8 ug/l (Please see HAA report for details).</p> <p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 30, 2020 for the following reason: Partial - St.Anthony_ West Street beginning at Ragna Rock Brewery to Fishing Point (including all side streets, but excluding Tucker's Lane and Starigan Hill. - Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).</p>				
St. Anthony Bight	St. Anthony Bight	Cabbox Pond	Not Given	Not Ranked
<p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 22, 1997 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
St. Bernard's-Jacques Fontaine	St. Bernard's-Jacques Fontaine	Rattle Brook	Not Given	Not Ranked
<p style="color: red;">THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 175 ug/l (Please see THM report for details).</p> <p style="color: red;">HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 173.3 ug/l (Please see HAA report for details).</p> <p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 5, 2020 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
St. Bride's	St. Bride's	South Side Brook	Not Given	Not Ranked
<p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1989 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact your regional Medical Officer of Health for more information).</p>				
St. Bride's	St. Bride's	North Side Brook	Not Given	Not Ranked
<p style="color: red;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1989 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).</p>				
St. John's	St. John's	Petty Harbour Long Pond	97	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
St. John's	St. John's	Windsor Lake	100	excellent
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	100	excellent
St. Judes	St. Judes	Chute Brook	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 16, 2011 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

St. Judes	St. Judes	Uncle Arthur Brook	Not Given	Not Ranked
-----------	-----------	--------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 24, 2005 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).

St. Lawrence	St. Lawrence	St. Lawrence River	Not Given	Not Ranked
--------------	--------------	--------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 304.8 ug/l (Please see HAA report for details).

St. Lawrence	St. Lawrence - PWDU	St. Lawrence River	94	very good
--------------	---------------------	--------------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE, PH (Please see Tap Water report for details).

St. Lewis	St. Lewis	Tub Harbour Pond	Not Given	Not Ranked
-----------	-----------	------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 290.75 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 200.1 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 12, 2020 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
St. Lunaire-Griquet	Gunners Cove	Lookout Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 170.6 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 198.9 ug/l (Please see HAA report for details).</p>				
St. Lunaire-Griquet	St. Lunaire-Griquet	Joe's Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 251.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 248.7 ug/l (Please see HAA report for details).</p>				
St. Pauls	St. Pauls	Two Mile Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 275.95 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 326.8 ug/l (Please see HAA report for details).</p>				
St. Shott's	St. Shott's	Unnamed Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 12, 2019 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).</p>				
Steady Brook	Steady Brook	Wellfield + Steady Brook	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 173.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 184.8 ug/l (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 1, 2021 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact your regional Medical Officer of Health for more information).</p>				
Stephenville	Stephenville	Well Field	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Stoneville	Stoneville	Dog Bay Pond Brook	97	excellent
------------	------------	--------------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR (Please see Tap Water report for details).

Straitsview	Straitsview	Saddle Hill Pond	Not Given	Not Ranked
-------------	-------------	------------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 17, 1998 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Summerford	Summerford (+Cottlesville)	Rushy Cove Pond	Not Given	Not Ranked
------------	----------------------------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 277.75 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 189.2 ug/l (Please see HAA report for details).

Sunnyside (T.B.)	Sunnyside	Center Cove River	Not Given	Not Ranked
------------------	-----------	-------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 249.13 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 243.2 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 6, 2020 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact your regional Medical Officer of Health for more information).

Terrenceville	Terrenceville	Big Brook	Not Given	Not Ranked
---------------	---------------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 338 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 399.8 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 7, 2020 for the following reason: Escherichia coli (E. coli) detected AND repeat samples can not be taken as required. (Please contact your regional Medical Officer of Health for more information).

Thornlea	Thornlea	Big Bakeapple Pond	Not Given	Not Ranked
----------	----------	--------------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 16, 2011 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Tilt Cove	Tilt Cove	Castle Rock Pond	Not Given	Not Ranked
-----------	-----------	------------------	-----------	------------

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 20, 1991 for the following reason: Water Supply has no disinfection system. (Please contact your regional Medical Officer of Health for more information).

Tizzard's Harbour	Tizzard's Harbour	Rocky Pond	Not Given	Not Ranked
-------------------	-------------------	------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 92.7 ug/l (Please see HAA report for details).

Torbay	Torbay	North Pond	Not Given	Not Ranked
--------	--------	------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 243.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 131.6 ug/l (Please see HAA report for details).

Trepassey	Trepassey	Miller's Pond	Not Given	Not Ranked
-----------	-----------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 265.85 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 419.6 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 29, 2018 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Trepassey	Trepassey	Broom Cove Pond	Not Given	Not Ranked
-----------	-----------	-----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 439.25 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 286.5 ug/l (Please see HAA report for details).

Trinity	Trinity, T.B.	Indian Pond	Not Given	Not Ranked
---------	---------------	-------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 195.5 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 182.8 ug/l (Please see HAA report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Trinity Bay North	Little Catalina	Whirl Pond	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: MANGANESE (Please see Tap Water report for details).</p> <p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 213.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 190.6 ug/l (Please see HAA report for details).</p>				
Trinity Bay North	Melrose	Whirl Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 260.5 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 199.7 ug/l (Please see HAA report for details).</p>				
Trinity Bay North	Port Union, Catalina (+Little Catalina)	Whirl Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 218.25 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 314 ug/l (Please see HAA report for details).</p>				
Triton	Triton, Jim's Cove, Card's Harbour	Triton Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 110.13 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 87 ug/l (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 4, 2012 for the following reason: Partial - unable to get chlorine residuals (harbour Road) partial BWA - No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Trout River	Trout River	Feeder Brook	100	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Twillingate	Twillingate	Wild Cove Pond	Not Given	Not Ranked

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 123 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 149.5 ug/l (Please see HAA report for details).

Upper Island Cove	Upper Island Cove	Kelly's Pond (Spider's Pond)	Not Given	Not Ranked
-------------------	-------------------	------------------------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 117.9 ug/l (Please see HAA report for details).

Victoria	Victoria (+Salmon Cove)	Rocky Pond	95	excellent
----------	-------------------------	------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Wabush	Wabush	Wahnahnish Lake	100	excellent
--------	--------	-----------------	-----	-----------

West Bay	West Bay	Victor's Brook	Not Given	Not Ranked
----------	----------	----------------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 167.65 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 131 ug/l (Please see HAA report for details).

West Bay	West Bay	Unnamed Brook	Not Given	Not Ranked
----------	----------	---------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 28, 2010 for the following reason: Chlorination system is turned off by operator, due to lack of funds to operate. (Please contact your regional Medical Officer of Health for more information).

West St. Modeste	West St. Modeste	Well Field	Not Given	Not Ranked
------------------	------------------	------------	-----------	------------

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
----------------	---------------	-------------	------	--------

Westport	Westport	Western Brook Pond	Not Given	Not Ranked
----------	----------	--------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 20, 1991 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Whitbourne	Whitbourne	Hodges River	Not Given	Not Ranked
------------	------------	--------------	-----------	------------

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 160.8 ug/l (Please see HAA report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 24, 2019 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).

Whiteway	Whiteway (+Cavendish)	Long Pond	Not Given	Not Ranked
----------	-----------------------	-----------	-----------	------------

THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 155 ug/l (Please see THM report for details).

HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 212 ug/l (Please see HAA report for details).

Whiteway	Whiteway - PWDU	Long Pond	95	excellent
----------	-----------------	-----------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Wild Cove	Wild Cove	Hedderson's Pond Brook	Not Given	Not Ranked
-----------	-----------	------------------------	-----------	------------

THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).

BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 20, 1991 for the following reason: Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact your regional Medical Officer of Health for more information).

Winterton	Winterton	Western Pond	95	excellent
-----------	-----------	--------------	----	-----------

AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area	Source Name	DWQI	Rating
Wooddale	Wooddale	Northern Arm Lake	Not Given	Not Ranked
<p style="color: red; margin: 0;">THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p style="color: red; margin: 0;">HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Woodstock	Woodstock	Mill Pond	Not Given	Not Ranked
<p style="color: red; margin: 0;">THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p style="color: red; margin: 0;">HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p style="color: red; margin: 0;">BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 26, 2007 for the following reason: No free chlorine residual detected in the water distribution system. (Please contact your regional Medical Officer of Health for more information).</p>				
Woody Point	Woody Point	Winterhouse Brook	97	excellent

A Drinking Water Quality Index (DWQI) is a means to summarize water quality data into simple terms (e.g. good) for reporting to the public in a consistent manner. Similar to the UV index or an air quality index , it tells us, in simple terms, what the quality of drinking water is from your drinking water supply.

Essentially the DWQI is calculated by comparing the water quality data to the Guidelines for Canadian Drinking Water Quality. This calculation produces a score between 0 and 100. A higher score means a better quality of drinking water. The scores are then ranked into one of the six categories described below:

Excellent: (DWQI Value 95-100) - Water quality is protected with a virtual absence of impairment; conditions are very close to pristine levels; these index values can only be obtained if all measurements meet recommended guidelines virtually all of the time.

Very Good: (DWQI Value 89-94) - Water quality is protected with a slight presence of impairment; conditions are close to pristine levels.

Good: (DWQI Value 80-88) - Water quality is protected with only a minor degree of impairment; conditions rarely depart from desirable levels.

Fair: (DWQI Value 65-79) - Water quality is usually protected but occasionally impaired; conditions sometimes depart from desirable levels.

Marginal: (DWQI Value 45-64) - Water quality is frequently impaired; conditions often depart from desirable levels.

Poor: (DWQI Value 0-44) - Water quality is almost always impaired; conditions usually depart from desirable levels