



GOVERNMENT OF  
NEWFOUNDLAND AND LABRADOR  
Department of Municipal Affairs and Environment

## CERTIFICATE OF APPROVAL

Pursuant to the Environmental Protection Act, SNL 2002 c E-14.2 Section 83

Issue Date: *February 17, 2016*

Approval No. AA16-025632A

*Amendment: November 28, 2019*

Expiration: *February 17, 2021*

File No. 716.006

Proponent: Newfoundland and Labrador Hydro  
Hydro Place, 500 Columbus Drive  
P.O. Box 12400, St. John's, NL  
A1B 4K7

Attention: Rod Healey, Manager – Environmental Department

Re: Rigolet Diesel Generating Station

Approval is hereby given for the operation of three (3) prime power generating units at Rigolet, Labrador.

This Certificate of Approval does not release the proponent from the obligation to obtain appropriate approvals from other concerned provincial, federal and municipal agencies. Nothing in this certificate of approval negates any regulatory requirement placed on the proponent. Where there is a conflict between conditions in this certificate of approval and a regulation, the condition in the regulation shall take precedence. Approval from the Department of Environment and Conservation shall be obtained prior to any significant change in the design, construction, installation, or operation of the diesel generating units at the Rigolet diesel generating station, including any future expansion of the diesel generating units. This Certificate of Approval shall not be sold, assigned, transferred, leased, mortgaged, sublet or otherwise alienated by the proponent without obtaining prior approval from the Minister.

This Certificate of Approval is subject to the terms and conditions as contained therein, as may be revised from time to time by the Department. Failure to comply with any of the terms and conditions may render this Certificate of Approval null and void, may require the proponent to cease all activities associated with this Certificate of Approval, may place the proponent and its agent(s) in violation of the *Environmental Protection Act*, and will make the proponent responsible for taking such remedial measures as may be prescribed by the Department. The Department reserves the right to add, delete or modify conditions to correct errors in the Certificate of Approval or to address significant environmental or health concerns.

  
For MINISTER



# TERMS AND CONDITIONS FOR APPROVAL No. AA16-025632A

November 28, 2019

## General

1. This Certificate of Approval is for the operation of three (3) prime power diesel generating units, as outlined in Table 1, located at Rigolet diesel generating station in Labrador. Extensive future expansion or change of activities will require a separate Certificate of Approval.

Number of Units	Unit No.	Date of Manufacture	Power Rating (kW)	Manufacturer	Model
1	2065	2002	320	Caterpillar	CAT3406
1	2081	2007	455	Caterpillar	CAT C15
1	2101	2018	545	Caterpillar	C18

2. Certificate of Approval AA16-025632 is revoked and replaced by this Certificate of Approval.
3. Any inquiries concerning this approval shall be directed to the St. John's office of the Pollution Prevention Division (telephone: (709) 729-2556; or facsimile: (709) 729-6969.
4. In this Certificate of Approval:
  - **Department** means the Department of Municipal Affairs and Environment and its successors;
  - **Director** means the Director of the Pollution Prevention Division of the Department;
  - **GAP** means *Storage and Handling of Gasoline and Associated Products Regulations, 2003*;
  - **licensed** means has a Certificate of Approval issued by the Minister to conduct an activity;
  - **Minister** means the Minister of the Department;
  - **NLH** means Newfoundland & Labrador Hydro;
  - **register(ed)**, in the context of storage tanks, means that information regarding the storage tank system has been submitted to a Service NL office and a registration number has been assigned to the storage tank system. In the context of dispersion modelling, registered means submitted to and approved by the Department in accordance with departmental policy and guidelines;
  - **regulated substance** means a substance subject to discharge limit(s) under the *Environmental Control Water and Sewage Regulations, 2003*;

- **spill or spillage** means a loss of gasoline or associated product in excess of 70 litres from a storage tank system, pipeline, tank vessel or vehicle, or an uncontrolled release of any volume of a regulated substance onto or into soil or a body of water;
- **storage tank system** means a tank and all vent, fill and withdrawal piping associated with it installed in a fixed location and includes a temporary arrangement;
- **used glycol** means glycol that, through use, storage or handling, can no longer be used for its original purpose; and
- **used oil** means oil that, through use, storage or handling, can no longer be used for its original purpose.

5. All necessary measures shall be taken to ensure compliance with all applicable acts, regulations, policies and guidelines, including the following, or their successors:

- *Environmental Protection Act;*
- *Water Resources Act;*
- *Air Pollution Control Regulations, 2004;*
- *Environmental Control Water and Sewage Regulations, 2003;*
- *Halocarbon Regulations;*
- *Storage and Handling of Gasoline and Associated Products Regulations, 2003; and*
- *Used Oil and Used Glycol Control Regulations.*

This Approval provides terms and conditions to satisfy various requirements of the above listed acts, regulations, policies, guidance documents and guidelines. If it appears that any of the pertinent requirements of these acts, regulations, policies and guidelines are not being met, then a further review of the works shall be conducted, and suitable pollution control measures may be required by the Minister.

6. All reasonable efforts shall be taken to minimize the impact of the operation on the environment. Such efforts include:

- minimizing the area disturbed by the operation,
- minimizing air or water pollution,
- finding alternative uses, acceptable to the Director, for waste or rejected materials,
- removing equipment or structures when they no longer have further use, and
- considering the requirement for the eventual rehabilitation of disturbed areas when planning the development of any area on the facility property.

7. NLH shall provide to the Department, within a reasonable time, any information, records, reports or access to data requested or specified by the Department.

8. NLH shall keep all records or other documents required by this Approval at the diesel generating site for a period of not less than three (3) years, beginning the day they were made. These records shall be made available for review by officials of the Department or Service NL when requested.

9. Should NLH wish to deviate in any way from the terms and conditions of this

Certificate of Approval, a written request detailing the proposed deviation shall be made to the Minister. NLH shall comply with the most current terms and conditions until the Minister has authorized otherwise. In the case of meeting a deadline requirement, the request shall be made at least 60 days ahead of the applicable date as specified in this Approval or elsewhere by the Department.

### **Waste Management**

10. The management of waste generated at the facility is subject to compliance with the *Environmental Protection Act*. All non-industrial waste shall be stored in a manner acceptable to the Department and, on at least a weekly basis, be disposed of:
- at an authorized waste disposal site, with the permission of the owner/operator of the site; or
  - by some other means acceptable to the Department.

If required, industrial waste shall be disposed of by a licensed operator.

### **Noise**

11. Efforts shall be made to minimize and control noise resulting from the operations and maintenance of the three (3) diesel generating units at Rigolet diesel generating station.

### **Spill Prevention and Containment**

12. All on site storage of petroleum shall comply with the *Storage and Handling of Gasoline and Associated Products Regulations, 2003*, or its successor. Storage tank systems shall be registered with the Service NL. All aboveground storage tanks shall be clearly and visibly labelled with their GAP registration numbers.
13. Where applicable, all tanks and fuel delivery systems shall be inspected to appropriate American Petroleum Institute or Underwriters' Laboratories' Canada standards, or any other standards acceptable to this Department. The required frequency of inspections may be changed at the discretion of the Director.

### **Used Oil and Used Glycol**

14. Used oil and used glycol shall be retained in separate approved or registered tanks or closed containers, and disposed of by a company licensed for handling and disposal of used oil and/or used glycol products.
15. Information on used oil that is generated by the diesel generating units shall be submitted to the Director for review within 30 days of the beginning of each calendar year. This shall include a description of:
- the type(s) of oil used;
  - the method of disposal for the used oil, and
  - the approximate total volume of used oil generated during the previous year.
16. In the event that off-site used oil is stored in the on-site storage tank(s), the

information listed above shall also be required for the off-site systems.

### **Ambient Air**

17. Pending the results of any ambient air monitoring, stack emission testing, and/or dispersion modeling, the Director may require that NLH take measures deemed necessary to ensure the requirements of the *Air Pollution Control Regulations, 2004* are being met.

### **Annual Air Emission Reporting**

18. NLH shall submit an annual Air Emission Report to the Director by *February 28* of each year. The report shall include:
- the estimated annual emissions of the following flue gas constituents: SO<sub>2</sub>, NO<sub>x</sub>, CO<sub>2</sub>, CO and particulates; and
  - the actual calculations including factors, formulae and/or assumptions used.

### **Monitoring Alteration**

19. Although a monitoring program is not part of this approval, the Department may require a monitoring program when it is the judgement of the Director that:
- pollutants might be released to the surrounding environment without being detected, or
  - an adverse environmental effect may occur.

### **Reporting**

20. All incidents of:
- non-conformance of any condition within this Approval; or
  - spillage or leakage of a regulated substance; or
  - verbal or written complaints of an environmental nature received from the public by NLH and related to the Port Hope Simpson diesel generator site, including complaints submitted anonymously;

shall be immediately reported, within one working day, to the Department.

A written report including a detailed description of the incident, summary of contributing factors, and an Action Plan to prevent future incidents of a similar nature, shall be submitted to the Department. The Action Plan shall include a description of actions already taken and future actions to be implemented, and shall be submitted within thirty days of the date of the initial incident.

21. Any spillage or leakage of gasoline or associated product shall be reported immediately through the Canadian Coast Guard at 1-(709)-772-2083.

### **Expiration**

22. This Certificate of Approval expires *February 17, 2021*.
23. Should NLH wish to continue to operate the Rigolet diesel generating units beyond this expiry date, a written request shall be submitted to the Director for the renewal of this Approval. Such request shall be made prior to *August 17, 2020*.

cc: Ms. Susan Hoddinott – Regional Director  
Service NL  
P. O. Box 2006  
Corner Brook, NL  
A2H 6J8