



1. ALL POSTS, RAIL AND BRACES TO BE SCHEDULE 40 CONTINUOUS WELD PIPE.
2. ALL TIE WIRE TO BE GALVANIZED STEEL.
3. CHAIN LINK FABRIC TO BE INDUSTRIAL GRADE GALVANIZED STEEL.
4. CONCRETE FOOTINGS TO BE 20MPa.
5. END POSTS TO BE PLACED AT THE ENDS OF A STRETCH OF FENCE AND AT GATES.
6. CORNER POSTS TO BE PLACED AT CORNERS AND CHANGES IN DIRECTION GREATER THAN 10°.
7. STRAINING POSTS TO BE PLACED AT CHANGES IN GRADE GREATER THAN 30°.

TYPICAL CHAIN LINK FENCE WITH GATES