



NOTES:

1. THE WIDTH OF THE EXCAVATION MAY BE REDUCED BY THE ENGINEER IN ACCORDANCE WITH SECTION 423.04 OF THE SPECIFICATIONS BOOK PROVIDED SURROUNDING SOIL IS COMPETENT ENOUGH TO SUPPORT DESIGN LOADS.
2. WIDTH FOR BEDDING AND BACK FILLING TO BE ADJUSTED IN ACCORDANCE WITH NOTE 1.
3. REFER TO SECTION 1233 FOR HARD FOUNDATION.