

TRENCH SECTION FOR WATER, SEWER, OR FORCEMAIN

NOTES:

- 1. BEDDING TYPE SHALL BE AS SPECIFIED IN THE SCHEDULE OF QUANTITIES AND PRICES.
- 2. EXCAVATION WIDTH FOR PAYMENT AS PER LIMITS FOR MEASUREMENT IN CONTRACT DOCUMENT.

DEPTH	MIN. WIDTH
0-4m	1500mm
>4m, <6m	2000mm
<u>></u> 6m	2500mm

3. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

MASTER SPECIFICATIONS

SINGLE PIPE TRENCH DETAIL

DRAWING NUMBER

04020

DATE: FEBRUARY 2019 REV. 1.0

SCALE: N.T.S.