



TRENCH SECTION FOR WATER AND SEWER

NOTES:

1. BEDDING TYPE SHALL BE AS SPECIFIED IN THE SCHEDULE OF QUANTITIES AND PRICES.
2. EXCAVATION WIDTH FOR PAYMENT AS PER LIMITS FOR MEASUREMENT IN CONTRACT DOCUMENT.
3. UNDER NO CIRCUMSTANCES, SHALL ANY FORCEMAIN BE INSTALLED AT ZERO SLOPE.
4. * CL OF TRENCH FOR MEASUREMENT PURPOSES.
5. MAINTAIN MINIMUM HORIZONTAL SEPARATION BETWEEN SEWER AND WATERMAIN OF 3.0 m. WHERE NOT ACHIEVABLE, MAINTAIN MINIMUM VERTICAL SEPARATION OF 0.45 m FROM CROWN OF SEWERMAIN.
6. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.
7. BACKFILL BY MACHINE. MAX LIFT SIZE 300mm.

DEPTH	MIN. WIDTH
0-4m	1500mm
>4m, <6m	2000mm
≥6m	2500mm

**MASTER
SPECIFICATIONS**

DOUBLE PIPE TRENCH DETAIL

DRAWING NUMBER

04030

DATE:

MARCH 2020

SCALE:

N.T.S.