



**1200mm DIAMETER  
MAN HOLE**

**PLAN OF FLAT CAP  
WITH REINFORCING  
STEEL BARS**

**PLAN OF FLAT CAP  
WITH WWR**

**SECTION B-B**

**SECTION C-C**

**NOTES:**

1. CENTER REINFORCING STEEL IN RISER ±20mm. ALL OTHER REINFORCING STEEL SHALL HAVE 25mm MINIMUM COVER.
2. STEPS SHALL BE ACCORDING TO STANDARD DRAWING 04280.
2. ALL DIMENSIONS ARE NOMINAL.
3. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

**MASTER  
SPECIFICATIONS**

**PRECAST CONCRETE MAN HOLE  
COMPONENTS**  
1200mm DIAMETER

DRAWING NUMBER 04220

DATE:  
MARCH 2016

SCALE:  
N.T.S.