



NOTES:

1. SHORT RADIUS BENDS ARE NOT PERMITTED UNDER ANY CIRCUMSTANCES.
2. MAXIMUM DEFLECTION IS 45° (ONE 45° BEND OR TWO 22.5° BENDS).
3. IF GREATER DEFLECTION THAN 45° IS APPROVED BY THE ENGINEER THEN A CLEAN OUT MUST BE INSTALLED UPSTREAM OF DEFLECTION (SEE STANDARD DRAWING 0865).
4. MINIMUM 1.0m DISTANCE BETWEEN TWO LONG RADIUS BENDS.
5. SERVICES TO BE BROUGHT TO PROPERTY BOUNDARY AND CONNECTED TO EXISTING SERVICE OR TERMINATED AS PER PROJECT REQUIREMENTS.
6. THE REQUIREMENTS OF THIS PLAN MUST BE FOLLOWED FOR THE FULL LENGTH OF THE SERVICE LATERAL, FROM THE BUILDING TO THE POINT OF CONNECTION TO THE PUBLIC MAINS.
7. MAINTAIN MINIMUM HORIZONTAL SEPARATION BETWEEN SEWER AND WATERMAIN OF 3.0 m. WHERE NOT ACHIEVABLE, MAINTAIN MINIMUM VERTICAL SEPARATION OF 0.45 m FROM CROWN OF SEWERMAIN.
8. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

MASTER SPECIFICATIONS

HOUSE SERVICES CONNECTION

DRAWING NUMBER 04460

DATE: MARCH 2016
SCALE: N.T.S.