



**NOTES:**

1. SEWER SERVICE CONNECTIONS TO THE MAIN PIPE SEWER SHALL BE MADE USING FACTORY MADE TEES OR WYES, STRAP-ON-SADDLES, OR OTHER APPROVED SADDLES.
2. BEDDING MATERIAL SHALL BE TYPE 1 FOR PVC, AND TYPE 3 FOR DUCTILE IRON PIPES.
3. CAP OR PLUG AT PROPERTY LINE SHALL BE ADEQUATELY PLACED.
4. MAINTENANCE HOLES SHALL BE USED AT THE MAIN SEWER TO CONNECT SERVICE CONNECTIONS GREATER THAN OR EQUAL TO 200mm.
5. FOR NEW CONSTRUCTION, SADDLES SHALL BE INSTALLED ON THE MAIN PIPE BEFORE THAT PIPE IS LAID.
6. APPROVED CUT-IN TOOL SHALL BE USED FOR FIELD MADE CONNECTIONS.
7. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

**MASTER SPECIFICATIONS**

**SEWER SERVICE CONNECTIONS FOR FLEXIBLE MAIN PIPE SEWER**

DRAWING NUMBER 04470

DATE: FEBRUARY 2019

SCALE: N.T.S.