



NOTES:

1. COUPLINGS SHALL NOT BE PERMITTED UNLESS THE SERVICE LENGTH EXCEEDS 20m BETWEEN THE MAIN STOP AND CURB STOP.
2. ALL WATER SERVICES SHALL BE INSTALLED 90° TO THE LONGITUDINAL AXIS OF THE WATERMAIN.
3. BACKFILL MATERIAL WITHIN 500mm OF SERVICE BOX SHALL BE NATIVE OR IMPORTED, AS SPECIFIED.
4. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

**MASTER
SPECIFICATIONS**

WATER SERVICE CONNECTION
32, 38, and 50mm DIAMETER SIZES

DRAWING NUMBER 04520

DATE: MARCH 2016
SCALE: N.T.S.