



NOTES:

1. HYDRANT LEADS TO BE 150 mm DIAMETER PIPE.
2. CONCRETE FOR THRUST BLOCKS TO BE 20 MPa.
3. HYDRANT DRAIN TO BE KEPT CLEAR OF CONCRETE THRUST BLOCK.
4. TEES FOR FIRE HYDRANT LATERALS TO BE 150 mm OFF ALL DIAMETER LINES. ALL LATERALS TO BE 150 mm DIAMETER PIPE.
5. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

MASTER
SPECIFICATIONS

HYDRANT CONNECTION

DRAWING NUMBER 04560

DATE:
MARCH 2016

SCALE:
N.T.S.