

GOVERNMENT OF NEWFOUNDLAND & LABRADOR
MUNICIPAL WATER, SEWER AND ROADS SPECIFICATIONS

List of Revisions, June 2014

<u>Item</u>	<u>Section</u>	<u>Revision</u>
1.	WATER MAINS SECTION 02713 (2.1 PIPE AND FITTINGS)	<p>Following new clause 2.1.3.2 added to PART 2-PRODUCTS Item numbering of subsequent clause changed to reflect addition.</p> <p>To CSA B137.3.1, rated at 235psi, unless otherwise specified in the Schedule of Quantities and Prices or to AWWA C909 for pipe sizes 100 mm to 450 mm, All pipe shall be certified to CSA B173.3.1, shall be U.L. and F.M. approved, and shall be 1 MPa gasket bell end, cast iron outside diameter</p>
2.	WATER MAINS SECTION 02713 (2.4 SERVICE CONNECTIONS)	<p>Following new clause 2.4.7 added to PART 2- PRODUCTS Item numbering of subsequent clause changed to reflect addition.</p> <p>Crossed linked polyethylene pipe: To conform to AWWA C904, ASTM F876, F877, F2023, NSF 14 & 61, and CSA B137.5. Pipe to have CTS outer diameter, with operating pressure of 160psi at 23°C / 73.4°F, 100psi at 82°C / 180°F, and 80 psi at 93°C / 200°F. Pipe to be marked with manufacturing date, and footage every five feet.</p>
3.	Standard Drawings # 0205 & 0208.	<p>Changed the department's name from <i>Municipal Affairs</i> to Municipal & Intergovernmental Affairs on the following standard drawings.</p> <p>a) Drawing # 0205 Departmental Project Sign b) Drawing # 0208 Multi-Year Capital Works Project Sign</p>